

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2021					Day : Thursday				Date : 04.03.21				
Probable Maximum Demand : 10800 MW					Probable Maximum Generation : 13951 MW					Rule Curve = 92.52 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 91.04 ft. Today = 90.92 ft.								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.03.21 (Yesterday)		04.03.21 (Today)		03.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal Limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.		
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	200	200				
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	3x4.3 35	108	108	12	12	12	12				
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Under maint.		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	370	380	450	450	70			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	338	350	412	412				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.		
13	Siddhirganj 100 PP(Dutch Bangle)	HFO (QRPP)	12x8.9	100	100	85	85	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	260	280	300	300				
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	16	86	100	100				
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	45	38	100	100				
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	50	55	55	55				
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	68	100	100	100				
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	16	102	100	102				
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	22	22				
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	35	53	58	58				
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33				
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33				
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	25	52	52				
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	50	95	105	105				
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	115	149	149				
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	9	37	50	50				
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	245	290	300	300				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149				
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300				
32	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
33	Aurabati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	35	48	55	55				
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	86	104	104				
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	121	144	144				
	Spectra Solar Plant Ltd.	Solar (IPP)				20	0	30	0				
Dhaka Zone Total					6171	5972	2543	3134	3732	3954	405	1160	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	18	25	25	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	45	50	50	50				
45	Sikalbaha 105 MW PP (Baraka Sik)	HFO (IPP)	6x18.415	105	105	0	0	50	100				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	125	105	0	0				
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Gas Shortage		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	307	303	300	300				
49	Julda 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	10	100	100				
50	Julda 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	100	100	100				
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	85	85				
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	16	16	16				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	20	10	20				
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	80	102	102				
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	31	54	54				
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
57	Julda unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	90	100	100				
58	Chattogram 116 MW PP (Anima Er	HFO (IPP)	6x21.06	116	116	0	0	116	116				
Chattogram Zone Total					2442	2382	818	985	1313	1348	565	180	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	10	10	10	10	35	Gas Shortage		
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	159	202	225	225				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	260	260	300	300				
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	265	265	300	300				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas shortage		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	33	0	50				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	139	0	0				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	103	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	5	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	23	52	52				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	16	20	20				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	88x1.4+40x1.515+15x1.056	200	200	0	0	0	200				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	34	114	114				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	26	68	113	113				
**	Import (Tirupura)	India		160	160	10	148	135	147				
	Bhairob 54.5 MW	HFO (IPP)				56	56	0	0				
Cumilla Zone Total					3040	2980	1111	1422	1540	1802	879	0	
79	RPCL 210MW CCPP	Gas (SIPP)	4x35+1x70	210	202	82	103	110	110				
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	24	81	82	82				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	35	92	115	115				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	192	200	200	200				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutahalli 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0				
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	21	25	22	22				
Mymensing Zone Total					717	709	421	518	598	546	0	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.03.21 (Yesterday)		04.03.21 (Today)		03.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)		
						Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	8	43	43	43				
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0				
89	Fenchugonj 51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	45	49	51	51				
90	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021	
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	130	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	35	36	36	36		30	Under maint.	
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	162	161	162	162	169		Gas Shortage	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	83	83	83				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	91	137	137	137		94	Under maint.	
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20				
98	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020	
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	5	5	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8				
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	341	341				
102	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	330	330	350	350				
	Bibiyana South 400 MW	Gas (PDB)				322	320	320	320				
	Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	0	0			On Test	
Sylhet Zone Total						2033	1988	1538	1641	1735	1735	169	124
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	210	175	240	240	235		Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	4	25	25				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	16	80	115	115				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	8	8	40	40				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	717	716	723	723				
Khulna Zone Total						2288	2284	1060	1088	1458	1744	235	0
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	110	110				
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	32	26	27				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.	
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	83	90	95	95				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	430	350	620	620				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	10	150	150				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				10	10	51	51				
Barishal Zone Total						1826	1826	559	602	1052	1053	0	194
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	50				
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	12	0	40				
123	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	12	12	12	12				
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	104	104				
125	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	50	50				
126	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	16	50	50				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	34				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	167	138	170	170				
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	338	324	400	400				
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	22	22				
133	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020	
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	25	45	52	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	113	113				
Rajshahi Zone Total						2193	2183	778	1000	1297	1421	601	0
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	111	108	85	85	-23		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150				
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		20	Under Overhauling	
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	113	107	113	113				
142	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara, Tatulia 8 MW Solar PP (Sympha P)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
Rangpur Zone Total						685	605	381	365	356	348	62	20
Sub-total: Plants in operation						21395	20929	9209.0	10755	13081	13951	2916	1678
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						8830	10312	12542	13376				
(B) Contract expired power plants													
Sub-Total: Plants under long term maintenance						0	0	0	0	0	0		
Gross Total						21395	20929	9209	10755	13081	13951	2916	1678
(C) Actual data of 03.03.21 (Yesterday) Wednesday :													
01.	Max. Demand (Generation end) : 10755.00 MW, at = 19:00 hrs					12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand (Sub-station end) : 10312.00 MW, at = 19:00 hrs					Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end) : 10755.00 MW, at = 19:00 hrs					Dhaka	3639	3639	0	Myemsingh	895	895	0
04.	Minimum Generation (Generation end) : 7437.00 MW, at = 5:00 hrs					Dhaka	3639	3639	0	Myemsingh	895	895	0
05.	Day-peak Generation (Generation end) : 9209.00 MW, at = 12:00 hrs					Chattogram	1115	1115	0	Sylhet	388	388	0
06.	Evening-peak Generation (Generation end) : 10755.00 MW, at = 19:00 hrs					Khulna	1254	1254	0	Barishal	294	294	0
07.	Evening Peak Load-shed (Sub-station end) : 0.00 MW, at = 19:00 hrs					Rajshahi	1074	1074	0	Rangpur	706	706	0
08.	Actual Minimum Generation up to 8:00 hrs : 6990.00 MW, at = 7:00 hrs					Cumilla	947	947	0				
09.	Generation shortfall at evening peak due to : :									Total	10312	10312	0
	a) Gas limitation : 2694 MW					13.	Fuel cost :	(a) Gas = 128750416 Taka		(c) Coal = 82489177 Taka		Taka	
	d) Coal supply Limitation : 62 MW							(b) Oil = 394796344 Taka		Total = 606035937 Taka		Taka	
	b) Low water level in Kaptai lake : 160 MW					14.	Maximum Temperature in Dhaka was : 33.4° C						
	c) Plants under shut down/ maintenance : 1678 MW					15.	Export through East-West interconnections :						
10.	Total Energy (Generation + India Import) : 220.65 MCKWh						At evening peak-hour : -417 MW, at 19:00 hrs						
	By Gas = 123.439 MCKWh						Maximum : -417 MW, at 19:00 hrs						
	By Coal = 17.055 MCKWh						Energy : 0.7815 MCKWh						
	By Solar= 0.689 MCKWh												
11.	Total Gas Supplied : 924.35 MMCFD												
(D) Forecast of 04.03.21 (Today) Thursday :													
01.	Maximum Demand : 10800 MW (Generation end)					04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation : 13951 MW (Generation end)					05.	Total Generation : 221.57 MCKWh						
03.	Maximum Shortage : -3151 MW (Generation end)					06.	Probable Max. Temperature in Dhaka : 33.2° C						

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation