

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month March, 2021		Day : Wednesday				Date : 10.03.21					
Probable Maximum Demand :		11400 MW		Yesterday = 90.03 ft		Probable Maximum Generation : 14911 MW		Today = 91.56 ft		Rule Curve =	
Water Level of Kaptai Lake at 06:00 AM											
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.03.21 (Yesterday)		10.03.21 (Today)		09.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/water/Coal limitation	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	a) Ghorasal Repowered CAPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.
	b) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	90	120	90	190		
2	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	270	300	300	300		
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	0	0	108	108	108	Gas Shortage
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Dirt in fuel gas
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	245	0	0	0	412	Dirt in fuel gas
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	200	221	220	220	114	ST Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	100	100	100		
14	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	305	305	255	235	300	300		
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	0	100	100	100		
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	100	100	100		
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55		
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	50	85	87	87		
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	102	100	100		
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	22	22		
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x167+7x8.73	80	80	48	55	58	58		
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	25	25		
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
24	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	25	52	52		
25	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	88	105	105		
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	100	149	149		
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	47	50	50		
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	34	280	300	300		
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	133	132	149	149		
31	Keraniganj 300 MW PP (APRI)	HSD (IPP)	25x6.14	300	300	0	0	100	300		
32	Bramhargan 100 MW PP (Aggregate)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
33	Aurabahi 100MW PP (Aggregate)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	0	55	55	55		
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55		
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	104	104	104		
38	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	144	144	144		
	Spectra Solar Plant Ltd.	Solar				25	0	30	0		
<b>Dhaka Zone Total</b>			<b>6171</b>	<b>5972</b>	<b>1833</b>	<b>2942</b>	<b>3495</b>	<b>3815</b>	<b>593</b>	<b>1351</b>	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
42	Raazari 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	50	50	50		
45	Sikalbaha 105 MW PP (Baraka Sika)	HFO (IPP)	6x18.415	105	105	0	0	50	100		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	110	120	120	120		
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Gas Shortage
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	250	306	300	300		
49	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	50	100	100		
50	Juldah 100 MW Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	0	100	100	100		
51	Dohazari - Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	102	102		
52	Halhazari 22 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	21	10	20		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	14	102	102		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
57	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
58	Chattogram 116 MW PP (Anima Er)	HFO (IPP)	6x21.06	116	116	0	17	116	116		
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>713</b>	<b>1153</b>	<b>1575</b>	<b>1610</b>	<b>445</b>	<b>180</b>	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	105	120	120	120		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	22	22	26	26	23	Gas Shortage
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	205	183	225	225		
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	300	280	300	300		
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	345	295	360	360		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	20	20	40	40	35	Gas shortage
65	Ashuganj 185MW PP (APSCL United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	0	50		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	91	85	90	90		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	128	170	200	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	3	11	11		
73	Jangala 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jangala 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	35	52	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	21	20	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+4x1.715+1x1.026	200	200	0	0	0	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	114	114		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	75	113	113		
**	Impoport (Tripura)	India		160	160	102	150	151	168		
	Bhairon 54.5 MW	HFO (IPP)				0	0	55	55		
<b>Cumilla Zone Total</b>			<b>3040</b>	<b>2980</b>	<b>1411</b>	<b>1572</b>	<b>1932</b>	<b>2200</b>	<b>718</b>	<b>0</b>	
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	115	120	160	160	82	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	12	14	22	22		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	16	81	81	81		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	45	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	160	200	200	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	36	0	50	0		
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	25	24	22	22		
<b>Mymensingh Zone Total</b>			<b>717</b>	<b>709</b>	<b>365</b>	<b>484</b>	<b>652</b>	<b>600</b>	<b>82</b>	<b>0</b>	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.03.21 (Yesterday)		10.03.21 (Today)		09.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	44	44	44			
88	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	22	22	22			
89	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	50	50	51	51			
90	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021
91	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163			
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11			
93	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	33	35	35	35	31		GT-9 Under maint.
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	302	300	300	300			
95	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	76	79	75	76			
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	176	0	0	0	231		Under maint.
97	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20			
98	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020
99	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	10	10			
100	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16			
101	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	325	270	341	341			
102	Bibiyana-II	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	340	317	366	366			
103	Bibiyana South	383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	250	250	320	320			
	Shahjibazar	100 MW GTTP	Gas (PDB)				0	0	0	0			On Test
<b>Sylhet Zone Total</b>				<b>2416</b>	<b>2371</b>	<b>1763</b>	<b>1582</b>	<b>1774</b>	<b>1775</b>	<b>0</b>	<b>262</b>		
104	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16			
105	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+ 1 x 132	410	410	385	245	400	400	165		Gas Shortage
106	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25			
107	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	13	60	60			
108	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220			
109	Khulna	115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	16	83	99	99			
110	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	20	50	100			
111	Noapara	40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	40	40	40			
112	Rupsha	105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	70	105	105	105			
113	Machumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			
**	Bheramara (HVDC)	India		1000	1000	774	725	740	740				
<b>Khulna Zone Total</b>				<b>2288</b>	<b>2284</b>	<b>1245</b>	<b>1231</b>	<b>1619</b>	<b>1905</b>	<b>165</b>	<b>0</b>		
114	Barsal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	96	110	110			
115	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	25	25	25			
116	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.
117	Bhola	95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	23	80	95	95			
118	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	350	500	620	620			
119	Potukhali	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150			
<b>Bhola Nutan Biddut BD LTD</b>				<b>Gas/HSD</b>			<b>117</b>	<b>15</b>	<b>0</b>	<b>0</b>			
<b>Barishal Zone Total</b>				<b>1826</b>	<b>1826</b>	<b>507</b>	<b>716</b>	<b>1000</b>	<b>1000</b>	<b>0</b>	<b>194</b>		
120	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
121		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	50			
122		Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
123		Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40			
124		Ammura 50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	0	12	44	44			
125		Chapanawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	101	104	104			
126		Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	50	50			
127		Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50			
128		Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	34			
129		Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
130		Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	199	140	200	225			
131		Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	206	180	200	225			
132		Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	426	346	400	400			
133		Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	22	22			
134		Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020
135		Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
136		Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	52	52			
137		Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	50	113	113	113			
138		Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	76	113	113	113			
<b>Rajshahi Zone Total</b>				<b>2193</b>	<b>2183</b>	<b>986</b>	<b>1186</b>	<b>1559</b>	<b>1733</b>	<b>381</b>	<b>0</b>		
139	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage
140		Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150			
141		Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	10	10	10			Under Overhauling
142		Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	113	113	113	113			
143		Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	8	0	0			
144		Majpara, Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
<b>Rangpur Zone Total</b>				<b>685</b>	<b>605</b>	<b>268</b>	<b>281</b>	<b>281</b>	<b>273</b>	<b>170</b>	<b>10</b>		
<b>Sub-total: Plants in operation</b>				<b>21778</b>	<b>21312</b>	<b>9091.0</b>	<b>11147</b>	<b>13887</b>	<b>14911</b>	<b>2554</b>	<b>1997</b>		
<b>Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss</b>						<b>8680</b>	<b>10643</b>	<b>13259</b>	<b>14237</b>				
<b>(B) Contract expired power plants</b>													
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0				
<b>Gross Total</b>				<b>21778</b>	<b>21312</b>	<b>9091</b>	<b>11147</b>	<b>13887</b>	<b>14911</b>	<b>2554</b>	<b>1997</b>		

  

Actual data of 09.03.21 (Yesterday)		Tuesday :		Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
01.	Max. Demand (Generation end)	11147.00	MW, at = 19:30 hrs	12.	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
02.	Max. Demand (Sub-station end)	10643.00	MW, at = 19:30 hrs	03.	Highest Generation (Generation end)	11147.00	MW, at = 19:30 hrs	04.	Minimum Generation (Generation end)	7915.00	MW, at = 5:00 hrs	05.	Day-peak Generation (Generation end)
06.	Evening-peak Generation (Generation end)	11147.00	MW, at = 19:30 hrs	07.	Evening Peak Load-shed (Sub-station end)	0.00	MW, at = 19:30 hrs	08.	Actual Minimum Generation Forecast up to 8:00	7989.00	MW, at = 5:00 hrs	09.	Generation shortfall at evening peak due to :
10.	Total Energy (Generation + India Import)	224.65	MKWh	11.	Total Gas Supplied	1074.25	MMCFD	13.	Fuel cost :	(a) Gas = 145175202	Taka	(c) Coal = 68961483	Taka
	By Gas = 137.330	MKWh	49.228	MKWh						(b) Oil = 349983793	Taka	Total = 564120478	Taka
	By Coal = 14.846	MKWh	1.712	MKWh									
	By Solar = 0.504	MKWh											
	By Hydro =												
11.	Total Gas Supplied	1074.25	MMCFD	14.	Maximum Temperature in Dhaka was :	31.3° C							
15.	Export through East-West interconnections :												
	At evening peak-hour	-110	MW, at 19:30 hrs										
	Maximum	-140	MW, at 18:30 hrs										
	Energy	0.4455	MKWh										

  

Forecast of 10.03.21 (Today)		Wednesday :		04.		05.		06.	
01.	Maximum Demand	11400	MW (Generation end)	04.	Maximum Load-shed	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	14911	MW (Generation end)	05.	Total Generation	229.75	MKWh		
03.	Maximum Shortage	-3511	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	35.5° C			

\* Captive Power \*\* Imported Power  
#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)  
Deputy Secretary, Generation