

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2021				Day : Thursday				Date : 11.03.21					
Probable Maximum Demand : 11200 MW				Probable Maximum Generation : 14811 MW				Rule Curve = 91.40 ft.					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 89.79 ft Today = 89.58 ft.									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.03.21 (Yesterday)		11.03.21 (Today)		10.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal Limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.		
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	90	190	190	190				
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300				
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	108	108	108	Gas Shortage		
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Dirt in fuel gas		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	260	250	0	0	200			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Dirt in fuel gas		
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	221	221	220	220	114	ST Under maint.		
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	240	240	300	300				
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	28	100	100	100				
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	100	100	100				
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55				
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	71	85	87	87				
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	24	102	100	100				
20	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22				
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	25	35	58	58				
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	25	25				
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	51	52	52				
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	62	90	105	105				
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	150	149	149				
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	49	50	50				
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	178	300	300	300				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149				
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300				
32	Bramhargan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
33	Aurabali 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	55	55	55	55				
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	91	90	104	104				
38	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	19	144	144	144				
	Spectra Solar Plant Ltd.	Solar (IPP)				11	0	30	0				
Dhaka Zone Total				6171	5972	2158	3053	3295	3515	643	1351		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	13	25	25	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	41	50	50	50				
45	Sikalbaha 105 MW PP (Baraka Sik)	HFO (IPP)	6x18.415	105	105	0	0	50	100				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	120	120	120				
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Gas Shortage		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	305	306	300	300				
49	Julda 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	40	100	100				
50	Julda 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	100	100	100				
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	102	102				
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	20	21	21				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	20	10	20				
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	8	54	102	102				
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	46	54	54	54				
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
57	Julda unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100				
58	Chattogram 116 MW PP (Anlima Er	HFO (IPP)	6x21.06	116	116	0	17	116	116				
Chattogram Zone Total				2442	2382	957	1198	1575	1610	445	180		
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	130	130	130				
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	22	23	26	26	22	Gas Shortage		
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	172	183	225	225				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	335	295	300	300				
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	30	360	360				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	55	55	55	0	Gas shortage		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	6	0	50				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	86	77	90	90				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	65	161	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	19	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	52	52				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	21	20	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	88x1.4+40x1.515+15x1.056	200	200	0	0	0	200				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	100	114	114				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	48	113	113	113				
**	Import (Tirupura)	India		160	160	20	140	151	168				
	Bhairab 54.5 MW	HFO (IPP)				0	37	55	55				
Cumilla Zone Total				3040	2980	1192	1483	1957	2225	682	0		
79	RPCL 210MW CCPP	Gas (SIPP)	4x35+1x70	210	202	114	123	160	160	79	Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	12	22	22				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	68	81	81	81				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	24	35	115	115				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	160	200	200	200				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	38	0	50	0				
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	24	22	22				
Mymensing Zone Total				717	709	405	475	652	600	79	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.03.21 (Yesterday)		11.03.21 (Today)		10.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening					
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	44	44					
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	22	31	30	30					
89	Fenchugonj 51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	48	53	51	51					
90	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021		
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163					
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	34	35	35	35		31	GT-9 Under maint.		
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	302	307	310	310					
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	79	80	80					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	150		231	Under maint.		
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	18	20	20					
98	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020		
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	10	10					
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	341	341					
102	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	322	322	366	366					
103	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	250	250	320	320					
	Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	0	0			On Test		
Sylhet Zone Total				2416	2371	1543	1625	1797	1947	0	262			
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16					
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	250	235	400	400	175		Gas Shortage		
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25					
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	12	60	60					
108	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220					
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	66	66	99	99					
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	50	100					
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	40	40	40					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	90	95	105	105					
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	727	725	739	739					
Khulna Zone Total				2288	2284	1133	1223	1618	1904	175	0			
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110					
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	34	33	33					
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.		
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	75	73	95	95					
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	470	520	620	620					
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150					
	Bhola Nutan Biddut BD LTD	Gas/HSD				70	72	0	0					
Barishal Zone Total				1826	1826	629	747	1008	1008	0	194			
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	50					
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40					
124	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	44	40	44	44					
125	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	100	100					
126	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	50	50					
127	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	50	50					
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	34					
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	140	140	200	225					
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	200	180	200	225					
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	388	394	400	400					
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22					
134	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020		
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	24	52	52	52					
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	70	113	113	113					
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113					
Rajshahi Zone Total				2193	2183	965	1320	1555	1729	381	0			
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150					
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	10	10	10	10		10	Under Overhauling		
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	113	113	113	113					
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Majpara, Tatulia 8 MW Solar PP (Sympa P)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
Rangpur Zone Total				685	605	278	273	281	273	170	10			
Sub-total: Plants in operation				21778	21312	9260.0	11397	13738	14811	2575	1997			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						8868	10915	13157	14185					
(B) Contract expired power plants														
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0					
Gross Total				21778	21312	9260	11397	13738	14811	2575	1997			
(C) Actual data of 10.03.21 (Yesterday) Wednesday :														
01.	Max. Demand (Generation end)	:	11397.00	MW,	at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand (Sub-station end)	:	10915.00	MW,	at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11397.00	MW,	at =	19:30 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	7989.00	MW,	at =	5:00 hrs	Dhaka	4036	4036	0	Myemsingh	878	878	0
05.	Day-peak Generation (Generation end)	:	9260.00	MW,	at =	12:00 hrs	Chattogram	1135	1135	0	Sylhet	393	393	0
06.	Evening-peak Generation (Generation end)	:	11397.00	MW,	at =	19:30 hrs	Khulna	1345	1345	0	Barishal	282	282	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:30 hrs	Rajshahi	1155	1155	0	Rangpur	700	700	0
08.	Actual Minimum Generation Forecast up to 8:00	:	7685.00	MW,	at =	5:00 hrs	Cumilla	991	991	0				
09.	Generation shortfall at evening peak due to :	:									Total	10915	10915	0
	a) Gas limitation	:	2245	MW			13.	Fuel cost :	(a) Gas = 137094140 Taka	(c) Coal = 74063470 Taka				
	d) Coal supply Limitation	:	170	MW				(b) Oil = 448473041 Taka	Total = 659630651 Taka					
	b) Low water level in Kaptai lake	:	160	MW										
	c) Plants under shut down/ maintenance	:	1997	MW										
10.	Total Energy (Generation + India Import)	:	227.82	MKWh			14.	Maximum Temperature in Dhaka was :	30.8° C					
	By Gas = 128.298		MKWh				15.	Export through East-West interconnections :						
	By Coal = 16.009		MKWh					At evening peak-hour :	-36	MW,	at	19:30 hrs		
	By Solar= 0.360		MKWh					Maximum	-110	MW,	at	19:00 hrs		
	By Hydro =		1.696	MKWh				Energy	0.095	MKWh				
11.	Total Gas Supplied	:	1027.30	MMCFD										
(D) Forecast of 11.03.21 (Today) Thursday :														
01.	Maximum Demand	:	11200	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14811	MW	(Generation end)		05.	Total Generation	:	223.88	MKWh			
03.	Maximum Shortage	:	-3611	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.7° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation