

Date : 12-Mar-21		Page -2					
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
	Ghorasal Repowered CCPP Unit-1	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	190	4599000	
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	300	7157127	Gas shortage
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	105	2463090	Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Dirty fuel(Gas)
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	96	236000	synchronized in 19.43.
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	0	0	Dirty fuel(Gas)
9	Meghnaghat 100 MW(EL)	QRPP	12*8.9	100	70	114240	Low demand
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	240	5786967	Dirty fuel(Gas)
11	Madanganj 102 PPI(Summit)	QRPP	6*17	100	72	376920	Low demand
12	Madanganj-55 MW PPI(Summit)	(IPP)	3*17.08+1*11.3	55	55	399155	
13	Keranganj 100 MW PP (Powerpa)	QRPP	8*13.45	100	0	214438	Line S/D.
14	Narsinghat 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	393408	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	145	3490000	Gas shortage
17	Siddhirgonj 100 PPI(Dutch Bangla	QRPP	12*8.9	100	92	426240	
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	221	5500347	ST Under maint.
19	Gagnagar 102 MW PP (Digital Po)	IPP	12*8.924	102	50	191952	Low demand
20	Katpadi 52 MW PP (Sinha)	IPP	7*7.9	51	12	46416	Low demand
21	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	54	1037160	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	32	112800	Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	351304	
24	Nabaganj 55 MW PP (Southern)	IPP	3*19.3	55	55	201447	
25	Boselia 108MW PP(RPCL)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
26	Summit Power (Madhabad+Ashuli)	SIPP, REB	3*3.67+*8.73	80	56	1167540	Engine problem
27	Maona 33 MW PPI(Summit)	SIPP, REB	4*8.73	33	33	820400	
28	Ruganaj 33 MW PPI(Summit)	SIPP, REB	4*8.73	33	33	790200	
29	Gazipur 52 MW PP	IPP	6*8.9	52	0	0	Reserve.
30	Tongi 80 MW GTPP	PDB	1* 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summ	IPP	16*17.076	300	247	2202981	Low demand
32	Keranganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve.
33	Bramhangan 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	132	2430720	Low demand
36	Gazipur 100 MW PP	RPCL	100 MW	105	17	284340	Engine problem
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	90	623040	Engine problem
38	Manikganj 162MW PPI(MPGL)	IPP	9*18	162	17	142560	Engine problem
	Spectra Solar Plant Ltd.	IPP	35	0	0	158378	
Dhaka area Total				5972	2491	41718170	
39	Chattogram TPP-1	PDB	1*210	180	120	2800000	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
40	Raozan 25 MW PP	IPP	3*8.9	25	25	69843	
41	Teknaf 20MW PP (Solartech/Teknaf	Solartech Energy	20	20	0	109755	
42	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	477120	
43	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	1688000	Unit-2 under maint
44	Sikalbaha 225MW	PDB	1*150+1*175	225	204	4907335	Gas shortage
45	Sikalbaha Peaking GT	PDB	1*150	150	120	2860398	
46	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	0	0	Reserve.
47	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under maint.
48	Dohazari-Kalash 100 MW Peaki	PDB	6*17	102	102	581746	
49	Juddah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	0	0	High Voltage.
50	Juddah 100 MW PP Unit-3 (Acorn)	IPP	0	100	86	507840	
51	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	445008	
*	Malancha, Ctg, EPZ (Uniled)		5*8.73+3*9.34	0	38	830400	
52	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	36480	Reserve.
53	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	30121	
54	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	197	3083673	Transformer problem.
55	Jodac Power	IPP	3*18.55+1*3.6	54	17	6186	Low demand
56	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
57	Juddah unit-2 (Acorn)	IPP	8*13.6	100	100	1719360	
	Anlima Energy Ltd.	IPP	6*21.2	116	0	0	Reserve.
Chattogram area Total				2382	1149	20208965	
58	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit- 5	APSCL	1*150	134	120	2634734	
59	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	186	4531000	FGMO
60	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	290	7325200	
61	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	285	7038000	FGMO
62	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	582264	Gas shortage
63	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	55	1331520	Gas shortage
64	Ashuganj 195MW PP (APSCL-Uh	IPP	20*9.73+1*16	195	0	0	Gas shortage
65	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	0	Line fault.
66	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	0	Line fault.
67	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	37512	Reserve.
68	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	85	1942640	Machine problem
69	Chandpur 200MW (Desh energy)	IPP	0	200	200	3281850	
70	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	387324	
71	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	215820	
**	Import (Tripura)	Imported power	0	160	156	2982720	
72	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	802400	
73	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	0	24826	Reserve.
74	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	42325	
75	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
76	Feni Lanka Power	IPP	7*18.415+1*19.78	114	0	39900	Reserve.
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	107	422520	
	Bhairab 54.5 MW	IPP	3*18.2	0	0	0	On Test
Cumilla Area Total				2980	1593	33622555	
78	RPCL 210MW CCPP	IPP	4*35+1*70	202	163	3703880	Gas shortage
79	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	406116	Engine problem
80	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	32	774720	Engine problem
81	Sarishebari 3 MW Solar Plant	IPP	3	0	1	13550	
82	Mymensingh 200 MW PP (Uniled)	IPP	200	200	200	4072800	Load increasing
83	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	105	614400	#REF!
84	Sutakhalhi 50 MW Solar PP	IPP	50	50	0	275730	
85	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	297360	
Mymensingh Area Total				709	544	10156358	
86	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1022000	Machine problem
87	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	42	991200	Machine problem
88	Kushina 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3375981	frequency control
89	Shahjibazar 330 MW CCPP	PDB	3*110	330	140	5068000	synchronized at 17.26.
90	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	0	957600	tripped at 15:41.
91	Fenchuganj 44MW (Energyprima	RPP	12*3.3+5*2	44	0	0	Contract Expired
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	210500	
93	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	35	823968	GT-9 Under maint.
94	Shahjibazar 88MW PP (Shahjibaz	RPP	32*2.90	86	84	1910400	
	Shahjibazar 100 MW GTPP	PDB	1*100	0	0	0	Under Shut down
95	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	163	3398770	
96	Sylhet 20 MW GTPP	PDB	1*20	20	19	423000	
97	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired
98	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	376416	Engine problem
99	Bibiana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	300	7245000	FGMO
100	Bibiana-III 400 MW CCPP	PDB	400 MW	400	409	8917000	
101	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	5	142920	Engine problem
	Bibiana South 400 MW	PDB	400 MW	383	365	8391600	On Test
Sylhet Area Total				2371	1762	43274355	
102	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve.
*	Bheramara (HVDC)	Imported power	2*500	1000	724	17508364	
103	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	60	386480	Engine problem
104	Fardipur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve.
105	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
106	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
107	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	315	7943616	FGMO
108	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	40	40	381750	
109	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	46	261120	Reserve.
110	Rupsha 105 MW PP (Oricon rupsh	IPP	6*18.445	105	80	972960	Engine problem
111	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1275	27464290	
112	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	80	435744	High Voltage.
113	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	28	582400	
114	Bhola 225 MW CCPP	PDB	2*63+1*68	194	0	0	Under maint.
115	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	65	1390363	Machine problem
116	Payra 1320 MW	BCPCL	2*622	1244	510	11774003	High Voltage.
	Bhola Nutan Biddu BD LTD	IPP	220	0	70	1706809	On Test
	Uniled Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Reserve.
Barisal Area Total				1826	753	15889316	
117	Baghabari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage.
118	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	24806	Reserve.
119	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
120	Armura 50 MW PP(Sinha)	QRPP	7*7.79	50	42	127870	Engine problem
121	Katakhalhi 50 MW PP (Northern)	QRPP	6*8.9	50	0	52753	Reserve.
122	Katakhalhi 50 MW Peaking PP	PDB	6*8.7	50	0	34361	Reserve.
123	Sirajgonj Unit-1 225MW	NWPGCL	1*1				