POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : 23-Mar-21

OF-LDC-08 Page -Hrs on 29-May-19
Today's Actual Min Gen. & Probable Gen. & Demand Till now the maximum generation is : -12893 MW 21:00 The Summary of Yesterday's Generation & Demand 10862.0 MW F 12:00 9127 MW Day Peak Generation Min. Gen. at 6:00 Evening Peak Generation 12565.0 MW F 19:30 Available Max Generation 15203 MW E.P. Demand (at gen end) 12565.0 MW F 19:30 Max Demand (Evening) 12800 MW Maximum Generation 12565.0 MW F 19:30 Reserve(Generation end) 2403 MW Load Shed Total Gen. (MKWH) 255.7 System Load Factor : 84.79%

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 0 MW Export from East grid to West grid :- Maximum -132 MW 20:00 MKWHR Energy MW Import from West grid to East grid :- Maximum Energy MKWHR Water Level of Kaptai Lake at 6:00 A M on 23-Mar-21 Ft.(MSL) 89.48 Ft.(MSL) 87.41 Rule curve : Actual: Gas Consumed Total = 1182.50 MMCFD Oil Consumed (PDB) : HSD Liter FO Cost of the Consumed Fuel (PDB+Pvt) Gas Tk154.273.254 : Tk548,765,785 Total : Tk779,037,663 Load Shedding & Other Information

Area	Yesterday			Today	
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	4495	0	0%
Chittagong Area	0	0:00	1533	0	0%
Khulna Area	0	0:00	1374	0	0%
Rajshahi Area	0	0:00	1242	0	0%
Cumilla Area	0	0:00	1122	0	0%
Mymensingh Area	0	0:00	905	0	0%
Sylhet Area	0	0:00	501	0	0%
Barisal Area	0	0:00	233	0	0%
Rangpur Area	0	0:00	698	0	0%
Total	0		12104	0	

Information of the Generating Units under shut down

Planned Shut- Down	Forced Shut-Down
	1) Barapukuria ST: Unit-1,2
	2) Baghabari-100, 71 MW
	3) Ashuganj-5
	4) Kaptai-2
	5) Raozan #2
	6) Sirajganj #1 CCPP
	7) Siddhirganj 335 MW
	8) Ghorashal unit-7
	9) Bibiyana-3 ST

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

- a) Dohazari-Cox'sbazar 132 kV Ckt-2 was under shut down from 10:28 to 17:05 for D/W.
- b) HVDC 20DF30 Shunt Reactor was under shutdown from 09:31 to 10:25 for maintenance c) Bibiyana 3 ST was force shutdown at 09:01 due to fire at DM water plant.
- d) Siddhirgani 335 MW was shutdown at 10:56 due to filter change.
- e) Rajshahi-Natore 132 kV Ckt-1 was under shut down from 09:03 to 11:48 for C/M.
 f) Rangpur 132/33 kV T-1 transformer was under shut down from 10:22 to 11:45 due to flashing.
- g) Hathazari 230/132 kV MT-03 transformer was under shut down from 11:36 to 11:50 for C/M. h) Bhaluka 132/33 kV T-2 transformer was under shut down from 09:19 to 18:05 for D/W
- i) Rangamati-Khagrachari 132 kV Ckt-1 was under shut down from 11:03 to 12:53 for C/M.
- j) Bhangura 132/33 kV T-1 transformer was shut down at 11:15 for D/W.
 k) Khulna(S) 230/132 kV T-03 transformer was under shut down from 09:28 to 11:42 for C/M.
- Rajshahi-Natore 132 kV Ckt-2 was under shut down from 11:51 to 13:34 for C/M.
 M) Hathazari 230/132 kV MT-02 transformer was under shut down from 12:04 to 13:05 for C/M.

- n) Rangamatt-Khagrachari 132 kV Ckt-2 was under shut down from 12:58 to 14:15 for C/M.
 o) Savar 132/33 kV T-1 transformer was under shut down from 13:15 to 13:59 for Kite removing.
 p) Barishal(N)-Bhola 230 kV Ckt-2 tripped at 12:01 from both ends showing Dist. L3-N-phase, Z1 at
- Barishal(N) end & Dist. Relay at Bhola end and was switched on at 12:39.
 q) Hathazari 230/132 kV MT-01 transformer was under shut down from 13:10 to 13:58 for C/M
- r) Bheramara HVDC 400 kV 10C02B Breaker was switched on at 15:31
- t) Bottail 132/33 kV T-1 transformer tripped at 13:55 operating Diff. Relay and was switched on at 14:40.
- u) Baroierhat 132/33 kV T-2 transformer tripped at 14:48 operating PRD.
 v) Hathazari-Raozan 230 kV Ckt-2 was under shut down from 16:15 to 16:25 for C/M.

- w) Rangamati 132 kV Bus coupler was under shut down from 16:03 to 16:59 for C/M.
 x) After maintenance Meghnaghat 450 MW CCPP GT-1 & GT-2 was synchronized at 17:27 & 230:10 respectively.
 y) Tongi-Kabirpur 132 kV Ckt-1 tripped at 02:10(23/03/2021) from both ends showing Dist. B-phase, Z1,
- E/F, O/C and was switched on at 02:31(23/03/2021).

 z) Tongi-Kabirpur 132 kV Ckt-2 tripped at 02:10(23/03/2021) from Tongi end showing O/C and was
- switched on at 02:25(23/03/2021)
- aa) Kodda-Gazipur 100 MW 132 kV Ckt tripped at 02:10(23/03/2021) from Kodda end showing no relay
- and was switched on at 02:37(23/03/2021).
- ab) Mirpur-Aminbazar 132 kV Ckt-1 was shut down at 07:18(23/03/2021) for C/M.
 ac) Rampura 230/132 kV T-03 transformer was shut down at 07:11(23/03/2021) for NLDC transformer work.
- ad) Khulna(C) 132/33 kV T-3 transformer was shut down at 07:10(23/03/2021) for C/M.
 ae) Ghorashal unit-7 ST & GT was shutdown at 06:53(23/03/2021) & 07:00(23/03/2021) respectively for maintenance.
- af) Shahjibazar GT-8 was shutdown at 06:10(23/03/2021) for maintenance
- ag) Rangamati-Chandraghona 132 kV Ckt-1 was shut down at 07:48(23/03/2021) for C/M.

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division For these tripping ACE Kodda 149 MW & Gazipur 100 MW P.P. Full interruption occurred at Manikgani(48 MW) & Raiendrapur(70 MW)

About 10 MW power interruption occurred under Rangpur S/S area

About 15 MW power interruption occurred under Bhaluka S/S area

from 10:22 to 11:45.

rom 09:19 to 18:05.

S/S area and partial interruption occurred under Kabirpur(94 MW) & Kodda(130 MW) S/S area till 02:37(23/03/2021).

Superintendent Engineer Load Despatch Circle