

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2021				Day : Friday				Date : 26.03.21				
Probable Maximum Demand : 12200 MW				Probable Maximum Generation : 15385 MW				Rule Curve = 89.00 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 87.02 ft.				Today = 86.78 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.03.21 (Yesterday)		26.03.21 (Today)		25.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under Repowering
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170			
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	190	190	190	190		175	Under maint.
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	92	91	99	99			
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0			Contract Expired on 08/01/2021
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360		Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	273	283	412	412	129		Gas Shortage
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	80	185	100	180			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		s/d for filter changing due to Dirt in gas
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	240	235	270	270	70		dirt in gas
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	100	100	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	93	98	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	71	59	85	85			
19	Gaganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	100	100			
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22			
21	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x8.9+7x8.13	80	80	51	54	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	33	33	33	33			
23	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	30	30	33	33			
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	50	52	52			
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	90	105	105			
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	148	147	149	149			
27	Kalpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	49	49	50	50			
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	255	265	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	122	60	149	149			
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6x1.4	300	300	54	257	100	300			
32	Bramangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+9x1x.959	100	100	0	100	50	100			
33	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+9x1x.959	100	100	33	100	100	100			
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	144	144	144			
	Spectra Solar Plant Ltd.	Solar (IPP)				34	0	30	0			
Dhaka Zone Total				6171	5972	3317	3787	3874	4174	914	745	
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160		Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
42	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.89	50	50	45	43	50	50			
45	Sikalbaha 105 MW PP (Baraka Sika)	HFO (IPP)	6x18.415	105	105	0	0	50	100			
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	140	120	120			
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	225	204	225	225			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	179	197	300	300			
49	Judah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	78	100	100	100			
50	Judah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	86	100	100	100			
51	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	81	102	102			
52	Hafhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	16	20	20			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			3	15	20	35			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	72	90	90			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54			
56	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Judah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
58	Chattogram 116 MW PP (Anlima En	HFO (IPP)	6x21.06	116	116	0	0	116	116			
Chattogram Zone Total				2442	2382	967	1163	1677	1717	160	360	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	110	100	100	135	35		Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	55	80	80	120	54		Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26	19		Gas Shortage
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	193	200	225	225			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	260	215	350	350			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	260	350	350			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	30	46	30	45			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+11'16	195	195	8	8	8	8	187		Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51		Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150		Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	8	42	0	50			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	70	101	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	52	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	20	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	59x1.4+40x1.570+15x1.085	200	200	52	200	100	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	100	114	114	114			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	113	113	113	113			
**	Import (Tripura)	India		160	160	132	154	151	168			
	Bhairab 54.5 MW	HFO (IPP)				5	37	0	0			
Cumilla Zone Total				3040	2980	1552	1817	1985	2242	625	163	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	98	104	160	160	98		Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	17	22	22			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	73	77	77			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115			
83	Myemensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	191	191	200	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakahi 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
86	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	21	23	22	22			
Myemensingh Zone Total				717	709	500	523	648	596	98	0	

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.03.21 (Yesterday)		26.03.21 (Today)		25.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance					
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :							
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down	Description/ Remarks	Probable start-up date				
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	44	44		27	GT-1 Load gear problem						
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Shaft Problem						
89	Fenchugonj 51 MW PP (Barakatlula)	Gas (RPP)	19x2.90	51	51	53	53	51	51									
90	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021						
91	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	130	130	130									
92	Hobiganj 11MW PP Cofidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11									
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0		66	Under maint.						
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	165	121	210	210									
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	79	80	81	81									
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	105	105	105	150		126	Water Problem						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	20	20									
98	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020						
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	6	7	10	10									
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16									
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	290	341	341									
102	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	240	241	250	250	159		Gas Shortage						
103	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	310	310	400	400	73		Gas Shortage						
**	Shahjibazar 100 MW GTPP	Gas (PDB)				0	0	0	0			On Test						
Sylhet Zone Total				2416	2371	1492	1437	1699	1744	159	279							
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16									
105	Bheramara 410 MW CCPP	Gas (NWPFGCL)	1 x 278+1 x 132	410	410	270	260	400	400	150		Gas Shortage						
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	5	13	25	25									
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	6	60	60									
108	Kulna 225 MW CCPP	HSD (NWPFGCL)	1 x 150+1x75	230	230	0	0	0	220									
109	Kulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	99	99	99									
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100									
111	Noapara 40 MW PP (Kharajahan Ali)	HFO (QRPP)	5x8.5	40	40	33	33	40	40									
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	94	93	90	95									
113	Madhumati 100 MW PP	HFO (NWPFGCL)	6x18.415	105	105	0	0	100	100									
**	Bheramara (HVDC)	India		1000	1000	714	720	735	735									
Kulna Zone Total				2288	2284	1199	1324	1599	1890	150	0							
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	65	110	110									
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	18	27	25	25									
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	66	64	70	70		130	GT-2 & STG Under maint.						
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	33	34	95	95									
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	450	610	622	622									
119	Potulakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	18	150	150									
**	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				70	82	0	0									
Barishal Zone Total				1826	1826	637	900	1072	1072	0	130							
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage						
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage						
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	40	50	50	50									
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	200	200	200									
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	35	34	40	40									
124	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42									
125	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	99	100	100									
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	32	50	50									
127	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	50	50									
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	34									
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPFGCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage						
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPFGCL)	1x150+1x75	220	220	164	165	200	200									
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPFGCL)	1x141+1x79	220	220	195	180	200	200									
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	367	387	400	400									
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22									
134	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020						
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11									
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52									
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	95	113	113									
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	113	113									
Rajshahi Zone Total				2193	2183	1100	1499	1643	1677	381	0							
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage						
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage						
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage						
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	10	10									
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	104	110	113	113									
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	7	0	0									
144	Majpara, Tatala 8 MW Solar PP (Sympa Po)	Solar (IPP)	1 x 8	8	8	5	0	8	0									
Rangpur Zone Total				685	605	259	267	281	273	294	0							
Sub-total: Plants in operation				21778	21312	11023.0	12717	14478	15385	2781	1677							
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss							10510	12125	13804	14669								
(B) Contract expired power plants																		
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0									
Gross Total				21778	21312	11023	12717	14478	15385	2781	1677							
(C) Actual data of 25.03.21 (Yesterday) Thursday :																		
01.	Max. Demand (Generation end)	:	12717.00	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand (Sub-station end)	:	12125.00	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed					
03.	Highest Generation (Generation end)	:	12717.00	MW, at =	19:30 hrs	MW	MW	MW	MW	MW	MW	MW	MW					
04.	Minimum Generation (Generation end)	:	9560.00	MW, at =	7:00 hrs	Dhaka	4324	4324	0	Mymensingh	1016	1016	0					
05.	Day-peak Generation (Generation end)	:	11023.00	MW, at =	12:00 hrs	Chattogram	1247	1247	0	Sylhet	469	469	0					
06.	Evening-peak Generation (Generation end)	:	12717.00	MW, at =	21:00 hrs	Kulna	1483	1483	0	Barishal	333	333	0					
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Rajshahi	1319	1319	0	Rangpur	744	744	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8760.00	MW, at =	5:00 hrs	Cumilla	1190	1190	0									
09.	Generation shortfall at evening peak due to :					Total		12125		12125		0						
a)	Gas limitation	:	2327	MW		Fuel cost :		(a) Gas = 142473679 Taka	(c) Coal = 76953481 Taka									
d)	Coal supply Limitation	:	294	MW		(b) Oil = 690267475 Taka		Total = 909694635 Taka										
b)	Low water level in Kaptai lake	:	160	MW		14. Maximum Temperature in Dhaka was : 37.4° C												
c)	Plants under shut down/ maintenance	:	1677	MW		15. Export through East-West interconnections :												
10.	Total Energy (Generation + India Import)	:	263.89	MKWh		At evening peak-hour		:	-32	MW, at	21:00 hrs							
	By Gas = 134.775 MKWh			By Oil =	89.275 MKWh	Maximum		:	-140	MW, at	8:00 hrs							
	By Coal = 16.669 MKWh			By Hydro =	1.696 MKWh	Energy		:	0.4725	MKWh								
	By Solar= 0.806 MKWh																	
11.	Total Gas Supplied	:	1101.57	MMCFD														
(D) Forecast of 26.03.21 (Today) Friday :																		
01.	Maximum Demand	:	12200	MW	(Generation end)	04.	Maximum Load-shed		:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	15385	MW	(Generation end)	05.	Total Generation		:	253.16	MKWh							
03.	Maximum Shortage	:	-3185	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :			38.4° C								