		POWER GRID COMPANY OF NATIONAL LOAD DESP			QF-LDC-08
		DAILY REPO			Page -1
					e: 27-Mar-21
ill now the maximum gener	ration is : - 12893 MV s 26-Mar-21 Generation	v on & Demand	21:00 Hrs	on 29-May-19 s Actual Min Gen. & Pro	habla Cara & Damand
the Summary of Yesterday's Day Peak Generation :	9413.0 MW	Hour:	12:00 Min. Ge	n. at 6:00	8585 MW
vening Peak Generation :	11129.0 MW	Hour:		e Max Generation	: 15935 MW
.P. Demand (at gen end) :	11129.0 MW	Hour :		mand (Evening) :	12400 MW
Maximum Generation :	11129.0 MW	Hour :		(Generation end)	3535 MW
otal Gen. (MKWH) :	234.9	System Loa		ned :	0 MW
, ,	EXI	PORT/IMPORT THROUGH EAST-WEST INTERCON	IECTOR		
xport from East grid to West gr	id :- Maximum		-200 MW at 19:30	Ener	gy MKWHR.
nport from West grid to East gr		-	MW at -	Ener	gy - MKWHR.
el of Kaptai Lake at 6:00 A M o	n 27-Mar-21				
Actual : 86.54	Ft.(MSL),		Rule curve: 89.00 Ft.(M	SL)	
	= 1186.25 MMCFD.		010 (000)		
Gas Consumed : Total :	= 1186.25 MMCFD.		Oil Consumed (PDB):	HSD :	Liter
				FO :	Liter
				10 .	Litei
cost of the Consumed Fuel (PDI	B Gas :	Tk155,135,594			
	Coal :	Tk70,195,228	Oil : Tk342,7	73.212 Total	: Tk568,104,033
		., ,	,		, . ,
	Load Shedding & Other Inf	ormation			
Area Yeste	erday		Today		
		Estimated Demand (S/S end)	Estimate	ed Shedding (S/S end)	Rates of Shedding
MW	0.00	MW		MW	(On Estimated Demand)
haka 0	0:00	4339		0	0%
Chittagong Area 0 Chulna Area 0	0:00	1478		0	0% 0%
thulna Area 0 Rajshahi Area 0	0:00 0:00	1325 1198		0	0%
Cumilla Area 0	0:00	1082		0	0%
Tymensingh Area 0	0:00	873		0	0%
lythet Area 0	0:00	485		0	0%
arisal Area 0	0:00	225		0	0%
Rangpur Area 0	0:00	673		0	0%
otal 0		11678		0	
Informa	tion of the Generating Units un	der shut down.			
Planned Shu	ıt- Down		Forced Shut-Down		
			1) Barapukuria ST: Unit- 2) Baghabari-100, 71 M	1,2	
			3) Ashugani-4	14	
			4) Kaptai-2		
			5) Raozan #2		
			6) Sirajganj #1 CCPP		
			6) Sirajganj #1 CCPP		
			6) Sirajganj #1 CCPP		
			6) Sirajganj #1 CCPP		
Additional In	oformation of Machines, lines	, Interruption / Forced Load shed etc.	6) Sirajganj #1 CCPP		
Additional In	oformation of Machines, lines	, Interruption / Forced Load shed etc.	6) Sirajganj #1 CCPP		
		-	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped	I at 09:31 due to flame failure a	-	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was	I at 09:31 due to flame failure a synchronized at 12:21.	-	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was) Siddhirganj 210 MW GT-2 wa	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01.	-	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was) Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-1 wa	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38.	-	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was) Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-1 wa) Chandpur 150 MW GT was sy Rampura-Bashundhara 132 k\	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38. /nchronized at 11:53. / Ckt-1 was switched on at 08	nd was synchronized at 11:42.	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was) Siddhirgani 210 MW GT-4 wa) Siddhirgani 210 MW GT-1 va) Chandpur 150 MW GT was sy Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV Ckt-2	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38. ynchronized at 11:53. / Ckt-1 was switched on at 08. 2 was under shut down from 05.	nd was synchronized at 11:42.	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-1 wa) Siddhirganj 210 MW GT-1 wa) Chandpur 150 MW GT was Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV CkT-2 Sylhet 225 MW CCPP ST was	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. is synchronized at 10:38. ynchronized at 11:53. / Ckt-1 was switched on at 08 2 was under shut down from 05 s synchronized at 13:17.	nd was synchronized at 11:42. 26. 56 to 12:16 for C/M.	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-1 wa) Chandpur 150 MW GT was y Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV Ckt-2) Sylhet 225 MW CCPP ST wa Aminbazar 230/132 kV T-3 tra	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:38. ynchronized at 10:38. ynchronized at 11:53. / Ckt.1 was switched on at 08.2 was under shut down from 05 s synchronized at 13:17. seformer was under shut down from form of 50 s ynchronized at 13:17.	nd was synchronized at 11:42. 26. :56 to 12:16 for C/M. from 17:24 to 17:48 due maintenance work.	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was) AES Haripur 360 MW GT-2 wa) Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-1 was) Chandpur 150 MW GT was sy Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV Ckt-2) Sylhet 225 MW CCPP ST wa Aminbazar 230/132 kV T-3 tra Copalganj(N)-Faridpur 132 kV	at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38. ynchronized at 11:53. / Ckt-1 was switched on at 08 2 was under shut down from 05 s synchronized at 13:17. nsformer was under shut down Ckt-1 tripped at 22:59 from bo	nd was synchronized at 11:42. 26. 56 to 12:16 for C/M.	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was) Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-1 wa) Chandpur 150 MW GT-1 wa) Chandpur 150 MW GT was sy , Tangail-Kaliakoir 132 kV Ckt-2) Sylhet 225 MW CCPP ST , Sylhet 225 MW CCPP ST Aminbazar 230/132 kV T-3 tra Gopalganj (N)-Faridpur 132 kV and was switched on at 23:22	at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38. ynchronized at 11:53. C Kt-1 was switched on at 08 was under shut down from 05 s synchronized at 13:17. nsformer was under shut down Ckt-1 tripped at 22:59 from bo 	nd was synchronized at 11:42. 26. :56 to 12:16 for C/M. from 17:24 to 17:48 due maintenance work. th end showing Dist. Z1, auto reclose	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was) Siddhirganj 210 MW GT-1 wa) Siddhirganj 210 MW GT-1 wa) Chandpur 150 MW GT-4 wa) Chandpur 150 MW GT was ya Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV Ckt-2) Sylhet 225 MW CCPP ST wa Aminbazar 230/132 kV T-3 tral Gopalganj(N)-Faridpur 132 kV and was switched on at 23:22 Shahjibazar 330 MW Gt-2 wa	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38. ynchronized at 11:53. / Ckt-1 was switched on at 08. 2 was under shut down from 05 s synchronized at 13:17. nsformer was under shut down Ckt-1 tripped at 22:59 from bo. shut down at 00:30(27-03-20	nd was synchronized at 11:42. 26. :56 to 12:16 for C/M. from 17:24 to 17:48 due maintenance work. th end showing Dist. Z1, auto reclose 21) due to filter clearing (DP high).	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-1 wa) Siddhirganj 210 MW GT-1 wa) Chandpur 150 MW GT-9 wa Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV T-3 ta Aminbazar 230/132 kV T-3 ta Copalganj (N)-Faridpur 132 kV and was switched on at 23:22) Shahjibazar 330 MW Gt-2 wa Ashuganj 225 MW STG was si	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38. ynchronized at 11:53. / Ckt-1 was switched on at 08 2 was under shut down from 05 s synchronized at 13:17. nsformer was under shut down Ckt-1 tripped at 22:59 from both S shut down at 00:30(27-03-20 hut down at 00:30(27-03-2021)	nd was synchronized at 11:42. 26. 56 to 12:16 for C/M. from 17:24 to 17:48 due maintenance work. th end showing Dist. Z1, auto reclose 21) due to filter clearing (DP high). due to work on BFP.	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-4 wa) Siddhirganj 210 MW GT-4 wa) Chandpur 150 MW GT was sy Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV Ckt-2) Sylhet 225 MW CCPP ST wa Aminbazar 230/132 kV T-3 tra Gopalganj (N)-Faridpur 132 kV and was switched on at 23:22) Shahjibazar 330 MW Gt-2 wa Ashuganj 225 MW GT-2 wa Ashuganj 225 MW STG was si) Ghorasal 132 kV Bus-2 was u	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38. ynchronized at 11:53. / Ckt-1 was switched on at 08 2 was under shut down from 05 s synchronized at 13:17. nsformer was under shut down Ckt-1 tripped at 22:59 from both S shut down at 00:30(27-03-20 hut down at 00:30(27-03-2021)	nd was synchronized at 11:42. 26. :56 to 12:16 for C/M. from 17:24 to 17:48 due maintenance work. th end showing Dist. Z1, auto reclose 21) due to filter clearing (DP high).	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-1 wa) Siddhirganj 210 MW GT-1 wa) Chandpur 150 MW GT-9 wa Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV T-3 ta Aminbazar 230/132 kV T-3 ta Copalganj (N)-Faridpur 132 kV and was switched on at 23:22) Shahjibazar 330 MW Gt-2 wa Ashuganj 225 MW STG was si	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38. ynchronized at 11:53. / Ckt-1 was switched on at 08 2 was under shut down from 05 s synchronized at 13:17. nsformer was under shut down Ckt-1 tripped at 22:59 from both S shut down at 00:30(27-03-20 hut down at 00:30(27-03-2021)	nd was synchronized at 11:42. 26. 56 to 12:16 for C/M. from 17:24 to 17:48 due maintenance work. th end showing Dist. Z1, auto reclose 21) due to filter clearing (DP high). due to work on BFP.	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-4 wa) Siddhirganj 210 MW GT-4 wa) Chandpur 150 MW GT was sy Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV Ckt-2) Sylhet 225 MW CCPP ST wa Aminbazar 230/132 kV T-3 tra Gopalganj (N)-Faridpur 132 kV and was switched on at 23:22) Shahjibazar 330 MW Gt-2 wa Ashuganj 225 MW GT-2 wa Ashuganj 225 MW STG was si) Ghorasal 132 kV Bus-2 was u	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38. ynchronized at 11:53. / Ckt-1 was switched on at 08 2 was under shut down from 05 s synchronized at 13:17. nsformer was under shut down Ckt-1 tripped at 22:59 from both S shut down at 00:30(27-03-20 hut down at 00:30(27-03-2021)	nd was synchronized at 11:42. 26. 56 to 12:16 for C/M. from 17:24 to 17:48 due maintenance work. th end showing Dist. Z1, auto reclose 21) due to filter clearing (DP high). due to work on BFP.	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-4 wa) Siddhirganj 210 MW GT-4 wa) Chandpur 150 MW GT was sy Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV Ckt-2) Sylhet 225 MW CCPP ST wa Aminbazar 230/132 kV T-3 tra Gopalganj (N)-Faridpur 132 kV and was switched on at 23:22) Shahjibazar 330 MW Gt-2 wa Ashuganj 225 MW GT-2 wa Ashuganj 225 MW STG was si) Ghorasal 132 kV Bus-2 was u	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38. ynchronized at 11:53. / Ckt-1 was switched on at 08 2 was under shut down from 05 s synchronized at 13:17. nsformer was under shut down Ckt-1 tripped at 22:59 from both S shut down at 00:30(27-03-20 hut down at 00:30(27-03-2021)	nd was synchronized at 11:42. 26. 56 to 12:16 for C/M. from 17:24 to 17:48 due maintenance work. th end showing Dist. Z1, auto reclose 21) due to filter clearing (DP high). due to work on BFP.	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-4 wa) Siddhirganj 210 MW GT-4 wa) Chandpur 150 MW GT was sy Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV Ckt-2) Sylhet 225 MW CCPP ST wa Aminbazar 230/132 kV T-3 tra Gopalganj (N)-Faridpur 132 kV and was switched on at 23:22) Shahjibazar 330 MW Gt-2 wa Ashuganj 225 MW GT-2 wa Ashuganj 225 MW STG was si) Ghorasal 132 kV Bus-2 was u	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38. ynchronized at 11:53. / Ckt-1 was switched on at 08 2 was under shut down from 05 s synchronized at 13:17. nsformer was under shut down Ckt-1 tripped at 22:59 from both S shut down at 00:30(27-03-20 hut down at 00:30(27-03-2021)	nd was synchronized at 11:42. 26. 56 to 12:16 for C/M. from 17:24 to 17:48 due maintenance work. th end showing Dist. Z1, auto reclose 21) due to filter clearing (DP high). due to work on BFP.	6) Sirajganj #1 CCPP		
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-4 wa) Siddhirganj 210 MW GT-4 wa) Chandpur 150 MW GT was sy Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV Ckt-2) Sylhet 225 MW CCPP ST Sylhet 225 MW CCPP ST and was switched on at 23:22) Shahjibazar 330 MW Gt-2 wa Ashuganj 225 MW STG was si 1) Ghorasal 132 kV Bus-2 was u maintenance at bus isolator.	at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. is synchronized at 10:38. inchronized at 13:38. inchronized at 13:17. Was switched on at 08 was under shut down from 05 s synchronized at 13:17. insformer was under shut down Ckt-1 tripped at 22:59 from bo is shut down at 00:30(27-03-20 but down at 03:40(27-03-2021) under shut down from 06:39(27 inchronized at 22:59 inchronized inchroniz	nd was synchronized at 11:42. 26. :56 to 12:16 for C/M. from 17:24 to 17:48 due maintenance work. th end showing Dist. Z1, auto reclose 21) due to filter clearing (DP high). due to work on BFP03-2021) to 09:54(27-03-2021) red hot	6) Sirajganj #1 CCPP	Synorini	endent Engineer
) Sylhet 225 MW CCPP tripped) AES Haripur 360 MW Gt was Siddhirganj 210 MW GT-2 wa) Siddhirganj 210 MW GT-4 wa) Siddhirganj 210 MW GT-4 wa) Chandpur 150 MW GT was sy Rampura-Bashundhara 132 kV) Tangail-Kaliakoir 132 kV Ckt-2) Sylhet 225 MW CCPP ST wa Aminbazar 230/132 kV T-3 tra Gopalganj (N)-Faridpur 132 kV and was switched on at 23:22) Shahjibazar 330 MW Gt-2 wa Ashuganj 225 MW GT-2 wa Ashuganj 225 MW STG was si) Ghorasal 132 kV Bus-2 was u	I at 09:31 due to flame failure a synchronized at 12:21. s synchronized at 10:01. s synchronized at 10:38. ynchronized at 11:53. / Ckt-1 was switched on at 08 2 was under shut down from 05 synchronized at 11:51. nsformer was under shut down ckt-1 tripped at 22:59 from books shut down at 03:40(27-03-20 hut down at 03:40(27-03-201) under shut down from 06:39(27 purples).	nd was synchronized at 11:42. 26. 56 to 12:16 for C/M. from 17:24 to 17:48 due maintenance work. th end showing Dist. Z1, auto reclose 21) due to filter clearing (DP high). due to work on BFP.	6) Sirajganj #1 CCPP		endent Engineer espatch Circle