

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2021				Day : Thursday				Date : 15.04.21							
Probable Maximum Demand :				13200	MW	Probable Maximum Generation : 15434				MW	Rule Curve = 85.20 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday =	80.64	ft	Today = 80.22 ft.								
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.04.21 (Yesterday)		15.04.21 (Today)		14.04.21 (Yesterday)		15.04.21 (Today)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	MW	MW	MW		
(A) Plants in operation:															
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0				170	Under Repowering	
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				180	Under Repowering	
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0				190	Under maint.	
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	250	0	0						
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	97	104	103	103						
4	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0				105	CB Problem	
5	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				20	Gas Shortage	
6	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	321	344	350	350				16	Gas Shortage	
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	260	260	260	260				190	Gas Shortage	
8	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0				115	Under Overhauling	
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0				412	Dirt in gas	
10	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	120	180	180	180				30	Gas Shortage	
11	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	216	218	220	220				117	ST under maint.	
12	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	7	100	100	100						
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	250	255	280	280				50	dirt in gas	
14	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	0	100	100	100						
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55						
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	73	100	100						
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	102	100	100						
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22						
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6.02.97+7x8.73	80	80	51	53	58	58						
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	30	33	33						
21	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	25	25						
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	51	52	52						
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	105	105	105						
24	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	0	150	149	149						
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0						
26	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54						
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	300	300	300						
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149						
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300						
30	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	25	50	100						
31	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	27	100	100						
32	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	55	55	55	55						
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55						
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0						
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	104	104	104						
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	162	162						
37	Manikganj 35MW Solar PP (Inspect)	Solar (IPP)	1x35	35	35	31	0	30	0						
Dhaka Zone Total				6026	5829	2221	3416	3451	3671	718	877				
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160				Low Water Level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0				180	Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0				180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0						
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	25	25						
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0						
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50						
44	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	0	0	50	100						
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	130	130						
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	229	215	230	230						
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	70	161	300	300						
48	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	50	88	100	100						
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	100	100	100						
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	83	82	85						
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0						
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	22	22						
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			33	42	25	35						
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	84	100	100						
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54						
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110						
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100						
57	Chattogram 116 MW PP (Anima En	HFO (IPP)	6x21.06	116	116	57	25	60	60						
Chattogram Zone Total				2442	2382	925	1240	1633	1671	160	360				
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	100	135	135	35				Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129				Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134				Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26						
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	167	210	225	225						
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	280	300	300	300						
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	275	300	360	360						
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	45	20	50	50						
64	Ashuganj 199MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187				Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51				Gas Shortage	
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0						
67	Titaf 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50						
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	51	53	50	50				110	ST Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	163	171	195	195						
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22						
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33						
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	52	52						
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	20	20	20						
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	195'4+8x1.515+15x1.058	200	200	0	20	100	200						
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	114	114	114						
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	50	113	113	113						
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	37	36	36						
**	Imporpt (Tripura)	India		160	160	136	164	157	188						
Cumilla Zone Total				3094	3034	1366	1824	2007	2188	536	110				
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	149	183	200	200	19				Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	17	17						
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	49	57	56	56						
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	75	115	115	115						
83	Myemensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200											

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.04.21 (Yesterday)		15.04.21 (Today)		14.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	41	43	43		29	GT-1 Load gear problem		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	43	43	43		47	Under maint.		
89	Fenchugonj 51 MW PP (Barakakulua)	Gas (RPP)	19x2.90	51	51	48	53	51	51					
90	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	32	33	33		34	Under maint.		
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	329	332	330	330					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	74	77	75	78					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x69	231	231	164	164	200	220					
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	9	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	310	341	341					
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	379	388	400	400					
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	350	400	400					
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total				2422	2377	1930	2007	2134	2157	0	110			
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16					
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	195	200	400	400	210		Gas Shortage		
105	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	18	20	20					
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60					
107	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220					
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	66	99	99	99					
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x3.4+7x3.515	100	100	0	100	50	100					
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	33	32	33					
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	14	92	92	92					
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	843	842	857	857					
Khulna Zone Total				2288	2284	1122	1384	1710	1997	210	0			
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110					
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	34	33	33					
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	64	67	70	70		127	GT-2 & STG Under maint.		
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	90	92	95	95					
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	440	580	622	622					
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150					
Barishal Zone Total				1826	1826	661	920	1117	1117	0	127			
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	39	35	35					
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0					
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	66	100	100					
125	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	31					
126	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	33					
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	80	80	120	120	130		Gas Shortage		
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	164	149	180	200					
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	176	178	200	200					
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	341	415	400	400					
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22					
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	16	52	52	52					
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113					
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113					
Rajshahi Zone Total				2173	2173	1031	1349	1626	1680	301	0			
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	71	74	70	70	11		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	149	150	150	150	124		Coal Shortage		
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	10	10					
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	100	113	113	113					
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
142	Majpara, Talula 8 MW Solar PP (Sympa Po)	Solar (IPP)	1 x 8	8	8	6	0	8	0					
Rangpur Zone Total				685	605	326	337	351	343	220	0			
Sub-total: Plants in operation				21673	21219	10094.0	13058	14691	15434	2164	1584			
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss						9632	12460	14018	14727					
(B) Plants under long term maintenance/ contract expired														
143	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021		
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
145	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021		
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020		
147	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
Sub-Total: Plants under long term maintenance/ contract expired				294	0	0	0	0	0					
Gross Total				21967	21219	10094	13058	14691	15434	2164	1584			
(C) Actual data of 14.04.21 (Yesterday) Wednesday :														
01.	Max. Demand at eve. peak (Generation end)	:	13058.00	MW,	at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12460.00	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13058.00	MW,	at =	21:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	9531.00	MW,	at =	7:00 hrs	Dhaka	4013	4013	0	Mymensingh	1099	1099	0
05.	Day-peak Generation (Generation end)	:	10094.00	MW,	at =	12:00 hrs	Chattogram	1313	1313	0	Sylhet	517	517	0
06.	Evening-peak Generation (Generation end)	:	13058.00	MW,	at =	21:00 hrs	Khulna	1591	1591	0	Barishal	380	380	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Rajshahi	1461	1461	0	Rangpur	796	796	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9520.00	MW,	at =	5:00 hrs	Cumilla	1290	1290	0				
09.	Generation shortfall at evening peak due to :	:									Total	12460	12460	0
	a) Gas limitation	:	1784	MW			13.	Fuel cost :	(a) Gas = 160199277 Taka	(c) Coal = 90285588 Taka				
	d) Coal supply Limitation	:	220	MW				(b) Oil = 588991390 Taka	Total = 839476255 Taka					
	b) Low water level in Kapta lake	:	160	MW										
	c) Plants under shut down/ maintenance	:	1584	MW			14.	Maximum Temperature in Dhaka was :	37.0° C					
10.	Total Energy (Generation + India Import)	:	273.79	MKWh			15.	Export through East-West interconnections :						
	By Gas = 149.037 MKWh							At evening peak-hour	: -452	MW,	at	21:00 hrs		
	By Coal = 19.033 MKWh							Maximum	: -452	MW,	at	21:00 hrs		
	By Solar= 0.780 MKWh							Energy	: 2.618	MKWh				
11.	Total Gas Supplied	:	1204.18	MMCFD										
(D) Forecast of 15.04.21 (Today) Thursday :														
01.	Maximum Demand	:	13200	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15434	MW	(Generation end)		05.	Total Generation	:	276.77	MKWh			
03.	Maximum Shortage	:	-2234	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	39.3° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13377 MW on 12-04-2021 at 21:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation