

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS							
Date : 16-Apr-21				Page -2			
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Enerov Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	170	2409750	
	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	104	2353318	
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	230	1434120	Sync at 17:16.
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	346	7606000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	290	6834500	Gas shortage
9	Meghnaghat 100 MW(VEL)	QRPP	12*8.9	100	100	1161600	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	270	6309527	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	1292847	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	0	348036	Reserve.
14	Narsingdij 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	489204	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	155	1648000	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	91	1446720	
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	220	2187928	ST under maint.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	102	1213200	
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	1074240	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	1401600	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1329097	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	54	1079520	
25	Bosala 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
26	Sumit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	52	1133340	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	780400	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	709900	Engine problem
29	Gazipur 52 MW PP	IPP	6*8.9	52	25	469440	Low demand
30	Tongi 80 MW GTTP	PDB	1* 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	3332071	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	25894	Reserve.
33	Bramhanganj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve.
34	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	37566	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	133	3443900	Low demand
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	1534800	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	2472960	
38	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	162	2522880	
	Spectra Solar Plant Ltd.	IPP	35	35	0	198890	
Dhaka area Total				5829	3415	58247238	
39	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
40	Razzar 25 MW PP	IPP	3*8.9	25	17	398372	Engine problem
41	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energ	20	20	0	71955	
42	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	948480	
43	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	35	840000	Unit-2 under maint
44	Sikalbaha 225MW	PDB	1*150+1*175	225	203	4850662	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	130	2709190	
46	Sikalbaha 105 MW PP (Baraka Sikalbah)	IPP	105 MW	105	0	0	Reserve.
47	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	
48	Dohazari-Kataish 100 MW Peaking	PDB	6*17	102	83	821649	Engine problem
49	Juldah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	80	1131960	Engine problem
50	Juldah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	1732800	
51	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	521136	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	42	803040	
52	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	77	609600	Engine problem
53	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	22080	
54	Anwara 300 MW PP (United)	IPP	300 MW	300	34	1387527	Transformer O/L
55	Jodiak Power	IPP	3*18.55+1*3.6	54	54	1232875	
56	Karnaghuli Power Ltd.	IPP	0	110	0	0	Reserve.
57	Juldah Unit-2 (Acom)	IPP	8*13.6	100	100	1841280	
	Anlima Energy Ltd.	IPP	6*21.2	116	95	1864255	Engine problem
Chattogram area Total				2382	1122	21768861	
58	Ashuganj TPP Unit- 3	APSCL	1*150	135	80	2629676	
	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Gas shortage
59	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	206	4513000	Gas shortage
60	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	260	7091800	FGMO
61	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	265	6899000	FGMO
62	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	576504	Engine problem
63	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	53	397920	Gas shortage
64	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	234181	Gas shortage
65	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	0	Line fault
66	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	0	Line fault
67	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	200208	Reserve.
68	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	91	2063240	
69	Chandpur 200MW (Desh energy)	IPP	0	200	195	4248000	
70	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	507096	
71	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	251640	
**	Import (Tripura)	Imported power	0	160	166	3475200	
72	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	798200	
73	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	513557	Engine problem
74	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	491390	
75	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	4800	Reserve.
76	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	260700	
77	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	113	2172240	
	Bhairab 54.5 MW	IPP	3*18.2	54	37	534240	Engine problem
Cumilla Area Total				3034	1638	37832592	
78	RPCL 210MW CCPP	IPP	4*35+1*70	202	207	4474120	Gas shortage
79	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	414216	Engine problem
80	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	74	1215360	Engine problem
81	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11890	
82	Mymensingh 200 MW PP (United)	IPP	200	200	198	3986400	
83	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1767600	
84	Sutikhal 50 MW Solar PP	IPP	50	0	0	346070	
85	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	461520	
Mymensingh Area Total				709	637	12677136	
86	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1003000	Machine problem
87	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	43	1025880	Machine problem
88	Kushlari 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3343990	
89	Shajibazar 330 MW CCPP	PDB	3*110	330	333	7584000	
90	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	53	1127400	
91	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
92	Hobiganj 11MW PP Confidene-E	SIPP, REB	4*2.90	11	11	156528	
93	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	32	779136	GT-8 Under maint.
94	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	78	1787520	
	Shajibazar 100 MW GTTP	PDB	1*100	100	0	0	Under Shut down
95	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	203	3760400	Gas shortage
96	Sylhet 20 MW GTTP	PDB	1*20	20	18	410000	
97	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
98	Shahjanulla 25 MW PP	SIPP, REB	9*9.34	25	16	353928	Engine problem
99	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	300	7289500	FGMO
100	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	368	8366000	FGMO
101	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	193320	
	Bibiyana South 400 MW	PDB	400 MW	383	335	7996000	
Sylhet Area Total				2377	2005	45126602	
102	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	723	19230545	
103	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	99	2151360	Engine problem
104	Fanipur 50 MW Peaking PP	PDB	8*6.89	54	19	111840	Engine problem
105	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
106	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
107	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	340	6730848	Gas shortage.
108	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	33	882850	Engine problem
109	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	100	644160	
110	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	92	1678080	Engine problem
111	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1406	31035083	
112	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	835680	
113	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	34	869670	
114	Bhola 225 MW CCPP	PDB	2*63+1*68	194	68	1530000	Machine problem
115	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	97	2014608	
116	Payra 1320 MW	BCPCL	2*622	1244	560	13762600	
	Bhola Nutan Biddut BD LTD	IPP	220	0	51	415255	On Test
	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	28800	Reserve.
Barisal Area Total				1826	920	19276613	
117	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
118	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	280256	Reserve.
119	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	99021	Engine problem
120	Amnura 5						