

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2021				Day : Saturday		Date : 24.04.21									
Probable Maximum Demand :				13300	MW	Probable Maximum Generation : 15828				MW	Rule Curve = 83.40				ft.
Water Level of Kaptai Lake at 06:00 AM				Yesterday =	78.48	ft.	Today = 78.34				ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.04.21 (Yesterday)		24.04.21 (Today)		23.04.21 (Yesterday)		24.04.21 (Today)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Gen. shortfall for :		Description/ Remarks		Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:															
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170		Under Repowering		
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under Repowering		
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Under maint.		
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	99	103	104	104						
4	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		CB Problem		
5	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20		Under Maint.		
6	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	340	344	360	360	16			Gas Shortage		
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170			Gas Shortage		
8	210 MW Siddhirganj PP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling		
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412			Dirt in gas		
10	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	90	140	200	200	70			Gas Shortage		
11	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	214	218	220	220		117		ST under maint.		
12	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	16	100	100						
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	275	225	285	285	80			dirt in gas		
14	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	0	7	100	100						
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55						
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100						
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	16	100	100						
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	22	22						
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6.02.97+7x8.73	80	80	41	54	50	50						
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33						
21	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33						
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52						
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	34	105	105						
24	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	0	0	149	149						
25	Kalpottti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0						
26	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54						
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	300	300						
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	130	149	149	149						
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300						
30	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100						
31	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100						
32	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	17	35	55	55						
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	35	35						
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0						
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	53	104	104						
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	162	162						
37	Manikganj 35MW Solar PP (Inspect)	Solar (IPP)	1x35	35	35	25	0	30	0						
Dhaka Zone Total				6026	5829	1831	2083	3667	3887	748	1072				
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	35	35	35	35	195			Low Water Level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0	0						
41	Raczan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	17	17						
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0						
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	50	50						
44	Sikalbaha 105 MW PP (Baraka Sika)	HFO (IPP)	6x18.415	105	105	51	105	100	100						
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	130	130						
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	217	220	220						
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300						
48	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	80	100	100	100						
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	100	100	100						
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	49	54	66	66						
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0						
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22						
*	Malancha Ctg.EPZ (United)	Gas	5x8.73+3x9.34			27	40	11	21						
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	45	90	90						
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54						
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110						
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	100	100	100						
57	Chattogram 116 MW PP (Anilima En)	HFO (IPP)	6x21.06	116	116	0	90	116	116						
Chattogram Zone Total				2442	2382	755	1108	1646	1631	195	360				
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	120	135	135	15			Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26						
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	204	196	225	225						
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	300	320	310	310						
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	295	315	340	340						
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	45	53	55	55						
64	Ashuganj 199MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187			Gas shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0		51		Line fault		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0						
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0						
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	95	96	95	95		67		ST Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	85	176	170	170						
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	10	22	22	22						
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11						
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33						
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	1	52	52	52						
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	20	20	20						
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	195'4+8x1.515+15x1.058	200	200	0	0	100	200						
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114						
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	0	113	113	113						
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	37	37						
**	Imporpt (Tripura)	India		160	160	108	166	157	179						
Cumilla Zone Total				3094	3034	1354	1762	2023	2195	465	118				
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	196	204	205	205						
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20						
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	74	74	74	74						
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	96	115	115	115						
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	150	200	200						
84	Sanishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	33	0	50	0						

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.04.21 (Yesterday)		24.04.21 (Today)		23.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	39	40	40	40		30	GT-1 Load gear problem		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	43	42	43		47	Under maint.		
89	Fenchugonj 51 MW PP (Barakatulla)	Gas (RPP)	19x2.90	51	51	53	53	51	51					
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
91	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	32	52	52		34	Under maint.		
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	328	334	330	330					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	78	75	75					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x69	231	231	0	145	135	210					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	17	18	18					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	9	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	320	341	341					
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	396	400	400					
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	392	400	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total				2422	2377	1893	2057	2084	2160	0	111			
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16					
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	300	390	400	400					
105	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20					
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60					
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220					
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	16	99	99	99					
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x3.4+7x3.515	100	100	0	63	50	100					
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	32	32	33					
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	92	90	92					
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	842	842	854	854					
Khulna Zone Total				2288	2284	1158	1518	1705	1994	0	0			
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110					
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	34	33	33					
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	60	60	60	60		134	GT-2 & STG Under maint.		
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	93	96	95	95					
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	360	560	622	622					
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	50					
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	109	110					
Barishal Zone Total				1826	1826	532	877	1029	1080	0	134			
119	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	50	50	50	50	21		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	50	50	50	50	50		Gas Shortage		
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	35	40					
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	12	50	50					
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	100	100					
125	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	31					
126	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43					
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	30					
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	60	130	144	144	80		Gas Shortage		
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+ 1x75	220	220	146	199	180	200					
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	153	201	200	200					
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	379	404	400	400					
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	22	22					
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11					
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	50	50					
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	70	113	113					
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	113	113	113					
Rajshahi Zone Total				2173	2173	861	1525	1841	1897	151	0			
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	76	73	75	75	12		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage		
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	10	10					
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	113	113	113					
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
142	Majpara, Talula 8 MW Solar PP (Sympa Po	Solar (IPP)	1 x 8	8	8	7	0	8	0					
Rangpur Zone Total				685	605	267	336	356	348	221	0			
Sub-total: Plants in operation				21673	21219	9072.0	11853	15039	15828	1780	1795			
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss						8669	11326	14370	15124					
(B) Plants under long term maintenance/ contract expired														
143	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021		
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
145	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021		
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020		
147	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
Sub-Total: Plants under long term maintenance/ contract expired				294	0	0	0	0	0					
Gross Total				21967	21219	9072	11853	15039	15828	1780	1795			
(C) Actual data of 23.04.21 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)	:	11853.00	MW,	at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11326.00	MW,	at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11853.00	MW,	at =	21:00 hrs	Dhaka	3584	3584	0	Mymensingh	1018	1018	0
04.	Minimum Generation (Generation end)	:	8277.00	MW,	at =	8:00 hrs	Chattogram	1289	1289	0	Sylhet	469	469	0
05.	Day-peak Generation (Generation end)	:	9072.00	MW,	at =	12:00 hrs	Khulna	1466	1466	0	Barishal	356	356	0
06.	Evening-peak Generation (Generation end)	:	11853.00	MW,	at =	21:00 hrs	Rajshahi	1215	1215	0	Rangpur	755	755	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Cumilla	1174	1174	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7962.00	MW,	at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:												
	a) Gas limitation	:	1364	MW			13.	Fuel cost :	(a) Gas = 166723779 Taka	(c) Coal = 549023071 Taka				
	d) Coal supply Limitation	:	221	MW				(b) Oil = 342833786 Taka	Total = 1058580636 Taka					
	b) Low water level in Kapta lake	:	195	MW										
	c) Plants under shut down/ maintenance	:	1795	MW			14.	Maximum Temperature in Dhaka was : 34.9° C						
10.	Total Energy (Generation + India Import)	:	348.92	MKWh			15.	Export through East-West interconnections :						
	By Gas = 153.485			By Oil = 46.792	MKWh			At evening peak-hour	:	288	MW,	at	21:00 hrs	
	By Coal = 123.537			By Hydro = 0.848	MKWh			Maximum	:	-60	MW,	at	18:30 hrs	
	By Solar= 0.807							Energy	:	0.0425	MKWh			
11.	Total Gas Supplied	:	1253.30	MMCFD										
(D) Forecast of 24.04.21 (Today) Saturday :														
01.	Maximum Demand	:	13300	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15828	MW	(Generation end)		05.	Total Generation	:	391.52	MKWh			
03.	Maximum Shortage	:	-2528	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	40.8° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13380 MW on 15-04-2021 at 21:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation