

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2021					Day : Monday				Date : 26.04.21				
Probable Maximum Demand : 13700 MW					Probable Maximum Generation : 15425 MW								
Water Level of Kaptai Lake at 06:00 AM					Rule Curve = 83.20 ft.								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Yesterday = 78.10	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Today = 77.86		26.04.21 (Today)		25.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW			
						Day	Evening	Day	Evening	Day	Evening		
(A) Plants in operation:													
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under Repowering	
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering	
	c) Ghorasal TPP Unit-5	Gas (PDB)	1x 210	210	190	180	180	180	180				
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.	
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	104	104	104				
4	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
5	Hairpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Under Maint.	
6	Hairpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	298	342	345	345	18		Gas Shortage	
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	290	290	300	300	160		Gas Shortage	
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
9	Hairpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	155	0	0	0	412		Dirt in gas	
10	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	179	175	150	180	35		Gas Shortage	
11	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	206	215	220	220		120	ST under maint.	
12	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	250	245	250	250	60		dirt in gas	
14	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	99	100	100	100				
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	43	55	55	55				
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	0	0				
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	60	102	102	102				
18	Narshingdi 22 MW PP (Doreen)	Gas (SIIP, REB)	8x2.90	22	22	19	19	22	22				
19	Summit Power,(Madhabdi+Ashula)	Gas (SIIP, REB)	6x8.57+8x7.3	80	80	49	49	50	50				
20	Maona 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	33	33	33	33				
21	Rupganj 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	0	33	33	33				
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	15	50	52	52				
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	40	150	150	150				
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
26	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54				
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	99	0	75	250				
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	148	149	149				
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	300	100	300				
30	Branhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.999	100	100	0	100	50	100				
31	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.999	100	100	0	0	0	0				
32	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	35	55	55	55				
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	37	35	35				
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	89	90	104	104				
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	162	162	162				
37	Manikganj 35MW Solar PP (Inspect	Solar (IPP)	1x35	35	35	32	0	30	0				
Dhaka Zone Total				6026	5829	2834	3293	3165	3590	685	1075		
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	35	35	35	35	195		Low Water Level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0				
41	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	17	17	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	50	50	50				
44	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	0	105	100	100				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	120	120	120				
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	180	204	205	205				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300				
48	Juddah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	80	100	100	100				
49	Juddah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100				
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	26	66	66	66				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
52	Barabkunda 22 MW PP (Regent)	Gas (SIIP, PDB)	8x2.90	22	22	20	21	22	22				
53	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	26	10	25				
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	7	90	90	90				
55	Sikalbaha 54 MW Power Plant(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	54	54				
56	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	17	110	110				
57	Juddah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100				
58	Chattogram 116 MW PP (Anlima En	HFO (IPP)	6x21.06	116	116	0	110	116	116				
Chattogram Zone Total				2442	2382	728	1215	1620	1610	195	360		
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	135	135	135	135	0		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	25	26	26	26				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	194	191	225	225				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	315	295	330	330				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	330	300	330	330				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	1574	55	55	51	40	55	55				
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	45	45	45	45	150		Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	25	25	51		Line fault	
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	48	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	95	95	95	95	68		Gas Shortage	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	158	158	180	180				
70	Feni 22MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	22	22	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIIP, REB)	4x2.90	11	11	10	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIIP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	49	52	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIIP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	200	200	0	197	100	200	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	22	114	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	113	113	113	113				
78	Bhairab 54 MW PP	HFO (IPP)	3x8.2	54	54	35	35	37	37				
**	Import (Tirupura)	India		160	160	140	158	156	171				
Cumilla Zone Total				3094	3034	1792	2088	2104	2419	481	51		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	97	175	175	175				
80	Tangail 22 MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	17	19	20	20				
81	Jamalspur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	65	65	74	74				
82	Jamalspur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	106	115	115	115				
83	Mymsensing 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	125	198	200	200				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	16	0				
85	Satishkahi 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0				
86	Tangail 22 MW PP(PPLCL)	HFO (IPP)	4x6.7	22	22	22	23	22	22				
Mymsensing Zone Total				717	709	486	595	658	606	0	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.04.21 (Yesterday)		26.04.21 (Today)		25.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	Under maint.	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	42	43		47	Under maint.	
89	Fenchugonj 51 MW PP (Barakatulla)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
90	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	5	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	66	66	66				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	160	250	275	275				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	74	77	78	78				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x69	231	231	217	218	225	225				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	9	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	341	341	341				
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	385	402	400	400				
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	378	370	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total						2422	2377	1894	2037	2096	2097	0	117
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
104	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	375	400	400	400				
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	19	20	20				
106	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	99	99	99				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	24	32	32	33				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	91	91	90	92				
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDCL)	India		1000	1000	839	725	737	737				
Khulna Zone Total						2288	2284	1412	1466	1588	1877	0	0
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110				
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	34	33	33				
115	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	62	65	66	66		129	GT-2 & STG Under maint.	
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	61	96	95	95				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	480	590	622	622				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	50				
Bhola Nutan Biddut BD LTD													
Barisal Zone Total						1826	1826	623	968	1035	1086	0	129
119	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	30	65	0	0	6		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	50	50	50	50				
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	200	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	38	40	45				
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	42	42	42				
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	100	100				
125	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	31				
126	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	43	43				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	30				
128	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	150	150		210	Under maint.	
129	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	140	210	180	200				
130	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	181	137	200	200				
131	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	356	415	400	400				
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	21	22	22				
133	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	11	10	11	11				
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	90	113	113	113				
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
Rajshahi Zone Total						2173	2173	1040	1522	1746	1802	106	210
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	72	73	75	75	12		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2'3	113	113	107	113	113	113				
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Majpara, Tatula 8 MW Solar PP (Sympa Po)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
Rangpur Zone Total						685	605	336	346	338	221	0	
Sub-total: Plants in operation						21673	21219	11145.0	13520	14358	15425	1688	1942
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							10497	12734	13523	14528			
(B) Plants under long term maintenance/ contract expired													
143	Ghorashal 78.5 MW PP (MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
144	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
147	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired						294	0	0	0	0	0		
Gross Total						21967	21219	11145	13520	14358	15425	1688	1942
(C) Actual data of 25.04.21 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	13520.00	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12734.00	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13520.00	MW, at =	21:00 hrs	Dhaka	4299	4299	0	Mymensingh	1073	1073	0
04.	Minimum Generation (Generation end)	:	9129.00	MW, at =	7:00 hrs	Chattogram	1349	1349	0	Sylhet	535	535	0
05.	Day-peak Generation (Generation end)	:	11145.00	MW, at =	12:00 hrs	Khulna	1586	1586	0	Barisal	376	376	0
06.	Evening-peak Generation (Generation end)	:	13520.00	MW, at =	21:00 hrs	Rajshahi	1461	1461	0	Rangpur	765	765	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Cumilla	1290	1290	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9950.00	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:								Total	12734	12734	0
	a) Gas limitation	:	1272	MW		13.	Fuel cost :	(a) Gas = 168541158 Taka	(c) Coal = 89633780 Taka				
	d) Coal supply Limitation	:	221	MW			(b) Oil = 633903549 Taka	Total = 892078466 Taka					
	b) Low water level in Kaptai lake	:	195	MW									
	c) Plants under shut down/ maintenance	:	1942	MW		14.	Maximum Temperature in Dhaka was : 39.5° C						
10.	Total Energy (Generation + India Import)	:	278.97	MKWh		15.	Export through East-West interconnections :						
	By Gas = 154.754 MKWH			By Oil =	81.578 MKWh		At evening peak-hour :						
	By Coal = 18.911 MKWH			By Hydro =	0.848 MKWh			-300	MW, at	21:00 hrs			
	By Solar= 0.812 MKWH							Maximum	-410	MW, at	23:00 hrs		
								Energy	0.547	MKWh			
11.	Total Gas Supplied	:	1271.44	MMCFD									
(D) Forecast of 26.04.21 (Today) Monday :													
01.	Maximum Demand	:	13700	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	15425	MW	(Generation end)	05.	Total Generation : 282.69 MKWh						
03.	Maximum Shortage	:	-1725	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 41.8° C						

* Captive Power ** Imported Power

#Remarks: Highest Generation 13520 MW on 25-04-2021 at 21:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation