

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2021				Day : Monday				Date : 10.05.21				
Probable Maximum Demand : 11800 MW				Probable Maximum Generation : 15724 MW				Rule Curve = 80.48 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.98 ft.				Today = 75.98 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.05.21 (Yesterday)		10.05.21 (Today)		09.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under Repowering
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	100	102	100	100			
4	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem
5	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Under Maint.
6	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	137	110	163	163	250		Gas Shortage
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	280	280	180		Gas Shortage
8	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	356	329	350	360	83		Dirt in gas
10	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	147	150	120	150	60		Gas Shortage
11	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	211	221	220	220		114	ST under maint.
12	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	40	100	100			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	230	225	225	225	80		dirt in gas
14	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	100	100			
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	50	40	55	55			
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100			
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	0	102	102			
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	8x3.67+7x6.73	80	80	49	38	53	53			
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	0	52	52			
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	88	105	105			
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	150	150			
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35			
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	163	0	250	250			
28	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	131	133	149	149			
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300			
30	Bramhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
31	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100			
32	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	0	55	55			
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	53	90	90			
36	Manikganj 162MW PP(MPLG)	HFO (IPP)	9x18	162	162	108	72	162	162			
37	Manikganj 35MW Solar PP (Inspect)	Solar (IPP)	1x35	35	35	18	0	30	0			
Dhaka Zone Total				6026	5829	2707	2229	3569	3879	653	1069	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	23	23	22	22	207		Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	80	80	80	80			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	17	17	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	18	22	43	43			
44	Sikalbaha 105 MW PP (Baraka Sila)	HFO (IPP)	6x18.415	105	105	89	89	90	90			
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	140	130	140			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	215	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300			
48	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	50	100	100			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	100	100	100			
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	21	22	22			
53	* Malanoha, Ctg EPZ (United)	Gas	5x8.73+3x3.34			3	40	15	20			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	50	90	90			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	17	110	110			
57	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
58	Chattogram 116 MW PP (Anlima Energy)	HFO (IPP)	6x21.06	116	116	116	116	116	116			
Chattogram Zone Total				2442	2382	967	1202	1707	1697	207	180	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135		Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	100	80	80	34		Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	23	26	26			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	186	195	220	220			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	265	320	330	330			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	310	335	330	330			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	30	55	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	45	8	45	150		Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	68	50	150	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	132	134	130	130			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	135	140	140			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	45	52	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	15	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x1.4+40x1.510+15x1.388	200	200	0	0	100	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	113	113	113	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	36	36			
**	Import (Tripura)	India		160	160	132	134	157	188			
Cumilla Zone Total				3094	3034	1681	1826	2178	2396	448	0	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	118	131	160	160	71		Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	19	19			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	65	73	74	74			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	115	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	0	200	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0			
86	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22			
Mymensingh Zone Total				717	709	388	360	642	590	71	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.05.21 (Yesterday)		10.05.21 (Today)		09.05.21 Gen. shortfall for : Gas/water/Coal limitation MW	09.05.21 (Yesterday) Gen. shortfall for : Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
89	Fenchugonj 51 MW PP (Barakattula)	Gas (RPP)	19x2.90	51	51	5	53	51	51				
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	33	32	32				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	272	273	163	275				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	71	76	76	78				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	177	215	225	225				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	341	341				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	368	390	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total				2422	2377	1909	2050	1991	2105	0	75		
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	225	215	210	210	195		Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	99	99	99	99				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	32	33				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	17	105	105				
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	842	842	855	855				
Khulna Zone Total				2288	2284	1201	1173	1531	1802	195	0		
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	64	0	110	110				
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	24	28	35	35				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	15	88	88	88		106	Gas Shortage	
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	96	62	95	95				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	480	480	622	622				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	80	80				
Bhola Nutan Biddut BD LTD			Gas+HSD (IPP)			2	73	90	90				
Barishal Zone Total				1826	1826	681	731	1120	1120	0	106		
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	40				
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42				
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	50	100	100				
125	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	29	29				
126	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	41	0	32				
128	Siragoinj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	100	88	130	130	62		Gas Shortage	
129	Siragoinj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	135	150	200	200	70		Gas Shortage	
130	Siragoinj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	150	160	200	200	60		Gas Shortage	
131	Siragoinj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	343	420	400	400				
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	35	113	113				
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	35	113	113				
Rajshahi Zone Total				2173	2173	847	1114	1745	1777	363	0		
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	72	73	75	75	12		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	110	70	113	113				
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Majpara, Tutula 8 MW Solar PP (Sympa Po)	Solar (IPP)	1 x 8	8	8	1	0	8	0				
Rangpur Zone Total				685	605	333	293	346	358	221	0		
Sub-total: Plants in operation				21673	21219	10714.0	10978	14829	15724	2158	1430		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10333	10588	14302	15165				
(B) Plants under long term maintenance/ contract expired													
143	Chorashal 78.5 MW PP (MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
144	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
147	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired				294	0	0	0	0	0				
Gross Total				21967	21219	10714	10978	14829	15724	2158	1430		
(C) Actual data of 09.05.21 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	10978.00	MW,	at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	10588.00	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	11358.00	MW,	at =	1:00 hrs		MW	MW			MW	MW
04.	Minimum Generation (Generation end)	:	8936.00	MW,	at =	7:00 hrs	Dhaka	3817	3817	0	Mymensingh	792	792
05.	Day-peak Generation (Generation end)	:	10714.00	MW,	at =	12:00 hrs	Chattogram	1227	1227	0	Sylhet	441	441
06.	Evening-peak Generation (Generation end)	:	10978.00	MW,	at =	21:00 hrs	Khulna	1270	1270	0	Barisal	273	273
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Rajshahi	1115	1115	0	Rangpur	619	619
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7793.00	MW,	at =	5:00 hrs	Cumilla	1034	1034	0			
09.	Generation shortfall at evening peak due to :	:									Total	10588	10588
	a) Gas limitation	:	1730	MW			13.	Fuel cost :	a) Gas = 165173540	Taka	c) Coal = 81960788	Taka	
	d) Coal supply Limitation	:	221	MW					b) Oil = 367976878	Taka	Total = 615111206	Taka	
	b) Low water level in Kaptai lake	:	207	MW									
	c) Plants under shut down/ maintenance	:	1430	MW									
10.	Total Energy (Generation + India Import)	:	247.42	MKWh			14.	Maximum Temperature in Dhaka was : 34.7° C					
	By Gas = 152.089			MKWh			15.	Export through East-West interconnections :					
	By Coal = 17.180			MKWh				At evening peak-hour :					
	By Solar= 0.661			MKWh				Maximum :					
								Energy :					
11.	Total Gas Supplied	:	1243.48	MMCFD									
(D) Forecast of 10.05.21 (Today) Monday :													
01.	Maximum Demand	:	11800	MW	(Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)					
02.	Maximum Generation	:	15724	MW	(Generation end)		05.	Total Generation : 257.05 MKWh					
03.	Maximum Shortage	:	-3924	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka : 32.3° C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation