

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

| Date : 20-May-21      |                                                  |                |                    |                  |                      |                  | Page - 2                     |
|-----------------------|--------------------------------------------------|----------------|--------------------|------------------|----------------------|------------------|------------------------------|
| No.                   | Name of the Power Stations                       | Producer       | Installed Capacity | Present Capacity | Peak Hour Generation | Energy Generated | Remarks                      |
| Unit No. X Capacity   |                                                  |                |                    |                  |                      |                  |                              |
|                       |                                                  |                | MW                 | MW               |                      | KWH              |                              |
| 1                     | Ghorasal Repowered CCGP Unit-1                   | PDB            | 1*260              | 260              | 0                    | 0                | Under maint.                 |
| 2                     | Ghorasal Repowered CCGP Unit-2                   | PDB            | 1*210              | 180              | 0                    | 0                | Under maint.                 |
| 3                     | Ghorasal TPP Unit-5                              | PDB            | 1*210              | 190              | 190                  | 4410000          |                              |
| 4                     | Ghorasal 365 MW CCGP Unit-7                      | QRPP           | 1*243+1*122        | 365              | 0                    | 0                | Under maint.                 |
| 5                     | Ghorashal 78.5 MW PP(MAX)                        | QRPP           | 2*40               | 0                | 0                    | 0                | Contract Expired             |
| 6                     | Haripur 108MW PP (Regent)                        | IPP            | 34*3.35            | 108              | 101                  | 2240409          |                              |
| 7                     | Haripur GTTP                                     | SBU, PDB       | 2*32               | 20               | 0                    | 0                | Under maint.                 |
| 8                     | Haripur 412 MW CCGP                              | EGCB           | 1*273+1*139        | 412              | 344                  | 8237835          | FGMO                         |
| 9                     | Haripur 360MW CCGP(HPL)                          | IPP            | 1*235+1*125        | 360              | 325                  | 7836000          | Gas shortage                 |
| 10                    | Meghnaghat 450 MW CCGP(MP)                       | IPP            | 2*150+1*150        | 450              | 300                  | 7068000          | Gas shortage                 |
| 11                    | Meghnaghat 100 MW(IEI)                           | QRPP           | 12*8.9             | 100              | 0                    | 0                | Contract Expired             |
| 12                    | Meghnaghat CCGP(Summit)                          | IPP            | 2*110+1*110        | 305              | 280                  | 6539695          | FGMO                         |
| 13                    | Madanganj 102 PP(Summit)                         | QRPP           | 6*17               | 0                | 0                    | 0                | Contract Expired             |
| 14                    | Madanganj-55 MW PP(Summit)                       | (IPP)          | 3*17.06+1*11.3     | 55               | 55                   | 1282140          |                              |
| 15                    | Keraniganj 100 MW PP (Powerpa                    | QRPP           | 8*13.45            | 100              | 0                    | 746              | Reserve.                     |
| 16                    | Narsingdi 22 MW PP (Doreen)                      | SIPP, REB      | 8*2.90             | 22               | 16                   | 331992           | Engine problem               |
| 17                    | 210 MW Siddhirganj TPP                           | PDB            | 1*210              | 115              | 0                    | 0                | Under maint.                 |
| 18                    | Siddhirganj 2*120 MW GTTP                        | EGCB           | 2*105              | 210              | 185                  | 3495000          | FGMO                         |
| 19                    | Siddhirganj 100 PP(Dutch Bangla                  | QRPP           | 12*8.9             | 100              | 65                   | 1887360          | Low demand                   |
| 20                    | Siddhirganj 335 MW CCGP                          | EGCB           | 1*217+1*118        | 335              | 218                  | 4795293          | ST Under Maint.              |
| 21                    | Gagnagar 102 MW PP (Digital P                    | IPP            | 12*8.924           | 102              | 48                   | 790848           | Low demand                   |
| 22                    | Kalpott 52 MW PP (Sinha)                         | IPP            | 7*7.9              | 51               | 0                    | 0                | Fuel shortage                |
| 23                    | Kamalaghat 54 MW PP(Banco E                      | IPP            | 3*18               | 54               | 35                   | 818960           | Engine problem               |
| 24                    | Kodda 150MW PP                                   | BPDB-RPCL      | 9*17.06            | 149              | 48                   | 1347840          | Low demand                   |
| 25                    | Manikganj 55 MW PP (Northern)                    | IPP            | 3*19.3             | 55               | 17                   | 363794           | Low demand                   |
| 26                    | Nababganj 55 MW PP (Southern                     | IPP            | 3*19.3             | 55               | 55                   | 1277965          |                              |
| 27                    | Bosila 108MW PP(CLC)                             | IPP            | 12*8.775+1*3.5     | 108              | 0                    | 0                | Fuel shortage                |
| 28                    | Summit Power, (Madhabadi-Ashul                   | SIPP, REB      | 3*3.67+4*8.73      | 80               | 41                   | 991500           | Engine problem               |
| 29                    | Maona 33 MW PP(Summit)                           | SIPP, REB      | 4*8.73             | 33               | 33                   | 742000           |                              |
| 30                    | Ruganaj 33 MW PP(Summit)                         | SIPP, REB      | 4*8.73             | 33               | 16                   | 399300           | Engine problem               |
| 31                    | Gazipur 52 MW PP                                 | IPP            | 6*8.9              | 52               | 16                   | 696480           | Low demand                   |
| 32                    | Tongi 80 MW GTTP                                 | PDB            | 1* 105             | 105              | 0                    | 0                | Under maint.                 |
| 33                    | Kodda 300 MW PP Unit-2 (Summ                     | IPP            | 18*17.076          | 300              | 195                  | 2034872          | Low demand                   |
| 34                    | Keraniganj 300 MW PP (APR)                       | IPP            | 25*11.4            | 300              | 0                    | 0                | Reserve.                     |
| 35                    | Bramhanganj 100 MW PP (Agg                       | IPP            | 100                | 100              | 0                    | 0                | Reserve.                     |
| 36                    | Aurahat 100MW PP (Aggreko)                       | IPP            | 0.85*23+0.95*9.1   | 100              | 0                    | 0                | Reserve.                     |
| 37                    | Kodda 149 MW PP Unit-1 (Summ                     | IPP            | 149                | 149              | 130                  | 3008880          | Engine problem               |
| 38                    | Gazipur 100 MW PP                                | RPCL           | 100 MW             | 105              | 50                   | 1357200          | Low demand                   |
| 39                    | Meghnaghat 104 MW PP (OPCL                       | IPP            | 18.5*5             | 104              | 56                   | 1408320          | Engine problem               |
| 40                    | Manikganj 162MW PP(MPGCL)                        | IPP            | 9*18               | 162              | 54                   | 2239320          | Low demand                   |
| 41                    | Spectra Solar Plant Ltd.                         | IPP            | 35                 | 35               | 0                    | 219529           |                              |
| Dhaka area Total      |                                                  |                |                    |                  |                      |                  | 5919 2873 65870878           |
| 41                    | Chattogram TPP-1                                 | PDB            | 1*210              | 180              | 0                    | 0                | Under maint.                 |
| 42                    | Chattogram TPP-2                                 | PDB            | 1*210              | 180              | 0                    | 0                | Gas shortage                 |
| 43                    | Raazan 25 MW PP                                  | IPP            | 3*8.9              | 25               | 17                   | 394338           | Engine problem               |
| 44                    | Teknaf 20MW PP (SolarTech)Knaif Solartech Energy | IPP            | 20                 | 20               | 0                    | 135540           |                              |
| 45                    | Patenga 50MW PP (Baraka)                         | IPP            | 8*6.98             | 50               | 25                   | 400800           | Low demand                   |
| 46                    | Kaptai Hydro: Unit-1,2,3,4, 5                    | PDB            | 2*40+3*50          | 230              | 25                   | 612000           | Low water level & Unit-2 unc |
| 47                    | Sikalbaha 225MW                                  | PDB            | 1*150+1*175        | 225              | 131                  | 3152025          | FGMO                         |
| 48                    | Sikalbaha Peaking GT                             | PDB            | 1*150              | 150              | 110                  | 2642975          |                              |
| 49                    | Sikalbaha 105 MW PP (Baraka S                    | IPP            | 105 MW             | 105              | 89                   | 2195454          | Engine problem               |
| 50                    | Hathazari 100 MW peaking PP                      | PDB            | 11*8.9             | 98               | 0                    | 0                | Under S/D                    |
| 51                    | Dohazari -Kalaish 100 MW Peak                    | PDB            | 6*17               | 102              | 68                   | 493997           | Engine problem               |
| 52                    | Juldah 100 MW Unit-1 (Acorn)                     | QRPP           | 8*13.45            | 100              | 100                  | 2133480          |                              |
| 53                    | Juldah 100 MW PP Unit-3 (Acorn                   | IPP            | 0                  | 100              | 100                  | 2345280          |                              |
| 54                    | Barakunda 22 MW PP (Regent)                      | SIPP, PDB      | 8*2.90             | 22               | 20                   | 465264           |                              |
| 55                    | * Malancha, Cg. EPZ (United)                     | IPP            | 5*8.73+9.34        | 0                | 25                   | 478520           |                              |
| 56                    | Chattogram 108 MW PP (ECPV)                      | IPP            | 16*7               | 108              | 18                   | 590400           | Low demand                   |
| 57                    | Kaptai 7 MW Solar PP                             | PDB            | 7.4 MW             | 7                | 0                    | 30600            |                              |
| 58                    | Anwara 300 MW PP (United)                        | IPP            | 300 MW             | 300              | 0                    | 0                | Reserve.                     |
| 59                    | Jodiad Power                                     | IPP            | 3*18.55+1*3.6      | 54               | 54                   | 1273333          |                              |
| 60                    | Karnaphuli Power Ltd.                            | IPP            | 110                | 110              | 17                   | 781163           | Low demand                   |
| 61                    | Juldah unit-2 (Acorn)                            | IPP            | 8*13.6             | 100              | 100                  | 2022720          |                              |
| 62                    | Anlima Energy Ltd.                               | IPP            | 6*21.2             | 116              | 111                  | 2209255          |                              |
| Chattogram area Total |                                                  |                |                    |                  |                      |                  | 2382 1010 22358144           |
| 61                    | Ashuganj TPP Unit- 3                             | APSCL          | 1*150              | 135              | 0                    | 0                | Gas Shortage                 |
| 62                    | Ashuganj TPP Unit- 4                             | APSCL          | 1*150              | 129              | 0                    | 0                | Gas shortage                 |
| 63                    | Ashuganj TPP Unit- 5                             | APSCL          | 1*150              | 134              | 80                   | 2013618          | Gas shortage                 |
| 64                    | Ashuganj 225 MW CCGP                             | APSCL          | 1*142+1*75         | 221              | 218                  | 5020000          | FGMO                         |
| 65                    | Ashuganj 450 MW CCGP(North)                      | APSCL          | 1*360              | 360              | 285                  | 7390000          | FGMO                         |
| 66                    | Ashuganj 450 MW CCGP(South)                      | APSCL          | 1*360              | 360              | 285                  | 7028000          | FGMO                         |
| 67                    | Ashuganj 50 MW PP                                | APSCL          | 14*3.968           | 45               | 26                   | 470160           | Engine problem               |
| 68                    | Ashuganj 55 MW PP (Precision)                    | RPP            | 15*4               | 55               | 20                   | 980160           | Gas shortage                 |
| 69                    | Ashuganj 150MW PP (APCL-U                        | IPP            | 20*7.3+1*16        | 195              | 8                    | 200727           | Gas shortage                 |
| 70                    | Ashuganj 51 MW PP (Midland)                      | IPP            | 6*9.34             | 51               | 51                   | 1109080          |                              |
| 71                    | Ashuganj 150MW PP (Midland)                      | IPP            | 23*7.015           | 150              | 148                  | 2472290          |                              |
| 72                    | Tilas 50 MW Peaking PP                           | PDB            | 6*8.92             | 52               | 50                   | 204120           |                              |
| 73                    | Chandpur 150 MW CCGP                             | PDB            | 1*106+1*57         | 163              | 86                   | 1929750          | Machine problem              |
| 74                    | Chandpur 200MW (Desh energy                      | IPP            | 0                  | 200              | 120                  | 2637280          | Engine problem               |
| 75                    | Feni 22MW PP (Doreen)                            | SIPP, PDB      | 8*2.90             | 22               | 22                   | 418248           |                              |
| 76                    | Feni 11 MW PP (Doreen)                           | SIPP, REB      | 4*2.90             | 11               | 5                    | 133200           | Engine problem               |
| 77                    | * Impoprt (Tripura)                              | Imported power | 0                  | 160              | 164                  | 3694080          |                              |
| 78                    | Jangalia 33MW PP (Summit)                        | SIPP, PDB      | 4*8.73             | 33               | 33                   | 805300           |                              |
| 79                    | Jangalia 52 MW PP (Lakdanavi)                    | IPP            | 6*8.92             | 52               | 52                   | 1243224          |                              |
| 80                    | Jangalia 25 MW PP (Summit)                       | SIPP, PDB      | 3*3.67+2*6.97      | 25               | 20                   | 470770           | Engine problem               |
| 81                    | Quaidandi 200 MW PP (B.Trac)                     | IPP            | 15*11.4            | 200              | 0                    | 0                | Reserve.                     |
| 82                    | Feni Lanka Power                                 | IPP            | 7*18.415+1*9.78    | 114              | 52                   | 458280           | Low demand                   |
| 83                    | Chowmuhani 113 MW                                | IPP            | 12*9.78+2*3.1      | 113              | 120                  | 2735040          |                              |
| 84                    | Bhairab 54.5 MW                                  | IPP            | 3*18.2             | 54               | 17                   | 703080           | 33 kV feeder fault.          |
| Cumilla Area Total    |                                                  |                |                    |                  |                      |                  | 3034 1862 42325407           |
| 82                    | RPCL 210MW CCGP                                  | IPP            | 4*35+1*70          | 202              | 153                  | 4115920          | Gas shortage                 |
| 83                    | Tangail 22 MW PP (Doreen)                        | SIPP, PDB      | 8*2.90             | 22               | 0                    | 309660           | Engine problem               |
| 84                    | Jamalpur 95 MW PP(Powerpac)                      | IPP            | 12*8.924           | 95               | 64                   | 1311360          | Engine problem               |
| 85                    | Sarishabari 3 MW Solar Plant                     | IPP            | 1*3                | 3                | 0                    | 10200            |                              |
| 86                    | Mymensingh 200 MW PP (Unit                       | IPP            | 200                | 200              | 8                    | 1310400          | Low demand                   |
| 87                    | Jamalpur 115 MW PP (United)                      | IPP            | 115 MW             | 115              | 45                   | 2276400          | Low demand                   |
| 88                    | Sutakhirali 50 MW Solar PP                       | IPP            | 50                 | 50               | 0                    | 314680           |                              |
| 89                    | Tangail Pali Power Gen 22 MW                     | IPP            | 4*6.7              | 22               | 24                   | 574320           |                              |
| Mymensingh Area Total |                                                  |                |                    |                  |                      |                  | 709 294 10304240             |
| 90                    | Fenchugonj CCGP Phase-1                          | PDB            | 2*32+1*33          | 70               | 43                   | 1020000          | Machine problem              |
| 91                    | Fenchugonj CCGP Phase-2                          | PDB            | 2*35+1*35          | 90               | 22                   | 522720           | Machine problem              |
| 92                    | Kushihara 163 MW CCGP (KP)                       | IPP            | 1*109+1*54         | 163              | 163                  | 3517118          |                              |
| 93                    | Shahjibazar 330 MW CCGP                          | PDB            | 3*110              | 330              | 192                  | 4518025          | GT-2 Synchronized at 20:24   |
| 94                    | Fenchugonj 51 MW PP (Barakat                     | RPP            | 19*2.90            | 51               | 53                   | 1161600          |                              |
| 95                    | Fenchugonj 44MW (Energyprima                     | RPP            | 12*3.3+5*2         | 0                | 0                    | 0                | Contract Expired             |
| 96                    | Hobiganj 11MW PP Confidence-E                    | SIPP, REB      | 4*2.90             | 11               | 0                    | 214000           |                              |
| 97                    | Shahjibazar GTTP Unit- 8 & 9                     | PDB            | 2*35               | 66               | 20                   | 521184           | Engine problem               |
| 98                    | Shahjibazar 86MW PP (Shahjiba                    | RPP            | 32*2.90            | 66               | 78                   | 1693440          | Engine problem               |
| 99                    | Shahjibazar 100 MW GTTP                          | PDB            | 1*100              | 100              | 0                    | 0                | Under Shut down              |
| 100                   | Sylhet 225 MW CCGP                               | PDB            | 1*142+1*89         | 231              | 140                  | 3258460          | Machine problem              |
| 101                   | Sylhet 20 MW GTTP                                | PDB            | 1*20               | 20               | 18                   | 405000           | Machine problem              |
| 102                   | Sylhet 50MW PP (EPL)                             | RPP            | 27*2               | 0                | 0                    | 0                | Contract Expired             |
| 103                   | Shahjahanulla 25 MW PP                           | SIPP, REB      | 3*9.34             | 25               | 16                   | 379344           | Engine problem               |
| 104                   | Bibiana-II 341 MW CCGP (Summ                     | IPP            | 1*222+1*119        | 341              | 300                  | 6802000          | FGMO                         |
| 105                   | Bibiyana-III 400 MW CCGP                         | PDB            | 400 MW             | 400              | 380                  | 8902000          | FGMO                         |
| 106                   | Sylhet 10MW PP (Desh)                            | RPP            | 6*1.95             | 10               | 7                    | 160380           | Engine problem               |
| 107                   | Bibiyana South 400 MW                            | PDB            | 400 MW             | 383              | 350                  | 7188000          | FGMO                         |
| Sylhet Area Total     |                                                  |                |                    |                  |                      |                  | 2377 1782 38148846           |
| 108                   | Bheramara GTTP Unit-3                            | PDB            | 1*20               | 16               | 0                    | 0                |                              |
| 109                   | * Bheramara (HVC)                                | Imported power | 2*500              | 1000             | 916                  | 2139354          |                              |
| 110                   | Khulna 115 PP MW (KPCL-2)                        | QRPP           | 7*17               | 115              | 99                   | 2054400          |                              |
| 111                   | Faridpur 50 MW Peaking PP                        | PDB            | 8*6.89             | 54               | 0                    | 64130            | Reserve.                     |
| 112                   | Khulna 225 MW CCGP                               | NWPGCL         | 1*150+1*75         | 230              | 0                    | 0                | Reserve.                     |
| 113                   | Gopalganj 100 MW Peaking PP                      | PDB            | 16*6.98            | 109              | 0                    | 0                | Reserve.                     |
| 114                   | Bheramara 410 MW CCGP                            | NWPGCL         | 1*278+1*132        | 410              | 370                  | 8927712          | FGMO                         |
| 115                   | Noapara 40 MW PP (Khanjahan,                     | QRPP           | 5*8.5              | 40               | 32                   | 401625           | Engine problem               |
| 116                   | Noapara 100 MW PP (Bangla Tr                     | IPP            | 70*1.4             | 100              | 98                   | 687360           |                              |
| 117                   | Rupsha 105 MW PP (Orion rupsa                    | IPP            | 6*18.445           | 105              | 105                  | 1990080          |                              |
| 118                   | Madhumati 100 MW PP                              | NWPGCL         | 100 MW             | 105              | 105                  | 816192           |                              |
| Khulna Area Total     |                                                  |                |                    |                  |                      |                  | 2284 1725 36334953           |
| 118                   | Barisal 110 MW PP (Summit )                      | IPP            | 7*17.076           | 110              | 110                  | 1487888          |                              |
| 119                   | Bhola 33 MW PP (Venture)                         | RPP            | 1*34.50            | 33               | 34                   | 794284           |                              |
| 120                   | Bhola 225 MW CCGP                                | PDB            | 2*63+1*68          | 194              | 88                   | 2065253          | Machine problem              |
| 121                   | Bhola 95 MW PP (Aggreko)                         | QRPP           | 96*1.10            | 95               | 92                   | 2192879          |                              |
| 122                   | Payra 1320 MW                                    | BCPCL          | 2*622              | 1244             | 500                  | 13150100         |                              |
| 123                   | Bhola Nutan Biddut BD LTD                        | IPP            | 220                | 0                | 0                    | 0                | On Test                      |
| 124                   | United Payra Power Ltd.                          | IPP            | 8*18.5+1*9.5       | 150              | 35                   | 537600           | Low demand                   |
| Barisal Area Total    |                                                  |                |                    |                  |                      |                  | 1826 859 20149004            |
| 124                   | Baghabari 71 MW GTTP                             | PDB            | 1*71               | 71               | 0                    | 0                | Gas shortage                 |
| 125                   | Baghabari 100 MW GTTP                            | PDB            | 1*100              | 100              | 0                    | 0                | Gas shortage.                |
| 126                   | Baghabari 50 MW Peaking PP                       | PDB            | 6*8.9              | 52               | 50                   | 742560           |                              |
| 127                   | Bera 70 MW Peaking PP                            | PDB            | 9*6.29             | 71               | 43                   | 120689           |                              |
| 128                   | Amnura 50 MW PP(Sinha)                           | QRPP           | 7*7.79             | 50               | 24                   | 164640           | Low demand                   |
| 129                   | Katakhal 50 MW PP (Northern                      | QRPP           | 6*8.9              | 50               | 0                    | 8541             | Reserve.                     |
| 130                   | Katakhal 50 MW Peaking PP                        | PDB            | 6*8.7              |                  |                      |                  |                              |