

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 22-May-21		Page -2					
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	190	4410000	
4	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
5	Ghorasah 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
6	Ghorasah 108MW PP (Regent)	IPP	34*3.35	108	104	2275954	
7	Haripur 412 MW CCPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 360MW CCPP(HPL)	EGCB	1*273+1*139	412	328	8123400	FGMO
9	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	340	7990000	
10	Meghnaghat 450 MW CCPP(MP)	IPP	2*150+1*150	450	300	7120500	Gas shortage
11	Meghnaghat 100 MW(EL)	QRPP	12*8.9	100	0	0	Contract Expired
12	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	230	6162327	FGMO
13	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3*17.06+1*11.3	55	55	1232461	
15	Keraniganj 100 MW PP (Powerpa	QRPP	8*13.45	100	40	372446	Low demand
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	321768	Engine problem
17	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	185	3321000	Gas shortage.
19	Siddhirganj 100 PP(Dutch Bangla	QRPP	12*8.9	100	95	1800000	Engine problem
20	Siddhirganj 335 MW CCPP	EGCB	1*217+1*18	335	211	4685847	ST under Maint.
21	Gagnagar 102 MW PP (Digital P	IPP	12*8.924	102	102	1063008	
22	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco E	IPP	3*18	54	35	687600	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	1577760	
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	782549	
26	Nababganj 55 MW PP (Southern	IPP	3*19.3	55	55	1157432	
27	Bosila 108MW PP(CLG)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
28	Summit Power (Madhabadi-Ashul	SIPP, REB	3*3.67+4*8.73	80	45	1027880	Engine problem
29	Madna 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	785300	
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	794900	
31	Gazipur 52 MW PP	IPP	6*8.9	52	41	960480	Engine problem
32	Tongi 80 MW GTTP	PDB	1* 105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	244	2137745	Low demand
34	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	81159	Reserve.
35	Bramhangonj 100 MW PP (Aga	IPP	100	100	0	0	Reserve.
36	Aurahai 100MW PP (Aggreko)	IPP	0.85*23+0.95*9.1	100	0	105418	Reserve.
37	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	149	3264480	
38	Gazipur 100 MW PP	RPCL	100 MW	105	88	1140000	Engine problem
39	Meghnaghat 104 MW PP (OPCL	IPP	18.5*5	104	74	1166400	Engine problem
40	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	2508490	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	249010	
Dhaka area Total				5919	3363	67277984	
42	Chattoqram TPP-1	PDB	1*210	180	0	0	Under maint.
43	Chattoqram TPP-2	PDB	1*210	180	0	0	Gas shortage
44	Razzan 25 MW PP	IPP	3*8.9	25	16	343663	Engine problem
45	Teknaf 20MW PP (Solar)Tknaf Solar	IPP	20	20	0	122040	
46	Palenga 50MW PP (Baraka)	IPP	8*6.98	50	50	480480	
47	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	25	600000	Low water level & Unit-2 unc
48	Sikalbaha 225MW	PDB	1*150+1*175	225	201	3091472	FGMO
49	Sikalbaha Peaking GT	PDB	1*150	150	110	2622440	
50	Sikalbaha 105 MW PP (Baraka S	IPP	105 MW	105	53	1482872	Engine problem
51	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
52	Dohazari -Kalaish 100 MW Peak	PDB	6*17	102	68	724805	Engine problem
53	Juldah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	86	1767480	Engine problem
54	Juldah 100 MW PP Unit-3 (Acom	IPP	0	100	100	2384640	
55	Barakunda 22 MW PP (Regent	SIPP, PDB	8*2.90	22	20	415008	
56	Matancho, Ctg. EPZ (United)	IPP	5*8.73+39.34	0	29	492000	
57	Chattoqram 108 MW PP (ECPV)	IPP	16*7	108	95	495360	Engine problem
58	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	35762	
59	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0	Reserve.
60	Jodiad Power	IPP	3*18.55+1*3.6	54	54	1199160	
61	Karnaphuli Power Ltd.	IPP	110	110	85	1431011	Low demand
62	Juldah unit-2 (Acom)	IPP	8*13.6	100	95	1988150	Engine problem
63	Anlima Energy Ltd.	IPP	6*21.2	116	116	2100109	
Chattoqram area Total				2382	1203	21776462	
64	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Gas Shortage
65	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
66	Ashuganj TPP Unit- 5	APSCL	1*150	134	100	1973546	Gas shortage
67	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	214	6905000	FGMO
68	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	260	6936000	FGMO
69	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	275	6748000	FGMO
70	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	590976	Engine problem
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	54	1264320	
72	Ashuganj 195MW PP (APSL-U)	IPP	20*37+1*16	195	16	317818	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1130373	Engine problem
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	150	2311709	
75	Tilas 50 MW Peaking PP	PDB	6*8.92	52	50	232704	
76	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	85	2105080	Machine problem
77	Chandpur 200MW (Desh energy	IPP	0	200	125	2903520	Engine problem
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	490246	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	167580	Engine problem
80	Impport (Tripura)	Imported power	0	160	174	3672960	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	564600	
82	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	1045738	
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	14	397680	Engine problem
84	Daudkandi 200 MW PP (B.Trac)	IPP	15*11.4	200	208	1971072	
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	34	679440	Low demand
86	Chowmuhan 113 MW	IPP	12*9.78+2*3.1	113	120	2535960	
87	Bhairab 54.5 MW	IPP	3*18.2	54	35	875160	33 kV feeder fault.
Cumilla Area Total				3032	2105	43715684	
88	RPCL 210MW CCPP	IPP	4*35+1*70	202	153	3853680	Gas shortage
89	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	17	198072	Engine problem
90	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	63	1455360	Engine problem
91	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	16250	
92	Mymensingh 200 MW PP (Unit	IPP	200	200	182	1812000	Engine problem
93	Jamalpur 115 MW PP (United)	IPP	115 MW	115	107	2659200	Engine problem
94	Sutakhirali 50 MW Solar PP	IPP	50	0	0	365680	
95	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	288000	
Mymensingh Area Total				709	546	10688242	
96	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	42	1003000	Machine problem
97	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	0	22080	Machine problem
98	Kushihara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3379745	
99	Shahjibazar 330 MW CCPP	PDB	3*110	330	331	6905000	
100	Fenchugonj 51 MW PP (Barakat	RPP	19*2.90	51	44	1114200	
101	Fenchugonj 44MW (Energyprima	RPP	12*3.5+5*2	0	0	0	Contract Expired
102	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	255000	
103	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	57	1273536	Engine problem
104	Shahjibazar 86MW PP (Shahjiba	RPP	32*2.90	86	76	1766400	Engine problem
105	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under Shut down
106	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	140	1629110	
107	Sylhet 20 MW PP	PDB	1*20	20	17	395000	Machine problem
108	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
109	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	356020	Engine problem
110	Bibiana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	280	7290000	FGMO
111	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	354	6793000	FGMO
112	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	7	152100	Engine problem
113	Bibiyana South 400 MW	PDB	400 MW	383	390	8458400	FGMO
Sylhet Area Total				2377	1928	42711591	
114	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	
115	Bheramara (HVC)	Imported power	2*1500	1000	916	22138909	
116	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	83	1845120	Engine problem
117	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	10	68160	Engine problem
118	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
119	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	10496	Reserve.
120	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	350	1016560	FGMO
121	Noapara 40 MW PP (Khanjashar	QRPP	5*1.5	40	32	462000	Engine problem
122	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	100	737280	
123	Rupsha 105 MW PP (Orion rupsa	IPP	6*18.445	105	105	1788000	
124	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1596	36156525	
125	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	1681536	
126	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	34	703170	
127	Bhola 225 MW CCPP	PDB	2*63+1*68	194	85	2079998	Engine problem
128	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	95	2190470	
129	Payra 1320 MW	BCPCL	2*622	1244	550	12050600	
130	Bhola Nutan Biddut BD LTD	IPP	220	0	0	574582	On Test
131	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	93	1098000	Low demand
Barisal Area Total				1826	967	20832356	
132	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
133	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
134	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	339382	
135	Bera 70 MW Peaking PP	PDB	9*8.29	71	23	123129	
136	Annura 50 MW PP(Sinha)	QRPP	7*7.79	50	42	215710	Engine problem
137	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	34	170581	Engine