

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2021				Day : Sunday		Date : 23.05.21									
Probable Maximum Demand : 14500 MW				Probable Maximum Generation : 15861 MW				Rule Curve = 77.80 ft.							
Water Level of Kapital Lake at 06:00 AM				Yesterday = 74.44 ft.		Today = 74.23 ft.									
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.05.21 (Yesterday)		23.05.21 (Today)		22.05.21 (Yesterday)		23.05.21 (Today)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Day	Evening	Day	Evening		
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0		260		Under maint.		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under Repowering		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Under maint.		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	96	104	100	102						
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		CB Problem		
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20		Under Maint.		
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	300	340	360	360						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150			Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling		
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	330	328	350	360						
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	120	185	120	185	25			Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	204	211	220	220		124		ST under maint.		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	70	95	100	100						
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	260	230	300	300						
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	0	0						
16	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	55	55	55						
17	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	40	100	100						
18	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	102	102	102						
19	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	14	19	20	20						
20	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	44	45	45	45						
21	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33						
22	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33						
23	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	41	41	41						
24	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	30	88	105	105						
25	Kodda 150MW PP	HFO (8PDB-RPCL)	9x17.06	149	149	48	150	150	150						
26	Kalpott 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0						
27	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35						
28	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	30	244	245	245						
29	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	138	149	149	149						
30	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300						
31	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100						
32	Aurash 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100						
33	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	35	35						
34	Maniganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55						
35	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0						
36	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	71	74	72	72						
37	Maniganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	105	162	162	162						
38	Maniganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	34	0	30	0						
Dhaka Zone Total				6076	5919	2693	3363	3707	4054	175	1169				
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205			Low Water Level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	6	0	5	0	0						
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	9	16	17	17						
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0						
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	50	50	50						
45	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	53	53	70	90						
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	110	110	110	110						
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	41	201	210	215						
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300						
49	Juddah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	80	86	100	100						
50	Juddah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100						
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68						
52	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0						
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	20	20						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	29	10	25						
	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	95	100	100						
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54						
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	64	85	110	110						
57	Juddah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	95	100	100						
58	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	76	116	116	116						
Chattogram Zone Total				2442	2382	767	1203	1585	1600	205	360				
59	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135			Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	80	100	80	100	34			Gas Shortage		
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	26	26						
61	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1775	221	221	211	214	215	215						
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	275	275	330	330						
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	350	260	330	330						
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	48	54	55	55						
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	16	16	8	8	179			Gas shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51						
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	118	150	150	150						
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50						
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	88	85	90	90	78			Gas Shortage		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	121	125	125	125						
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	22	22						
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11						
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33						
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	52	52	52						
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	14	20	20						
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86'1.4+86'1.515+15x1.058	200	200	0	208	100	200						
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	34	114	114						
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	113	120	113	113						
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	36						
**	Impoort (Tripura)	India		160	160	142	174	156	190						
Cumilla Zone Total				3094	3034	1748	2105	2116	2321	555	0				
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	148	153	160	160						
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	17	19	19						
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	56	63	64	64						
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	105	107	115	115						
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	182	200	200						
85	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	56	0	50	0						
87	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	0	24	22	22						

No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.05.21 (Yesterday)		23.05.21 (Today)		22.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	42	42		28	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	22	22		90	Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	44	44	44				
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	57	57	57				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	158	331	330	330				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	70	76	76	76				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	140	140	140				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	6	7	7	7				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	280	341	341				
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	369	354	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	390	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total				2422	2377	1632	1928	2067	2067	0	118		
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	400	350	410	410				
106	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	10	20	20				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	7	0	60	60				
108	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	74	83	99	99				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	32	32	32				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	105	105	105				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	917	916	928	928				
Khulna Zone Total				2288	2284	1433	1596	1804	2074	0	0		
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	110	110				
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	25	34	33	33				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	85	88	88		109	GT-2 & STG Under maint.	
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	94	95	95	95				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	430	550	622	622				
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	93	0	110				
Bhola Nutan Biddut BD LTD				Gas/HSD (IPP)		34	0	50	50				
Barishal Zone Total				1826	1826	679	967	998	1108	0	109		
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	23	40	40				
124	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	42	40	42				
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	98	100	100				
126	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	30				
127	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	43	43				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35				
129	Siragajonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	119	98	125	125	52		Gas Shortage	
130	Siragajonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	195	181	200	200				
131	Siragajonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	182	190	200	200				
132	Siragajonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	343	357	400	400				
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	14	20	20	20				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	10	113	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	47	112	113	113				
138	Siragajonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total				2179	2179	972	1446	1743	1774	223	0		
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	113	113	113				
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
144	Majpara, Tutula 8 MW Solar PP (Sypsa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
Rangpur Zone Total				685	605	270	263	271	283	294	0		
Sub-total: Plants in operation				21729	21315	10561.0	13417	14923	15861	1452	1756		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							10004	12710	14136	15025			
(B) Plants under long term maintenance/ contract expired													
145	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
147	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
148	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired				294	0	0	0	0	0				
Gross Total				22023	21315	10561	13417	14923	15861	1452	1756		
(C) Actual data of 22.05.21 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	13417.00	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12710.00	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13417.00	MW, at =	21:00 hrs	Dhaka	4259	4259	0	Mymensingh	1046	1046	0
04.	Minimum Generation (Generation end)	:	9349.00	MW, at =	8:00 hrs	Chattogram	1308	1308	0	Sylhet	566	566	0
05.	Day-peak Generation (Generation end)	:	10561.00	MW, at =	12:00 hrs	Khulna	1656	1656	0	Barishal	427	427	0
06.	Evening-peak Generation (Generation end)	:	13417.00	MW, at =	21:00 hrs	Rajshahi	1346	1346	0	Rangpur	777	777	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Cumilla	1325	1325	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10560.00	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	953	MW		13.	Fuel cost :	(a) Gas = 167483623 Taka	(c) Coal = 74786106 Taka				
	d) Coal supply Limitation	:	294	MW			(b) Oil = 560665443 Taka	Total = 802935172 Taka					
	b) Low water level in Kapitai lake	:	205	MW									
	c) Plants under shut down/ maintenance	:	1756	MW		14.	Maximum Temperature in Dhaka was :	37.3° C					
10.	Total Energy (Generation - India Import)	:	274.94	MKWh		15.	Export through East-West interconnections :						
	By Gas = 156.865 MKWh			By Oil = 74.624 MKWh			At evening peak-hour	: -175 MW, at 21:00 hrs					
	By Coal = 16.175 MKWh			By Hydro = 0.600 MKWh			Maximum	: -175 MW, at 21:00 hrs					
	By Solar= 0.863 MKWh						Energy	: 0.5325 MKWh					
11.	Total Gas Supplied	:	1314.71	MMCFD									
(D) Forecast of 23.05.21 (Today) Sunday :													
01.	Maximum Demand	:	14500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15861	MW	(Generation end)	05.	Total Generation	:	297.13	MKWh			
03.	Maximum Shortage	:	-1361	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	38.4° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faazul Islam Shaker)
Deputy Secretary, Generation