

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : **24-May-21**

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity		Peak Generation		Energy Generated	Remarks
				Unit No. X Capacity	MW	MW	KWH		
1	Ghorasal Repowered CCGP Unit-1	PDB	1260	260	0	0	0	Under maint.	
2	Ghorasal Repowered CCGP Unit-2	PDB	1210	180	0	0	0	Under maint.	
3	Ghorasal TPP Unit-5	PDB	1210	190	180	415800	0		
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	0	Under maint.	
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	0	Contract Expired	
6	Ghorasal 108MW PP (Regent)	IPP	343.35	108	100	2015636	0		
7	Haripur GTPP	SBU, PDB	232	20	0	0	0	Under maint.	
8	Haripur 412 MW CCGP	EGCB	1273+1139	412	329	8511490	0	Machine problem	
9	Haripur 360MW CCGP(HPL)	IPP	1235+1125	360	176	5944000	0	Gas shortage	
10	Meghnaghat 450 MW CCGP(MP)	IPP	2150+1150	450	300	7120750	0	Gas shortage	
11	Meghnaghat 100 MW(EL)	QRPP	128.9	100	0	0	0	Contract Expired	
12	Meghnaghat CCGP(Summit)	IPP	2110+1110	305	275	6336622	0	FGMO	
13	Madanganj 102 PP(Summit)	QRPP	617	0	0	0	0	Contract Expired	
14	Madanganj-55 MW PP(Summit)	(IPP)	317.08+111.3	55	55	1267427	0		
15	Keraniganj 100 MW PP (Powerpa)	QRPP	813.45	100	86	1138815	0	Engine problem	
16	210 MW Siddhirganj TPP	PDB	1210	115	0	0	0	Engine problem	
17	Siddhirganj 2120 MW GTPP	EGCB	2105	210	150	3532000	0	Under maint.	
18	Siddhirganj 100 PP(Dutch Bangla)	QRPP	128.9	100	100	2214710	0	FGMO	
19	Siddhirganj 335 MW CCGP	EGCB	1217+118	335	214	4756402	0	ST Under Maint.	
20	Gagnagar 102 MW PP (Digital Pt)	IPP	128.924	102	102	1906416	0		
21	Katpott 52 MW PP (Sinha)	IPP	77.9	51	0	0	0	Fuel shortage	
22	Kamatnagar 54 MW PP(Banco E)	IPP	319	54	35	711000	0	Engine problem	
23	Kodda 150MW PP	BFDB-RPCL	917.06	149	149	3137280	0		
24	Manikganj 55 MW PP (Northern)	IPP	319.3	55	35	789008	0	Engine problem	
25	Nabaganj 55 MW PP (Southern)	IPP	319.3	55	55	1162833	0		
26	Bosila 108MW PP(CLG)	IPP	128.775+113.5	108	0	0	0	Fuel shortage	
27	Summit Power, (Madhabdi+Ashul)	SIPP, REB	33.674+87.3	80	37	944340	0	Engine problem	
28	Madona 33 MW PP(Summit)	SIPP, REB	48.73	33	33	750600	0		
29	Ruganaj 33 MW PP(Summit)	SIPP, REB	48.73	33	33	708800	0		
30	Gazipur 52 MW PP	IPP	68.9	52	41	881760	0	Engine problem	
31	Tongi 80 MW GTPP	PDB	1105	105	0	0	0	Under maint.	
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	245	4767271	0	Engine problem	
33	Keraniganj 300 MW PP (AFR)	IPP	2581.4	300	105	1504511	0	Engine problem	
34	Bramhanganj 100 MW PP (Agg)	IPP	100	100	82	467916	0	Low demand	
35	Auraha 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	100	805180	0		
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3482640	0		
37	Gazipur 100 MW PP	RPCL	100 MW	105	86	1889976	0	Engine problem	
38	Meghnaghat 104 MW PP (OPCL)	IPP	185.75	104	95	2112000	0	Engine problem	
39	Manikganj 162MW PP(MPCL)	IPP	918	162	144	3405600	0	Engine problem	
40	Spectra Solar Plant Ltd.	IPP	35	35	0	213349	0		
Dhaka area Total				5919	3510	7697428			
41	Chattoagram TPP-1	PDB	1210	180	0	0	0	Under maint.	
42	Chattoagram TPP-2	PDB	1210	180	0	0	0	Gas shortage	
43	Raazan 25 MW PP	IPP	38.9	25	0	33518	0	Engine problem	
44	Teknaf 20MW PP (Solar) (Khatun Solartech Energy)	IPP	20	20	0	27540	0		
45	Patenga 50MW PP (Baraka)	IPP	86.98	50	46	694800	0		
46	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	240+350	230	25	580000	0	Low water level & Unit-2 unc	
47	Sikalbaha 225MW	PDB	1150+1175	225	71	4816254	0	Synchronized at 15:35.	
48	Sikalbaha Peaking GT	PDB	1150	150	0	1518189	0	Tripped at 15:50.	
49	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	0	459163	0	Tripped at 15:50.	
50	Hathazari 100 MW peaking PP	PDB	118.9	98	0	0	0	Under S/D	
51	Dohazari-Kalaish 100 MW Peak	PDB	617	102	42	444683	0	Low demand	
52	Juidah 100 MW Unit-1 (Acom)	QRPP	813.45	100	76	1653480	0	Engine problem	
53	Juidah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	1890240	0		
54	Barakunda 22 MW PP (Regent)	SIPP, PDB	0	22	0	410592	0		
55	Malancha, Cg. EZZ	IPP	518.72+19.34	0	10	362880	0		
56	Chattoagram 108 MW PP (ECPV)	IPP	67	108	97	910080	0		
57	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	37680	0		
58	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	153	1523016	0	Low demand	
59	Jodiak Power	IPP	318.55+13.6	54	54	692221	0		
60	Karnaphuli Power Ltd.	IPP	110	110	34	441598	0	Low demand	
61	Juidah unit-2 (Acom)	IPP	813.6	100	80	1752860	0	Low demand	
62	Anlima Energy Ltd.	IPP	621.2	116	110	1014927	0		
Chattoagram area Total				2382	898	19563103			
63	Ashuganj TPP Unit-3	APSCL	1150	135	0	0	0	Gas Shortage	
64	Ashuganj TPP Unit-4	APSCL	1150	129	0	0	0	Gas shortage	
65	Ashuganj TPP Unit-5	APSCL	1150	134	0	0	0	Gas shortage	
66	Ashuganj 225 MW CCGP	APSCL	1142+175	221	145	3511000	0		
67	Ashuganj 450 MW CCGP(North)	APSCL	1360	360	235	4423500	0		
68	Ashuganj 450 MW CCGP(South)	APSCL	1360	360	295	7152000	0	FGMO	
69	Ashuganj 50 MW PP	APSCL	143.968	45	10	504000	0	Engine problem	
70	Ashuganj 55 MW PP (Precision)	RPP	154	55	10	756960	0		
71	Ashuganj 150MW PP (APSC-U)	IPP	2073+1116	195	16	1421618	0	Gas shortage	
72	Ashuganj 51 MW PP (Midland)	IPP	69.34	51	5	948766	0		
73	Ashuganj 150MW PP (Midland)	IPP	237.015	150	0	1532218	0	Tripped at 15:50.	
74	Tilas 50 MW Peaking PP	PDB	68.92	52	0	108576	0	Reserve.	
75	Chandpur 150 MW CCGP	PDB	1106+157	163	90	2126210	0	Machine problem	
76	Chandpur 200MW (Desh energy)	IPP	0	200	103	2209920	0	Engine problem	
77	Feni 22MW PP (Doreen)	SIPP, PDB	87.90	22	0	375912	0	Tripped at 15:50.	
78	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	0	135360	0	Tripped at 15:50.	
79	Impoort (Tripura)	Imported power	0	160	102	3399360	0		
80	Jangalia 33MW PP (Summit)	SIPP, PDB	48.73	33	33	743400	0		
81	Jangalia 52 MW PP (Lakdanavi)	IPP	68.92	52	52	1128475	0		
82	Cumilla 25 MW PP (Summit)	SIPP, PDB	33.67+216.97	25	15	353190	0	Engine problem	
83	Daudkandi 200 MW PP (B.Trac)	IPP	15411.6	200	100	1294480	0	Low demand	
84	Feni Lanka Power	IPP	718.415+19.78	114	114	1557240	0		
85	Chowmuhani 113 MW	IPP	129.78+23.1	113	110	2522520	0		
86	Bhairab 54.5 MW	IPP	318.2	54	17	591480	0	33 kV feeder fault.	
Cumilla Area Total				3034	1452	36782353			
87	RPCL 210MW CCGP	IPP	435+1170	202	151	3071280	0	Gas shortage	
88	Tangail 22 MW PP (Doreen)	SIPP, PDB	87.90	22	19	385344	0	Engine problem	
89	Jamalpur 95 MW PP(Powerpac)	IPP	128.924	95	63	1362240	0	Engine problem	
90	Sarishabari 3 MW Solar Plant	IPP	13	3	0	15150	0		
91	Mymensingh 200 MW PP (Unite)	IPP	200	190	190	3242400	0		
92	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	115	2611200	0		
93	Sutakhirali 50 MW Solar	IPP	50	50	0	368840	0		
94	Tangail Palli Power Gen 22 MW	IPP	46.7	22	24	546720	0		
Mymensingh Area Total				709	562	11603174			
95	Fenchugonj CCGP Phase-1	PDB	232+133	70	42	999000	0	Machine problem	
96	Fenchugonj CCGP Phase-2	PDB	235+135	90	30	699720	0	Machine problem	
97	Kushkhara 163 MW CCGP (KP)	IPP	1109+154	163	130	3502064	0	Frequency control	
98	Shahjibazar 330 MW CCGP	PDB	3110	330	328	7250000	0		
99	Fenchugonj 51 MW PP (Barakat)	RPP	192.90	51	50	1111800	0		
100	Fenchugonj 44MW (Energyprima)	RPP	1213.3+52	0	0	0	0	Contract Expired	
101	Hobiganj 11MW PP Confidence-E	SIPP, REB	42.90	11	11	230000	0		
102	Shahjibazar GTPP Unit-8 & 9	PDB	235	66	56	1184928	0	Engine problem	
103	Shahjibazar 80MW PP (Shahjiba)	RPP	322.90	86	77	1704960	0	Engine problem	
104	Shahjibazar 100 MW GTPP	PDB	1100	100	0	0	0	Under Shut down	
105	Sylhet 225 MW CCGP	PDB	1142+1189	231	120	2893770	0	Machine problem	
106	Sylhet 20 MW GTPP	PDB	120	20	17	209000	0		
107	Sylhet 50MW PP (EPL)	RPP	272	0	0	0	0	Contract Expired	
108	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	16	347424	0	Engine problem	
109	Bibiana-II 341 MW CCGP (Summit)	IPP	1122+1119	341	310	1703950	0	FGMO	
110	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	403	6862000	0	FGMO	
111	Sylhet 10MW PP (Desh)	RPP	61.95	10	0	143280	0	Engine problem	
112	Bibiyana South 400 MW	PDB	400 MW	383	394	9030900	0	FGMO	
Sylhet Area Total				2377	1984	45284346			
113	Bheramara GTPP Unit-3	PDB	120	16	0	0	0		
114	Bheramara (NWDCL)	Imported power	21500	1000	827	2114565	0		
115	Khulna 115 PP MW (KPCL-2)	QRPP	717	115	99	2167680	0	Engine problem	
116	Fariapur 50 MW Peaking PP	PDB	68.98	54	17	148800	0	Engine problem	
117	Khulna 225 MW CCGP	NWPGCL	1150+1175	230	0	0	0	Reserve.	
118	Gopalganj 100 MW Peaking PP	PDB	166.98	109	0	11264	0	Reserve.	
119	Bheramara 410 MW CCGP	NWPGCL	1278+1132	410	365	6927264	0	FGMO	
120	Noapara 40 MW CCGP (Karnahar)	QRPP	51.15	40	32	451500	0	Engine problem	
121	Noapara 100 MW PP (Bangla Tr)	IPP	70.14	100	100	743040	0		
122	Rupsha 105 MW PP (Orion rupsa)	IPP	618.445	105	105	2480160	0		
123	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	0	Reserve.	
Khulna Area Total				2284	1545	34075163			
124	Bansail 110 MW PP (Summit)	IPP	717.076	110	110	1316160	0		
125	Bhola 33 MW PP (Venture)	RPP	134.50	33	34	694050	0		
126	Bhola 225 MW CCGP	PDB	263+1168	194	86	1909309	0	Engine problem	
127	Bhola 95 MW PP (Aggreko)	QRPP	961.10	95	76	1913567	0	Engine problem	
128	Payra 1320 MW	BCPCL	2622	1244	550	13153800	0		
129	Bhola Nutan Biddut BD LTD	IPP	220	0	165	917073	0	On Test	
130	Uniled Payra Power Ltd.	IPP	618.5+19.5	150	54	302400	0	Line over load.	
Barisal Area Total				1826	1075	20206399			
131	Baghabari 71 MW GTPP	PDB	171	71	0	0	0	Gas shortage	
132	Baghabari 100 MW GTPP	PDB	1100	100	0	0	0	Gas shortage.	
133	Baghabari 50 MW Peaking PP	PDB	68.9	52	31	434114	0		
134	Bera 70 MW Peaking PP	PDB	98.29	71	45	399597	0		
135	Amura 50 MW PP(Sinha)	QRPP	77.79	50	42	593560	0	Engine problem	
136	Katakhal 50 MW PP (Northern)	QRPP	68.9	50	34	244211	0	Low demand	
137	Katakhal 50 MW Peaking PP	PDB	68.7	50	30	320029	0	Engine problem	
138	Sirajgonj Unit-1 225MW	NWPGCL	1150+1175	210	142	2793900	0	Gas shortage	
139	Sirajgonj Unit-2 225MW	NWPGCL	1150+1175	220	132	3689745	0	FGMO	
140	Sirajgonj Unit-3 225MW	NWPGCL	1141	220	172	4466990	0	FGMO	
141	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1						