

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2021				Day : Tuesday				Date : 25.05.21						
Probable Maximum Demand : 11800 MW				Probable Maximum Generation : 16053 MW				Rule Curve = 77.40 ft.						
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.99 ft		Today = 73.75 ft.		24.05.21 (Yesterday)		25.05.21 (Today)		24.05.21 (Yesterday)		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)		Status of Machines under shut-down/ Maintenance	Probable start-up date
					Day	Evening	Day	Evening	Day	Evening				
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0		260		Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under Repowering	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	90	100	100	102					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		CB Problem	
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20		Under Maint.	
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	201	176	360	360					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150			Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	337	329	360	390					
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	180	150	180	185	60			Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	208	214	220	220		121		ST under maint.	
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100					
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	265	275	300	300					
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	0	0					
16	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55					
17	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	41	86	85	85					
18	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	75	102	102	102					
19	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	20	20					
20	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	37	45	45					
21	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
22	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
23	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	41	41	41					
24	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	86	105	105					
25	Kodda 150MW PP	HFO (BPDG-RPCL)	9x17.06	149	149	150	149	150	150					
26	Katpott 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0					
27	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35					
28	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	200	245	245	245					
29	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149					
30	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	105	100	300					
31	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	82	100	100					
32	Aurshali 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	50	100					
33	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
34	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	55	55					
35	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
36	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	95	95	72	72					
37	Manikganj 162MW PP(MPLG)	HFO (IPP)	9x18	162	162	144	144	162	162					
38	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	27	0	30	0					
Dhaka Zone Total				6076	5919	3173	3510	3822	4079	210	1166			
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205			Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0	0					
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	0	17	17					
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	47	46	50	50					
45	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	0	0	70	90					
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	0	110	110					
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	71	220	220					
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	162	153	300	300					
49	Juddah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	80	76	100	100					
50	Juddah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100					
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	42	68	68					
52	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0					
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	0	20	20					
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	10	10	25					
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	60	97	100	100					
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	54	54					
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	34	110	110					
57	Juddah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	80	100	100					
58	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	110	116	116					
Chattogram Zone Total				2442	2382	934	898	1595	1605	205	360			
59	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135			Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	80	100	134			Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	10	26	26					
61	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1775	221	221	211	145	215	215					
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	295	295	330	330					
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	230	235	360	360					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	30	10	55	55					
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	83	16	45	45	179			Gas shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	5	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	92	0	150	150					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	90	90	90	73			Gas Shortage	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	103	125	125					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	0	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	0	11	11					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	15	20	20					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86'14+86'15+15x1.058	200	200	0	100	100	200					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	98	114	114	114					
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	116	110	113	113					
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	5	17	35	36					
**	Impoport (Tripura)	India		160	160	166	102	145	181					
Cumilla Zone Total				3094	3034	1716	1452	2172	2379	650	0			
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	150	151	160	160	51			Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19					
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	55	63	64	64					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115					
84	Myemsensing 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	88	190	200	200					
85	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	27	0							

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.05.21 (Yesterday)		25.05.21 (Today)		24.05.21 (Yesterday)		25.05.21 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW					
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	42	42			28		Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30			60		Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	46	50	44						
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163						
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11						
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	56	57						
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	320	328	163			330			
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x90	86	86	73	77	76						
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	120	120	140			140			
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	18						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	6	0	7						
99	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16						
100	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	310	341						
101	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	403	400			400			
102	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	385	394	400			400			
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0						
Sylhet Zone Total					2422	2377	1988	1984	1908	2075	0	88		
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0						
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	295	365	410			45		Gas Shortage	
106	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	3	17	20						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60			60			
108	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0			220			
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	90	99	99			99			
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50			100			
111	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	32	32			32			
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	70	105	105			105			
113	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100			100			
**	Bheramara (HVDC)	India		1000	1000	892	827	909			909			
Khulna Zone Total					2288	2284	1350	1545	1785	2055	45	0		
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110						
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	23	34	33						
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	84	86	88			108		GT-2 & STG Under	
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	92	76	95			95			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	520	550	622			622			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	3	54	0			110			
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	165	110			165			
Barishal Zone Total					1826	1826	722	1075	1058	1223	0	108		
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0			71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0			100		Gas Shortage	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	31	50			50			
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200			200			
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	7	45	40			40			
124	Amura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	12	42	40			42			
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	70	96	100			100			
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30			30			
127	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	43			43			
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	14	0			35			
129	Siragajon 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	107	142	125			125			
130	Siragajon 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	136	132	200			200		Gas Shortage	
131	Siragajon 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	172	172	200			200		Gas Shortage	
132	Siragajon 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	401	0	400			400			
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	20	20			20			
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11			11			
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	52	52			52			
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	113	113	113			113			
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	112	113	113			113			
138	Siragajon 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6			0			
Rajshahi Zone Total					2179	2179	1204	1047	1743	1774	307	0		
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0			85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0			85		Coal Shortage	
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	149	150	150			124		Coal Shortage	
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	17	0			10			
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	112	113	113			113			
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0			10			
144	Maipara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8			0			
Rangpur Zone Total					685	685	268	280	271	283	294	0		
Sub-total: Plants in operation					21729	21315	11835.0	12353	14986	16053	1762	1722		
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss							11238	11730	14230	15243				
(B) Plants under long term maintenance/ contract expired														
145	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0					Contract Expired on 08/01/2021	
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0						
147	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0					Contract Expired on 14/02/2021	
148	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0					Contract Expired on 04/01/2020	
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0					Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired							294	0	0	0	0			
Gross Total					22023	21315	11835	12353	14986	16053	1762	1722		
(C) Actual data of 24.05.21 (Yesterday) Monday :														
01.	Max. Demand at eve. peak (Generation end)	:	12353.00	MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11730.00	MW, at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	13012.00	MW, at =	1:00 hrs		MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	:	10785.00	MW, at =	8:00 hrs	Dhaka	4695	4695	0	Mymensingh	1047	1047	0	
05.	Day-peak Generation (Generation end)	:	11835.00	MW, at =	12:00 hrs	Chattogram	949	949	0	Sylhet	310	310	0	
06.	Evening-peak Generation (Generation end)	:	12353.00	MW, at =	19:30 hrs	Khulna	1530	1530	0	Barishal	404	404	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	19:30 hrs	Rajshahi	1152	1152	0	Rangpur	679	679	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7904.00	MW, at =	5:00 hrs	Cumilla	964	964	0					
09.	Generation shortfall at evening peak due to :	:								Total	11730	11730	0	
	a) Gas limitation	:	1263	MW		13.	Fuel cost :	(a) Gas = 157458025 Taka	(c) Coal = 77625742 Taka					
	d) Coal supply Limitation	:	294	MW			(b) Oil = 697534734 Taka	Total = 932618501 Taka						
	b) Low water level in Kaptai lake	:	205	MW										
	c) Plants under shut down/ maintenance	:	1722	MW		14.	Maximum Temperature in Dhaka was :	38.1° C						
10.	Total Energy (Generation + India Import)	:	279.68	MWWh		15.	Export through East-West interconnections :							
	By Gas = 1.47/833 MKWH	By Oil =	89.168	MWWh			At evening peak-hour	: -154 MW, at	19:30 hrs					
	By Coal = 16.822 MKWH	By Hydro =	0.580	MWWh			Maximum	: -438 MW, at	22:00 hrs					
	By Solar= 0.737 MKWH						Energy	: 0.739 MKWh						
11.	Total Gas Supplied	:	1187.87	MMCFD										
(D) Forecast of 25.05.21 (Today) Tuesday :														
01.	Maximum Demand	:	11800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	16053	MW	(Generation end)	05.	Total Generation	:	253.63	MWWh				
03.	Maximum Shortage	:	-4253	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.6° C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation