

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 25-May-21

Page -2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present | Peak | Energy | Remarks |
|------------------------------|--|----------------|---------------------|-------------|-------------|-----------------|------------------------------|
| | | | | Capacity | Hour | Generated | |
| | | | Unit No. X Capacity | MW | MW | KWH | |
| 1 | Ghorasal Repowered CCGP Unit-1 | PDB | 1'260 | 260 | 0 | 0 | Under maint. |
| 2 | Ghorasal Repowered CCGP Unit-2 | PDB | 1'210 | 180 | 0 | 0 | Under maint. |
| 3 | Ghorasal TPP Unit-5 | PDB | 1'210 | 190 | 170 | 4095000 | |
| 4 | Ghorasal 365 MW CCGP Unit-7 | PDB | 1'243+1'122 | 365 | 0 | 0 | Under maint. |
| 5 | Ghorasal 78.5 MW PP(MAX) | QRPP | 2'40 | 0 | 0 | 0 | Contract Expired |
| 6 | Ghorasal 108MW PP (Regen) | IPP | 34'3.35 | 108 | 102 | 2217409 | |
| 7 | Haripur GTTP | SBU_PDB | 2'32 | 20 | 0 | 0 | Under maint. |
| 8 | Haripur 412 MW CCGP | EGCB | 1'273+1'139 | 412 | 326 | 7956480 | FGMO |
| 9 | Haripur 360MW CCGP(HPL) | IPP | 1'235+1'125 | 360 | 161 | 5684000 | Gas shortage |
| 10 | Meghnaghat 450 MW CCGP(MP) | IPP | 2'150+1'150 | 450 | 300 | 7125500 | Gas shortage |
| 11 | Meghnaghat 100 MW (EL) | QRPP | 12'8.9 | 100 | 0 | 0 | Contract Expired |
| 12 | Meghnaghat CCGP(Summit) | IPP | 2'110+1'110 | 305 | 264 | 6462080 | FGMO |
| 13 | Madanganj 102 PP(Summit) | QRPP | 6'17 | 0 | 0 | 0 | Contract Expired |
| 14 | Madanganj-55 MW PP(Summit) | (IPP) | 3'17.08+1'11.3 | 55 | 55 | 873905 | |
| 15 | Keraniganj 100 MW PP (Powerpa) | QRPP | 8'13.45 | 100 | 40 | 61403 | Low demand |
| 16 | Narsingdi 22 MW PP (Doreen) | SIPP, REB | 8'2.90 | 22 | 0 | 203688 | Engine problem |
| 17 | 210 MW Siddhirganj TPP | PDB | 1'210 | 115 | 0 | 0 | Under maint. |
| 18 | Siddhirganj 2'120 MW GTTP | EGCB | 2'105 | 210 | 153 | 2829000 | FGMO |
| 19 | Siddhirganj 100 PP(Dutch Bangla) | QRPP | 12'8.9 | 100 | 100 | 1359024 | |
| 20 | Siddhirganj 335 MW CCGP | EGCB | 1'217+1'118 | 335 | 219 | 5155348 | ST Under Maint. |
| 21 | Gagnagar 102 MW PP (Digital Pt) | IPP | 12'8.924 | 102 | 92 | 1212624 | Engine problem |
| 22 | Katpotti 52 MW PP (Sinha) | IPP | 7'7.9 | 51 | 0 | 0 | Fuel shortage |
| 23 | Kamatnagar 54 MW PP(Banco E) | IPP | 3'18 | 54 | 35 | 527040 | Engine problem |
| 24 | Kodda 150MW PP | BPDB-RPCL | 9'17.06 | 149 | 150 | 2068800 | |
| 25 | Manikganj 55 MW PP (Northern) | IPP | 3'19.3 | 55 | 55 | 627958 | |
| 26 | Nababganj 55 MW PP (Southern) | IPP | 3'19.3 | 55 | 55 | 829520 | |
| 27 | Bosila 108MW PP(CLC) | IPP | 12'8.775+1'3.5 | 108 | 0 | 0 | Fuel shortage |
| 28 | Summit Power, (Madhabdi+Ashul) | SIPP, REB | 3'3.67+4'8.73 | 80 | 38 | 945240 | Engine problem |
| 29 | Machna 33 MW PP(Summit) | SIPP, REB | 4'8.73 | 33 | 33 | 781500 | |
| 30 | Ruganj 33 MW PP(Summit) | SIPP, REB | 4'8.73 | 33 | 33 | 699900 | |
| 31 | Gazipur 52 MW PP | IPP | 6'8.9 | 52 | 42 | 462240 | Engine problem |
| 32 | Tongi 80 MW GTTP | PDB | 1'105 | 105 | 0 | 0 | Under maint. |
| 33 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 18'17.076 | 300 | 268 | 3146399 | Engine problem |
| 34 | Keraniganj 300 MW PP (AFR) | IPP | 25'11.4 | 300 | 0 | 0 | Reserve. |
| 35 | Bramhangonj 100 MW PP (Agg) | IPP | 100 | 100 | 0 | 0 | Reserve. |
| 36 | Auraha 100MW PP (Aggreko) | IPP | 0.85'23+0.95'91 | 100 | 0 | 0 | Reserve. |
| 37 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 149 | 149 | 149 | 2799504 | |
| 38 | Gazipur 100 MW PP | RPCL | 100 MW | 105 | 105 | 1613448 | |
| 39 | Meghnaghat 104 MW PP (OPCL) | IPP | 18'5.75 | 104 | 94 | 1177920 | Engine problem |
| 40 | Manikganj 162MW PP(MPCL) | IPP | 9'18 | 162 | 144 | 1896480 | Engine problem |
| 41 | Spectra Solar Plant Ltd. | IPP | 35 | 35 | 0 | 162054 | |
| Dhaka area Total | | | | 5919 | 3183 | 62973194 | |
| 41 | Chattogram TPP-1 | PDB | 1'210 | 180 | 0 | 0 | Under maint. |
| 42 | Chattogram TPP-2 | PDB | 1'210 | 180 | 0 | 0 | Gas shortage |
| 43 | Raazan 25 MW PP | IPP | 3'8.9 | 25 | 17 | 401623 | Engine problem |
| 44 | Teknaf 20MW PP (Solar) (Khatun Solartech Energy) | IPP | 20 | 20 | 0 | 1880 | |
| 45 | Patenga 50MW PP (Baraka) | IPP | 8'6.98 | 50 | 43 | 844320 | Engine problem |
| 46 | Kaptai Hydro: Unit-1,2,3,4, 5 | PDB | 2'40+3'50 | 230 | 25 | 600000 | Low water level & Unit-2 unc |
| 47 | Sikalbaha 225MW | PDB | 1'150+1'175 | 225 | 204 | 4778949 | FGMO |
| 48 | Sikalbaha Peaking GT | PDB | 1'150 | 150 | 110 | 1099532 | |
| 49 | Sikalbaha 105 MW PP (Baraka S) | IPP | 105 MW | 105 | 53 | 127127 | Low demand |
| 50 | Hathazari 100 MW peaking PP | PDB | 1'18.9 | 98 | 0 | 0 | Under S/D |
| 51 | Dohazari-Kalaish 100 MW Peak | PDB | 6'17 | 102 | 68 | 495443 | Engine problem |
| 52 | Juidah 100 MW Unit-1 (Acorn) | QRPP | 8'13.45 | 100 | 85 | 1920240 | Engine problem |
| 53 | Juidah 100 MW PP Unit-3 (Acorn) | IPP | 0 | 100 | 40 | 1315200 | Low demand |
| 54 | Barakunda 22 MW PP (Regent + Malancho, Ctg. ETC) | SIPP, PDB | 5'8.72+3'9.34 | 22 | 22 | 511152 | |
| 55 | Chattogram 108 MW PP (ECPV) | IPP | 6'7 | 108 | 64 | 974400 | Low demand |
| 56 | Kaptai 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 39641 | |
| 57 | Anwara 300 MW PP (Uniled) | IPP | 300 MW | 300 | 0 | 0 | Reserve. |
| 58 | Jodiak Power | IPP | 3'18.55+1'3.6 | 54 | 54 | 1298946 | |
| 59 | Karnaphuli Power Ltd. | IPP | 110 | 110 | 51 | 281853 | Low demand |
| 60 | Juidah unit-2 (Acorn) | IPP | 8'13.6 | 100 | 20 | 888800 | Low demand |
| 61 | Anlima Energy Ltd. | IPP | 6'21.2 | 116 | 17 | 1149164 | Low demand |
| Chattogram area Total | | | | 2382 | 884 | 18286440 | |
| 61 | Ashuganj TPP Unit- 3 | APSCL | 1'150 | 135 | 0 | 0 | Gas Shortage |
| 62 | Ashuganj TPP Unit- 4 | APSCL | 1'150 | 129 | 70 | 178110 | Gas shortage |
| 63 | Ashuganj TPP Unit- 5 | APSCL | 1'150 | 134 | 0 | 0 | Gas shortage |
| 64 | Ashuganj 225 MW CCGP | APSCL | 1'142+1'75 | 221 | 172 | 4478000 | FGMO |
| 65 | Ashuganj 450 MW CCGP(North) | APSCL | 1'360 | 360 | 310 | 6622000 | FGMO |
| 66 | Ashuganj 450 MW CCGP(South) | APSCL | 1'360 | 360 | 270 | 7074000 | FGMO |
| 67 | Ashuganj 50 MW PP | APSCL | 14'3.968 | 45 | 26 | 542808 | Engine problem |
| 68 | Ashuganj 55 MW PP (Precision) | RPP | 15'4 | 55 | 20 | 929280 | Gas shortage |
| 69 | Ashuganj 195MW PP (APCL-U) | IPP | 20'37+1'16 | 195 | 8 | 719272 | Gas shortage |
| 70 | Ashuganj 51 MW PP (Midland) | IPP | 6'9.34 | 51 | 51 | 982732 | |
| 71 | Ashuganj 150MW PP (Midland) | IPP | 23'7.015 | 150 | 108 | 1560654 | Engine problem |
| 72 | Tilas 50 MW Peaking PP | PDB | 6'8.92 | 52 | 50 | 281368 | |
| 73 | Chandpur 150 MW CCGP | PDB | 1'106+1'57 | 163 | 87 | 2132390 | Machine problem |
| 74 | Chandpur 200MW (Desh energy) | IPP | 0 | 200 | 58 | 1412160 | Engine problem |
| 75 | Feni 22MW PP (Doreen) | SIPP, PDB | 8'2.60 | 22 | 21 | 465120 | |
| 76 | Feni 11 MW PP (Doreen) | SIPP, REB | 4'2.90 | 11 | 8 | 134460 | |
| 77 | Impport (Tripura) | Imported power | 0 | 160 | 162 | 3116160 | |
| 78 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4'8.73 | 33 | 0 | 624400 | Engine problem |
| 79 | Jangalia 52 MW PP (Lakdanavi) | IPP | 6'8.92 | 52 | 52 | 1070728 | |
| 80 | Cumilla 25 MW PP (Summit) | SIPP, PDB | 3'3.67+2'6.97 | 25 | 15 | 274760 | Engine problem |
| 81 | Cumilla 200 MW PP (B.Trac) | IPP | 15'41.4 | 200 | 0 | 0 | Reserve. |
| 82 | Feni Lanka Power | IPP | 7'18.415+1'9.78 | 114 | 114 | 1578900 | |
| 83 | Chowmuhani 113 MW | IPP | 12'9.78+2'3.1 | 113 | 119 | 2099160 | |
| 84 | Bhairab 54.5 MW | IPP | 3'18.2 | 54 | 35 | 681120 | 33 kV feeder fault. |
| Cumilla Area Total | | | | 3034 | 1786 | 36957572 | |
| 82 | RPCL 210MW CCGP | IPP | 4'35+1'70 | 202 | 151 | 3363850 | Gas shortage |
| 83 | Tangail 22 MW PP (Doreen) | SIPP, PDB | 8'2.90 | 22 | 0 | 31132 | Engine problem |
| 84 | Jamalpur 95 MW PP(Powerpac) | IPP | 12'8.924 | 95 | 24 | 819840 | Low demand |
| 85 | Sarishabari 3 MW Solar Plant | IPP | 1'3 | 3 | 0 | 9650 | |
| 86 | Mymensingh 200 MW PP (Unite) | IPP | 200 | 88 | 88 | 693600 | Low demand |
| 87 | Jamalpur 115 MW PP (Uniled) | IPP | 115 MW | 115 | 115 | 1844400 | |
| 88 | Sutakhir 50 MW Solar | IPP | 50 | 50 | 0 | 323640 | |
| 89 | Tangail Palli Power Gen 22 MW | IPP | 4'6.7 | 22 | 24 | 372450 | |
| Mymensingh Area Total | | | | 709 | 402 | 7464802 | |
| 90 | Fenchuganj CCGP Phase-1 | PDB | 2'32+1'33 | 70 | 43 | 1003000 | Machine problem |
| 91 | Fenchuganj CCGP Phase-2 | PDB | 2'35+1'35 | 90 | 42 | 765600 | Machine problem |
| 92 | Kushihara 163 MW CCGP (KP) | IPP | 1'109+1'54 | 163 | 163 | 3626263 | |
| 93 | Shahjibazar 330 MW CCGP | PDB | 3'110 | 330 | 160 | 4602000 | ST Under S/D. |
| 94 | Fenchuganj 51 MW PP (Barakat) | RPP | 19'2.90 | 51 | 53 | 919800 | |
| 95 | Fenchuganj 44MW (Energyprima) | RPP | 12'3.3+5'2 | 0 | 0 | 0 | Contract Expired |
| 96 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 4'2.90 | 11 | 2 | 97000 | |
| 97 | Shahjibazar GTTP Unit- 8 & 9 | PDB | 2'35 | 66 | 52 | 949440 | Engine problem |
| 98 | Shahjibazar 80MW PP (Shahjibaz) | RPP | 32'2.90 | 86 | 78 | 1359360 | Engine problem |
| 99 | Shahjibazar 100 MW GTTP | IPP | 1'100 | 100 | 0 | 0 | Under Shut down |
| 100 | Sylhet 225 MW CCGP | PDB | 1'142+1'89 | 231 | 135 | 3047769 | Machine problem |
| 101 | Sylhet 20 MW GTTP | PDB | 1'20 | 20 | 17 | 393000 | |
| 102 | Sylhet 50MW PP (EPL) | RPP | 2'72 | 0 | 0 | 0 | Contract Expired |
| 103 | Shahjahanulla 25 MW PP | SIPP, REB | 3'9.34 | 25 | 16 | 255580 | Engine problem |
| 104 | Bibiana-II 341 MW CCGP (Summit) | IPP | 1'122+1'119 | 341 | 280 | 7265800 | FGMO |
| 105 | Bibiyana-III 400 MW CCGP | PDB | 400 MW | 400 | 366 | 8725000 | FGMO |
| 106 | Sylhet 10MW PP (Desh) | RPP | 6'1.95 | 10 | 7 | 100620 | Engine problem |
| 107 | Bibiyana South 400 MW | PDB | 400 MW | 383 | 399 | 8310000 | FGMO |
| Sylhet Area Total | | | | 2377 | 1823 | 41420932 | |
| 108 | Bheramara GTTP Unit-3 | PDB | 1'20 | 16 | 0 | 0 | |
| 109 | Bheramara (NWDCL) | Imported power | 2'500 | 1000 | 892 | 2156972 | |
| 110 | Khulna 115 PP MW (KPCL-2) | QRPP | 7'17 | 115 | 99 | 1172160 | Engine problem |
| 111 | Fariapur 50 MW Peaking PP | PDB | 8'6.89 | 54 | 8 | 147540 | Low demand |
| 112 | Khulna 225 MW CCGP | NWPGCL | 1'150+1'75 | 230 | 0 | 0 | Reserve. |
| 113 | Gopalganj 100 MW Peaking PP | PDB | 16'6.98 | 109 | 0 | 0 | Reserve. |
| 114 | Bheramara 410 MW CCGP | NWPGCL | 1'278+1'132 | 410 | 350 | 7889544 | FGMO |
| 115 | Noapara 40 MW CCGP (Khanjahan) | QRPP | 5'13.5 | 40 | 32 | 81375 | Engine problem |
| 116 | Noapara 100 MW PP (Bangla Tr) | IPP | 70'1.4 | 100 | 20 | 56640 | Low demand |
| 117 | Rupsha 105 MW PP (Orion rups) | IPP | 6'18.445 | 105 | 53 | 131520 | Low demand |
| 118 | Madhumati 100 MW PP | NWPGCL | 100 MW | 105 | 0 | 0 | Reserve. |
| Khulna Area Total | | | | 2284 | 1454 | 31029051 | |
| 118 | Barisal 110 MW PP (Summit) | IPP | 7'17.076 | 110 | 96 | 223872 | Engine problem |
| 119 | Bhola 33 MW PP (Venture) | RPP | 1'34.50 | 33 | 14 | 480360 | Engine problem |
| 120 | Bhola 225 MW CCGP | PDB | 2'63+1'68 | 194 | 88 | 2105507 | Engine problem |
| 121 | Bhola 95 MW PP (Aggreko) | QRPP | 96'1.10 | 95 | 82 | 705481 | Engine problem |
| 122 | Payra 1320 MW | BCPCL | 2'622 | 1244 | 460 | 10005700 | Low demand |
| 123 | Bhola Nutan Biddut BD LTD | IPP | 220 | 0 | 0 | 2212391 | On Test |
| 124 | United Payra Power Ltd. | IPP | 8'18.5+1'9.5 | 150 | 0 | 56460 | Reserve. |
| Barisal Area Total | | | | 1826 | 740 | 15789719 | |
| 124 | Baghabari 71 MW GTTP | PDB | 1'71 | 71 | 0 | 0 | Gas shortage |
| 125 | Baghabari 100 MW GTTP | PDB | 1'100 | 100 | 0 | 0 | Gas shortage. |
| 126 | Baghabari 50 MW Peaking PP | PDB | 6'8.9 | 52 | 0 | 206708 | Reserve. |
| 127 | Bera 70 MW Peaking PP | PDB | 9'8.29 | 71 | 47 | 306202 | |
| 128 | Annara 50 MW PP(Sinha) | QRPP | 7'7.79 | 50 | 42 | 216090 | Engine problem |
| 129 | Katakhal 50 MW PP (Northern) | QRPP | 6'8.9 | 50 | 0 | 0 | Reserve. |
| 130 | Katakhal 50 MW Peaking PP | PDB | 6'8.7 | 50 | 30 | 159971 | Engine problem |
| 131 | Sirajgonj Unit-1 225MW | NWPGCL | 1'150+1'75 | 210 | 127 | 2424500 | Gas shortage |
| 132 | Sirajgonj Unit-2 225MW | NWPGCL | 1'150+1'75 | 220 | 163 | 4048182 | FGMO |
| 133 | Sirajgonj Unit-3 225MW | NWPGCL | 1'141 | 220 | 181 | 4257400 | FGMO |
| 134 | Sirajgonj 400 MW CCGP Unit-4 | SNWPGCL | 1'282+1'132 | 414 | 387 | 8386600 | FGMO |
| 135 | Sanlahar 50 MW Peaking PP | PDB | 6'8.7 | 50 | 35 | 183003 | Engine problem |
| 136 | Bogra 22 MW PP (GDB) | RPP | 6'4 | 22 | 20 | 301440 | |
| 137 | Bogra 20 MW PP (Energyprima) | RPP | 5'3.3+5'2 | 0 | 0 | 0 | Contract Expired |
| 138 | Uliapara 11 MW PP (Summit) | SIPP, REB | 4'2.90 | 11 | 0 | 142326 | Engine problem |
| 139 | Natore 52 MW PP (Rajshahi) | IPP | 6'8.92 | 52 | 52 | 365760 | |
| 140 | Chapainawabganj 100 MW Peak | PDB | 12'8.924 | 104 | 96 | 492800 | |
| 141 | Baghabari 200 MW PP (Paramo) | IPP | 200 MW | 200 | 0 | 0 | Reserve. |
| 142 | Bagura 113 MW PP (Confidence) | IPP | 113 MW | 113 | 113 | 1432224 | |
| 143 | Confidence Power Bogura Unit-1 | IPP | 6'18.55 | 113 | 109 | 470888 | |
| 144 | Sirajgonj 6.55 MW Solar | NWPGCL | 1'6 | 6 | | | |