

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 29-May-21		Page -2					
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP Unit-1	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-2	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	185	4410000	
4	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
5	Ghorashal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
6	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	93	1955000	Engine problem
7	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	0	5349394	Shut down due to gas problem
9	Haripur 360MW CCGP(HPL)	IPP	1*235+1*125	360	105	3900000	Gas shortage
10	Meghnaghat 450 MW CCGP(MP)	IPP	2*150+1*150	450	280	6665050	Gas shortage
11	Meghnaghat 100 MW(IEI)	QRPP	12*8.9	100	0	0	Contract Expired
12	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	145	3429760	GT-2 under shut down
13	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3*17.06+1*11.3	55	55	876655	
15	Keraniganj 100 MW PP (Powerpa	QRPP	8*13.45	100	87	814420	Engine problem
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	409880	Engine problem
17	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	185	4232000	FGMO
19	Siddhirganj 100 PP(Dutch Bangla	QRPP	12*8.9	100	100	2128349	
20	Siddhirganj 335 MW CCGP	EGCB	1*217+1*18	335	212	5226857	ST Under Maint.
21	Gagnagar 102 MW PP (Digital P	IPP	12*8.924	102	102	1290816	
22	Kalpott 52 MW PP (Siraha)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco E	IPP	3*18	54	35	873720	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	2017920	
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	845344	
26	Nababganj 55 MW PP (Southern	IPP	3*19.3	55	17	478197	Engine problem
27	Bosila 108MW PP(CLG)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
28	Summit Power, (Madhabadi+Ashu	SIPP, REB	3*3.67+4*8.73	80	43	936780	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	796000	
30	Ruganaj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	786500	
31	Gazipur 52 MW PP	IPP	6*8.9	52	42	640800	Engine problem
32	Tongi 80 MW GTTP	PDB	1* 105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	228	2978289	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	307	1551205	
35	Bramhangganj 100 MW PP (Agg	IPP	100	100	100	479318	
36	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	102	610503	
37	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	149	1885390	
38	Gazipur 100 MW PP	RPCL	100 MW	105	72	1644000	Engine problem
39	Meghnaghat 104 MW PP (OPCL	IPP	18.5*6	104	104	1280640	
40	Manikganj 162MW PP(MPGL)	IPP	9*18	162	144	2298240	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	219153	
Dhaka area Total				5919	3182	60992160	
42	Chattogram TPP-1	PDB	1*210	180	100	2400000	Gas shortage
43	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
44	Raazan 25 MW PP	IPP	3*8.9	25	17	399538	Engine problem
45	Teknaf 20MW PP (Solartech)Kinaf Solartech Energ	APSC	20	20	0	130005	
46	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	45	794400	Engine problem
47	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	20	548000	Low water level & Unit-2 und
48	Sikalbaha 225MW	PDB	1*150+1*175	225	217	4997999	FGMO
49	Sikalbaha Peaking GT	PDB	1*150	150	0	0	
50	Sikalbaha 105 MW PP (Baraka S	IPP	105 MW	105	103	1661018	
51	Halfazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
52	Dohazari -Kalaish 100 MW Peak	PDB	6*17	102	68	1270757	Engine problem
53	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	100	2176680	
54	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1994880	
55	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	511728	
56	* Malancha, Cg. EPZ (United)		5*8.73+1*9.34	0	29	545280	
57	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	6	24000	Fuel shortage
58	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	35639	
59	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0	TF OIL
60	Jodiad Power	IPP	3*18.55+1*3.6	54	54	1125870	
61	Karnaphuli Power Ltd.	IPP	110	110	110	2640397	
62	Juldah unit-2 (Acorn)	IPP	8*13.6	100	40	773760	Line OIL
63	Anlima Energy Ltd.	IPP	6*21.2	116	17	477982	TF OIL
Chattogram area Total				2382	1048	22507933	
64	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Gas Shortage
65	Ashuganj TPP Unit- 4	APSCL	1*150	129	80	1919630	Gas shortage
66	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Gas shortage
67	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	201	4892000	FGMO
68	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	295	7415000	FGMO
69	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	300	6993000	FGMO
70	Ashuganj 50 MW PP	APSCL	14*3.968	45	23	476352	Engine problem
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	10	669120	Gas shortage
72	Ashuganj 150MW PP (APSC-U	IPP	20*7.3+1*16	195	8	217454	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1088338	
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	150	2422109	
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	48	478632	
76	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	90	2141170	Machine problem
77	Chandpur 200MW (Desh energy	IPP	0	200	85	1615680	Engine problem
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	465336	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	205020	
80	** Impoprt (Tripura)	Imported power	0	160	162	3290880	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	816600	
82	Jangalia 52 MW PP (Lakdanavi)	IPP	6*9.92	52	52	1220290	
83	Jangalia 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	435610	Engine problem
84	Daudkandi 200 MW PP (B.Trac)	IPP	15*14.1	200	200	1099320	
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	100	2171700	Engine problem
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	115	2695560	
87	Bhairab 54.5 MW	IPP	3*18.2	54	35	819360	33 kV feeder fault.
Cumilla Area Total				3034	2087	43545161	
88	RPCL 210MW CCGP	IPP	4*35+1*70	202	139	3458200	Gas shortage
89	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	16	365688	Engine problem
90	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	16	376320	Engine problem
91	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	15900	
92	Mymensingh 200 MW PP (Unit	IPP	200	172	172	2877600	Engine problem
93	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2761200	
94	Sutakhal 50 MW Solar PP	IPP	50	50	0	337200	
95	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	439680	
Mymensingh Area Total				709	482	10631788	
96	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	42	1003000	Machine problem
97	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	41	998280	Machine problem
98	Kushihara 163 MW CCGP (KP)	IPP	1*109+1*54	163	163	3648845	
99	Shahjibazar 330 MW CCGP	PDB	3*110	330	162	3571000	Machine problem
100	Fenchugonj 51 MW PP (Barakat	RPP	19*2.90	51	50	1099200	
101	Fenchugonj 44MW (Energyprima	RPP	12*3.3+5*2	0	0	0	Contract Expired
102	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	235210	
103	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	56	1326240	Engine problem
104	Shahjibazar 80MW PP (Shahjiba	RPP	32*2.90	86	79	1726080	Engine problem
105	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under Shut down
106	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	219	5232220	
107	Sylhet 20 MW GTTP	PDB	1*20	20	17	396000	Engine problem
108	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
109	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	352644	Engine problem
110	Bibiana-II 341 MW CCGP (Summ	IPP	1*122+1*119	341	320	7386000	FGMO
111	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	405	9117000	FGMO
112	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	7	160200	Engine problem
113	Bibiyana South 400 MW	PDB	400 MW	383	389	9328900	FGMO
Sylhet Area Total				2377	1977	45583819	
114	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	
115	Bheramara (HVDCL)	Imported power	2*1500	1000	827	21700364	
116	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	99	2260800	Engine problem
117	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	19	95040	Engine problem
118	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve.
119	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	17920	Reserve.
120	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	400	9046080	
121	Noapara 40 MW PP (Khanjahan	QRPP	5*8.5	40	0	0	Contract Expired
122	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	100	934080	
123	Rupsha 105 MW PP (Orion rupa	IPP	6*18.445	105	105	1524480	
124	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1550	35578764	
125	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	1713988	
126	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	33	655709	
127	Bhola 225 MW CCGP	PDB	2*63+1*68	194	85	2043582	Engine problem
128	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	97	1851793	
129	Payra 1320 MW	BCPCL	2*622	1244	590	13762900	
130	Bhola Nutan Biddut BD LTD	IPP	0	0	0	0	On Test
131	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	55	540000	Low demand
Barisal Area Total				1826	970	20567872	
132	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
133	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
134	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	308896	
135	Bera 70 MW Peaking PP	PDB	9*6.29	71	29	217208	Engine problem
136	Annura 50 MW PP(Siraha)	QRPP	7*7.79	50	42	301840	Fuel shortage
137	Katakhal 50 MW PP (Northern)	QRPP	6*8.9				