

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 30-May-21		Page - 2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP Unit-1	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-2	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	185	4378500	
4	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
5	Ghorashal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
6	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	99	2150500	
7	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	0	0	Shut down due to gas problem
9	Haripur 360MW CCGP(HPL)	IPP	1*235+1*125	360	118	3094000	Gas shortage
10	Meghnaghat 450 MW CCGP(MP)	IPP	2*150+1*150	450	280	666550	Gas shortage
11	Meghnaghat 100 MW(IEI)	QRPP	12*8.9	100	0	0	Contract Expired
12	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	260	4489600	FGMO
13	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3*17.06+1*11.3	55	55	1201721	
15	Meghnaghat 100 PP (Powerpa	QRPP	8*13.45	100	80	1465997	Engine problem
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	0	228996	Engine problem
17	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	185	3979000	FGMO
19	Siddhirganj 100 PP(Dutch Bangla	QRPP	12*8.9	100	100	1638720	
20	Siddhirganj 335 MW CCGP	EGCB	1*217+1*18	335	214	5131093	ST Under Maint.
21	Gagnagar 102 MW PP (Digital Pa	IPP	12*8.924	102	102	2082672	
22	Kalpott 52 MW PP (Siraha)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco E	IPP	3*18	54	35	874800	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	3604800	
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1002266	
26	Nababganj 55 MW PP (Southern	IPP	3*19.3	55	55	768491	
27	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
28	Summit Power (Madhabadi-Ashul	SIPP, REB	3*3.67+4*8.73	80	45	1073940	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	799800	
30	Ruganaj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	763900	
31	Gazipur 52 MW PP	IPP	6*8.9	52	41	846240	Engine problem
32	Tongi 80 MW GTTP	PDB	1* 105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	245	5211380	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	108	1724988	Low demand
35	Bramhanganj 100 MW PP (Agg	IPP	100	100	100	1062298	
36	Aurahati 100MW PP (Agreko)	IPP	0.85*23+0.95*9.1	100	102	1255546	
37	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	149	3288960	
38	Gazipur 100 MW PP	RPCL	100 MW	105	83	1944000	Engine problem
39	Meghnaghat 104 MW PP (OPCL	IPP	18.5*5	104	104	2166720	
40	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	144	3353760	Engine problem
41	Spectra Solar Plant Ltd.	IPP	35	35	0	177732	
Dhaka area Total				5919	3160	66407467	
41	Chattogram TPP-1	PDB	1*210	180	90	2200000	Gas shortage
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
43	Raazan 25 MW PP	IPP	3*8.9	25	17	419335	Engine problem
44	Teknaf 20MW PP (SolarTech)Kinaf Solartech Energy	IPP	20	20	0	117180	
45	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	46	992640	Engine problem
46	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	20	484000	Low water level & Unit-2 unc
47	Sikalbaha 225MW	PDB	1*150+1*175	225	204	4958502	FGMO
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka S	IPP	105 MW	105	105	2559272	
50	Halfazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
51	Dohazari -Kalaish 100 MW Peak	PDB	6*17	102	85	888837	Engine problem
52	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	100	2022000	
53	Juldah 100 MW PP Unit-3 (Acorn	IPP	0	100	100	2415360	
54	Barakunda 22 MW PP (Regent	SIPP, PDB	5*8.73+9.34	22	22	505344	
55	Chattogram 108 MW PP (ECPV)	IPP	6*7	108	0	0	Engine problem
56	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	27959	
57	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0	TF O/L
58	Jodiad Power	IPP	3*18.55+1*3.6	54	54	1299168	
59	Karnaphuli Power Ltd.	IPP	110	110	91	2004762	Engine problem
60	Juldah unit-2 (Acorn)	IPP	8*13.6	100	80	1631040	Line O/L
61	Anlima Energy Ltd.	IPP	6*21.2	116	17	429055	Line O/L
Chattogram area Total				2382	1057	23418074	
61	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Gas Shortage
62	Ashuganj TPP Unit- 4	APSCL	1*150	129	80	1969105	Gas shortage
63	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Gas shortage
64	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	211	5034000	
65	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	265	7289000	FGMO
66	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	275	6793000	FGMO
67	Ashuganj 50 MW PP	APSCL	14*3.968	45	20	454896	Engine problem
68	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	43	586560	Gas shortage
69	Ashuganj 150MW PP (APCL-U	IPP	20*7.3+1*16	195	8	200727	Gas shortage
70	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1183045	
71	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	132	3206618	Engine problem
72	Tilas 50 MW Peaking PP	PDB	6*8.92	52	47	819824	
73	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	90	2126610	Machine problem
74	Chandpur 200MW (Desh energy	IPP	0	200	100	2233920	Engine problem
75	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	471886	
76	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	168120	
77	Impoprt (Tripura)	Imported power	0	160	172	3715200	
78	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	816800	
79	Jangalia 52 MW PP (Lakdanavi)	IPP	6*9.92	52	43	1109381	Engine problem
80	Daikandi 200 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	496340	Engine problem
81	Daikandi 200 MW PP (B.Trac)	IPP	15*11.4	200	200	2284416	
82	Feni Lanka Power	IPP	7*18.415+1*9.78	114	100	2362080	Engine problem
83	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	120	2485560	
84	Bhairab 54.5 MW	IPP	3*18.2	54	35	887040	33 kV feeder fault.
Cumilla Area Total				3034	2074	46869130	
82	RPCL 210MW CCGP	IPP	4*35+1*70	202	130	3137680	Gas shortage
83	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	18	394524	Engine problem
84	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	16	367680	Engine problem
85	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12200	
86	Mymensingh 200 MW PP (Unit)	IPP	200	200	196	3921600	
87	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2750400	
88	Sutakhirali 50 MW Solar PP	IPP	50	50	0	343490	
89	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	586080	
Mymensingh Area Total				709	499	11513854	
90	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	42	1002000	Machine problem
91	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	42	990360	Machine problem
92	Kushihara 163 MW CCGP (KP)	IPP	1*109+1*54	163	163	3607445	
93	Shahjibazar 330 MW CCGP	PDB	3*110	330	161	3547000	Machine problem
94	Fenchugonj 51 MW PP (Barakat	RPP	19*2.90	51	53	1202400	
95	Fenchugonj 44MW (Energyprima	RPP	12*3.3+5*2	0	0	0	Contract Expired
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	264000	
97	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	56	1329120	Engine problem
98	Shahjibazar 80MW PP (Shahjiba	RPP	32*2.90	86	78	1794240	Engine problem
99	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under Shut down
100	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	212	5120110	
101	Sylhet 20 MW GTTP	PDB	1*20	20	17	399000	Engine problem
102	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
103	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	363360	Engine problem
104	Bibiana-II 341 MW CCGP (Summ	IPP	1*222+1*119	341	300	7289600	FGMO
105	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	365	9558000	FGMO
106	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	7	161280	Engine problem
107	Bibiyana South 400 MW	PDB	400 MW	383	395	9514900	FGMO
Sylhet Area Total				2377	1918	46149715	
108	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	
109	Bheramara (HVDCL)	Imported power	2*500	1000	820	19972363	
110	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	99	2233920	Engine problem
111	Fardpur 50 MW Peaking PP	PDB	8*6.89	54	20	248160	Engine problem
112	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve.
113	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
114	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	365	8978976	FGMO
115	Noapara 40 MW PP (Khanjhar	QRPP	5*8.5	40	0	0	Contract Expired
116	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	100	855360	
117	Rupsha 105 MW PP (Orion rupa	IPP	6*18.445	105	105	1813440	
118	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1509	34102219	
118	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	96	3172032	Engine problem
119	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	34	653655	
120	Bhola 225 MW CCGP	PDB	2*63+1*68	194	85	2057109	Machine problem
121	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	66	2172999	Machine problem
122	Payra 1320 MWD	BCPCL	2*622	1244	570	13744600	
123	Bhola Nutan Biddut BD LTD	IPP	220	0	109	888145	On Test
124	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	17	528000	Low demand
Barisal Area Total				1826	977	21232970	
124	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
125	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
126	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	902048	
127	Bera 70 MW Peaking PP	PDB	9*6.29	71	48	222533	Engine problem
128	Annura 50 MW PP(Siraha)	QRPP	7*7.79	50	24	402130	Raj. 132 kV Bus O/L
129	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	34	317168	Engine problem
130	Katakhal 50 MW Peaking PP	PDB	6*8.7	50</			