

Date : 1-Jun-21		Page -2						
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks	
			Unit No. X Capacity	MW	Generation	KWH		
				MW	MW	KWH		
1	Ghorasal Rewerred CCGP Unit-3	PDB	1260	260	0	0	Under maint.	
2	Ghorasal Rewerred CCGP Unit-2	PDB	1210	180	0	0	Under maint.	
3	Ghorasal TPP Unit-5	PDB	1210	190	185	4504500		
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	Under maint.	
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	Contract Expired	
6	Ghorasal 108MW PP (Regent)	IPP	343.35	108	99	2205909		
7	Harihar GTPP	SBU, PDB	232	20	0	0	Under maint.	
8	Harihar 412 MW CCGP	EGCB	1273+1139	412	0	0	Shut down due to gas problem	
9	Harihar 360MW CCGP(HPL)	IPP	1235+1125	360	156	3418000	Gas shortage	
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1150	450	280	6647750	Gas shortage	
11	Meghnaghat 100 MW(IELE)	QRPP	12*8.9	100	0	0	Contract Expired	
12	Meghnaghat CCGP(Summit)	IPP	2*110+1110	305	260	5544087	FGMO	
13	Madangan 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired	
14	Madangan 35 MW PP(Summit)	(IPP)	3*11.08+111.3	55	30	537051		
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	10	201047	Low demand	
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	360288		
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.	
18	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	181	3514000	FGMO	
19	Siddhirgonj 100 PPI/Dutch Bangla	QRPP	12*8.9	100	100	1491840		
20	Siddhirgonj 335 MW CCGP	EGCB	12*11+118	335	227	5098957	ST under Maint.	
21	Gagunagar 102 MW PP (Digital Po	IPP	12*8.924	102	64	813168	Low demand	
22	Kalpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage	
23	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	35	718956	Engine problem	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	1897440		
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	361507	Engine problem	
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	787274		
27	Bostia 108MW PP(CLO)	IPP	12*8.775+113.5	108	0	0	Fuel shortage	
28	Summit Power (Madhabadi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	45	999240	Engine problem	
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	28	628500	Engine problem	
30	Ruggan 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	728900		
31	Gazipur 52 MW PP	IPP	6*8.9	52	42	699926	Engine problem	
32	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.	
33	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	195	2571817	Low demand	
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve.	
35	Bramhangonj 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.	
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.	
37	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	140	1822460		
38	Gazipur 100 MW PP	RPCL	100	105	82	1745016	Engine problem	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.5	104	104	987690		
40	Manikganj 162MW PP(MPGL)	IPP	9*18	162	126	1563840	Engine problem	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	62719		
<b>Dhaka area Total</b>				<b>5919</b>	<b>2684</b>	<b>49910972</b>		
41	Chattogram TPP-1	PDB	1*210	180	100	2300000	Gas shortage	
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage	
43	Razzan 25 MW PP	IPP	3*8.9	25	17	413810	Engine problem	
44	Takrawi 20MW PP (Solartech)Tektar Solartech Energ	IPP	20	20	0	47385		
45	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	589440		
46	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	20	492000	Low water level & Unit-2 und	
47	Sikalbaha 225MW	PDB	1*150+1*175	225	203	5103443	FGMO	
48	Sikalbaha Peaking GT	PDB	1*150	150	0	102507	Under maint.	
49	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	2581018		
50	Hathazari 100 MW Peaking PP	PDB	11*8.9	98	0	0	Under S/D	
51	Dohazari -Kalesh 100 MW Peakin	PDB	6*17	102	85	816488	Engine problem	
52	Judah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	100	2175600		
53	Judah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1933440		
54	Barakkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	430032		
55	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	25	397440		
56	Chattogram 108 MW PP (ECPV)	IPP	18*5.5	108	0	0	Fuel shortage	
57	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	8602		
58	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0	Transformer O/L	
59	Jodac Power	IPP	3*18.55+1*3.6	54	54	1094967		
60	Karnaphuli Power Ltd.	IPP	110	110	85	2498207	Low demand	
61	Judah unit-2 (Acorn)	IPP	8*13.6	100	50	688320	Line O/L	
62	Anilma Energy Ltd.	IPP	6*21.2	116	17	421527	Line O/L	
<b>Chattogram area Total</b>				<b>2382</b>	<b>1630</b>	<b>2292234</b>		
61	Ashuganj TPP Unit-3	APSCl	1*150	135	0	135	0	Gas Shortage
62	Ashuganj TPP Unit-4	APSCl	1*150	129	125	2602385		
63	Ashuganj TPP Unit-5	APSCl	1*150	134	0	0	Gas shortage	
64	Ashuganj 225 MW CCGP	APSCl	1*142+1*75	221	221	5052000		
65	Ashuganj 450 MW CCGP(North)	APSCl	1*360	360	370	6089500	FGMO	
66	Ashuganj 450 MW CCGP(South)	APSCl	1*360	360	0	1679000	Under maint.	
67	Ashuganj 50 MW CCGP	APSCl	14*3.988	45	23	485824	Engine problem	
68	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	52	878880		
69	Ashuganj 195MW PP (APSCl-UH)	IPP	20*9.73+1*16	195	83	1271272	Gas shortage	
70	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	983124	Engine problem	
71	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	135	2363563		
72	Titas 50 MW Peaking PP	PDB	6*8.92	52	50	106944		
73	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	77	1595400	Machine problem	
74	Chandpur 200MW (Desh energy)	IPP	0	200	139	2746560	Engine problem	
75	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	416304		
76	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	5	119160	Engine problem	
77	Impoport (Tripura)	Imported power	0	160	110	1334400		
78	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	25	665900	Engine problem	
79	Jangalia 52 MW PP (Kaldanar)	IPP	6*8.92	52	54	967400	Engine problem	
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*9.67	25	20	314480	Engine problem	
81	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.	
82	Feni Lanka Power	IPP	7*18.415+1*9.78	114	100	2278860	Engine problem	
83	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	110	2700600		
84	Bhairab 54.5 MW	IPP	3*18.2	54	35	510480	33 kV feeder fault.	
<b>Cumilla Area Total</b>				<b>3034</b>	<b>1779</b>	<b>35548716</b>		
82	RPCL 210MW CCGP	IPP	4*35+1*70	202	135	3213232		
83	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	17	401256	Gas shortage	
84	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	16	379200	Engine problem	
85	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	8750		
86	Mymensingh 200 MW PP (Unite	IPP	200	200	192	1257600		
87	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	107	2100000		
88	Sylhet 50 MW Solar PP	IPP	50	50	0	131030		
89	Tangail Fall Power 22 MW	IPP	4*6.7	22	24	469240		
<b>Mymensingh Area Total</b>				<b>709</b>	<b>491</b>	<b>7943276</b>		
90	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	42	1011000	Machine problem	
91	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	42	1008000	Machine problem	
92	Kushihara 163 MW CCGP (KP)	IPP	1*109+1*54	163	163	3550990		
93	Shahbazar 330 MW CCGP	PDB	3*110	330	163	3627000	GT-1 under maint	
94	Fenchugonj 51 MW PP (Barakati)	IPP	19*2.90	51	49	1165200		
95	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired	
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	183100		
97	Shahbazar GTPP Unit- 8 & 9	PDB	2*35	66	63	1424160		
98	Shahbazar 86MW PP (Shahjibaz	RPP	32*2.90	86	81	1768320		
99	Shahbazar 100 MW GTPP	PDB	1*100	100	0	0	Under Shut down	
100	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	219	4184860		
101	Sylhet 20 MW GTPP	PDB	1*20	20	18	407000		
102	Sylhet 50MW PP (EPL)	RPP	2*72	0	0	0	Contract Expired	
103	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	357648	Engine problem	
104	Bibiana-II 341 MW CCGP (Summ	IPP	1*222+1*119	341	290	7219000	FGMO	
105	Bibiana-III 400 MW CCGP	PDB	400 MW	400	363	8951000	FGMO	
106	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	7	163620	Engine problem	
107	Bibiana South 400 MW	PDB	400 MW	383	400	9039000	FGMO	
<b>Sylhet Area Total</b>				<b>2377</b>	<b>1927</b>	<b>44053898</b>		
108	Bheramara GTPP Unit-3	PDB	1*20	16	0	0		
109	Bheramara (HVDC)	Imported power	2*500	1000	804	19338909		
110	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	0	0	Contract Expired	
111	Fairdipur 50 MW Peaking PP	PDB	6*8.89	54	9	43200	Engine problem	
112	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	225	0	0	Reserve.	
113	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	9088	Reserve.	
114	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	370	9020736	FGMO	
115	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	40	0	0	Contract Expired	
116	Noapara 100 MW PP (Bangla Tre	IPP	70*1.4	100	31	221760	Low demand	
117	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	1577568		
118	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.	
<b>Khulna Area Total</b>				<b>2284</b>	<b>1519</b>	<b>30211261</b>		
118	Basirdal 110 MW PP (Summit)	IPP	7*17.076	110	16	422784	Engine problem	
119	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	26	517640	Engine problem	
120	Bhola 225 MW CCGP	PDB	2*63+1*68	194	68	1816856	Machine problem	
121	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	13	942833	Machine problem	
122	Payra 1320 MW	BCPCL	2*622	1244	410	10378900		
123	Bhola Nutan Bidrut BD LTD	IPP	220	0	233	3046636	On Test	
124	United Payra Power Ltd.	IPP	8*18.8+1*9.5	150	17	88800	Low demand	
<b>Barisal Area Total</b>				<b>1826</b>	<b>783</b>	<b>17213849</b>		
124	Baghbari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage	
125	Baghbari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage.	
126	Bera 70 MW Peaking PP	PDB	6*8.9	52	50	495024		
127	Amrua 50 MW PP(Sinha)	QRPP	7*7.9	50	42	168430	Engine problem	
128	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	43	90405	Engine problem	
129	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	38	197750	Engine problem	
130	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage	
131	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	164	4311173	FGMO	
132	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	177	4562855	FGMO	
133	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1*282+1*132	414	374	8959127	FGMO	
134	Santihar 50 MW Peaking PP	PDB	6*8.9	50	27	180196	Engine problem	
135	Bogra 22 MW PP (GBB)	RPP	6*4	22	21	492480		
136	Bogura 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	Contract Expired	
137	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	197136		
138	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	1005600		
139	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	95	1030704		
140	Baghbari 200 MW PP (Perencou	IPP	200 MW	200	0	0	Reserve.	
141	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	1373568		
142	Confidence Power Bogura Unit-1	IPP	6*18.55	113	113	1057920		
143	Sirajgonj 6.55 MW Solar	NWPGCL	1*6	6	0	13560	</	