

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 954667, 9551095

Month June, 2021					Day : Saturday		Date : 05.06.21					
Probable Maximum Demand : 12800 MW					Probable Maximum Generation : 15570 MW							
Water Level of Kaptai Lake at 06:00 AM					Rule Curve = 77.04 ft.							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Today = 72.43 ft.		05.06.21 (Today)		04.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	96	104	104			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.	
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	330	343	280	350	17	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	119	257	310	310	155	Dirty in Gas	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	73	92	0	0	118	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	290	331	300	335			
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	75	98	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	290	285	280	300			
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	0	0			
16	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55			
17	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100			
18	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	58	102	102			
19	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	20	20			
20	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	39	45	45	45			
21	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
22	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
23	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	41	42	42			
24	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	85	85	85	85			
25	Kodda 150MW PP	HFO (8PDB-RPCL)	9x17.06	149	149	16	82	150	150			
26	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
27	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35			
28	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	45	245	245			
29	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	102	78	149	149			
30	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300			
31	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
32	Aurshali 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
33	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	55	55			
34	Maniganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	17	55	55			
35	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
36	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	104	104			
37	Maniganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	0	54	144	144			
38	Maniganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	23	0	30	0			
Dhaka Zone Total				6076	5919	2174	2684	3571	3916	460	1045	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	20	20	20	20	210	Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
43	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	11	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	50	50			
45	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	17	105	105	105			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	120	120	125			
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	209	220	220			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300			
49	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	73	100	100	100			
50	Juddah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	10	50	100	100			
51	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	85	85			
52	Helhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			16	42	32	40			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	0	0	0			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	68	110	110			
57	Juddah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	10	100	100			
58	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	0	116	116	116			
Chattogram Zone Total				2442	2382	704	1002	1676	1664	210	180	
59	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	100	125	125	125	4	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	26	26			
61	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1775	221	221	201	194	220	220			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	320	280	300	360			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	335	330	360	360			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	48	49	55	55	6	Gas shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	55	139	150	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	90	90	90	73	ST under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	74	150	160	160			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
73	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	43	43	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	21	20	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	95'14+8x1.515+15x1.058	200	200	0	0	100	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	100	100	100	100			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	113	116	113	113			
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
**	Impoport (Tripura)	India		160	160	112	156	152	181			
Cumilla Zone Total				3094	3034	1476	1976	2174	2414	466	73	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	146	156	159	159	46	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	20	20			
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	15	15	16	16			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	105	115	115	115			
84	Myensing 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	113	200	200			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0			
87	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	14	24	22	22			
Myensing Zone Total				717	709	347	442	584	532	46	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.06.21 (Yesterday)		05.06.21 (Today)		04.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	42	44	44		28	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	61	63	63				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	158	162	0	0				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x90	86	86	40	83	83	83				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	218	218	140	210				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	7	7				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
100	Bitiyana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	341	341				
101	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	401	403	400	400				
102	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	388	400	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1847	1989	1779	1849	0	76	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	390	370	400	400				
106	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	9	20	20	20				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	155	0	220				
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	0	0				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	105	105	105				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	895	895	921	921				
Khulna Zone Total					2288	2284	1294	1645	1656	1926	0	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	110	110				
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	34	33	33				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	68	67	88	88		127	GT-2 & STG Under	
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	0	0	0				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	380	500	622	622				
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110				
Bhola Nutan Biddut BD LTD						222	224	228	233				
Barishal Zone Total					1826	1826	690	857	1081	1196	0	127	
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	45	45				
124	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	34	42	42				
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	8	98	90	90				
126	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	40	40				
127	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35				
129	Siragajonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	110	126	144	144	24		Gas Shortage, STG S/D	
130	Siragajonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	194	184	195	195				
131	Siragajonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	186	165	197	197				
132	Siragajonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	390	363	400	400				
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	20	20				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	0	70	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	113	113	113				
138	Siragajonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total					2179	2179	968	1357	1761	1790	195	0	
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	0	113	113	113				
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
144	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
Rangpur Zone Total					685	685	154	263	271	283	294	0	
Sub-total: Plants in operation					21729	21315	9954.0	12215	14553	15570	1671	1501	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss							9532	11697	13935	14910			
(B) Plants under long term maintenance/ contract expired													
145	Chorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
147	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
148	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired					294	0	0	0	0	0			
Gross Total					22023	21315	9954	12215	14553	15570	1671	1501	
(C) Actual data of 04.06.21 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	12215.00 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11697.00 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	12275.00 MW, at =	23:00 hrs	Dhaka	4025	4025	0	Mymensingh	959	959	0	
04.	Minimum Generation (Generation end)	:	9086.00 MW, at =	8:00 hrs	Chattogram	1243	1243	0	Sylhet	396	396	0	
05.	Day-peak Generation (Generation end)	:	9954.00 MW, at =	12:00 hrs	Khulna	1579	1579	0	Barishal	353	353	0	
06.	Evening-peak Generation (Generation end)	:	12215.00 MW, at =	21:00 hrs	Rajshahi	1164	1164	0	Rangpur	769	769	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at =	21:00 hrs	Cumilla	1209	1209	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8452.00 MW, at =	5:00 hrs					Total	11697	11697	0	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 173532303 Taka (b) Oil = 417839304 Taka	(c) Coal = 69772713 Taka Total = 661144320 Taka					
	a) Gas limitation	:	1167 MW		14.	Maximum Temperature in Dhaka was : 35.9° C							
	d) Coal supply Limitation	:	294 MW		15.	Export through East-West interconnections :							
	b) Low water level in Kaptai lake	:	210 MW			At evening peak-hour	:	-5 MW, at	21:00 hrs				
	c) Plants under shut down/ maintenance	:	1501 MW			Maximum	:	-203 MW, at	13:00 hrs				
10.	Total Energy (Generation + India Import)	:	259.28 MKWh			Energy	:	0.4435 MKWh					
	By Gas = 164.254 MKWh		By Oil = 54.225 MKWh										
	By Coal = 15.030 MKWh		By Hydro = 0.484 MKWh										
	By Solar= 0.740 MKWh												
11.	Total Gas Supplied	:	1279.60 MMCFD										
(D) Forecast of 05.06.21 (Today) Saturday :													
01.	Maximum Demand	:	12800 MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	15570 MW (Generation end)		05.	Total Generation : 270.37 MKWh							
03.	Maximum Shortage	:	-2770 MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 37.6° C							

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzi Islam Shaker)

Deputy Secretary, Generation