

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month June, 2021				Day : Monday				Date : 14.06.21					
Probable Maximum Demand : 13000 MW				Probable Maximum Generation : 14863 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.48 ft.	Today = 74.79 ft.	13.06.21 (Yesterday)		14.06.21 (Today)		Rule Curve = 79.41 ft.			
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Actual Peak Generation (MW)		Probable Peak Generation (MW)		13.06.21 Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	
						Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0		260	Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	98	98	104	104				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Under Maint.	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	74	70	0	0		290	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300		150	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0		412	Under maint.	
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	92	0	0	0		210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	330	331	335	335				
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	260	275	260	260				
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	8	74	85	85				
17	Gargnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102				
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	20	21	21	21				
19	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	54	53	55	55				
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	33	33	33				
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	42	42	42				
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	85	85				
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	133	150	150				
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	137	226	250	250				
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	82	131	132	132				
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	258	100	300				
30	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100				
31	Auralah 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	101	50	100				
32	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	55	55				
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	60	90	104	104				
36	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	118	126	162	162				
37	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	27	0	30	0				
Dhaka Zone Total				5976	5819	2534	3169	3037	3257	650	1457		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low Water Level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0				
41	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	2	17	17	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	1	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	10	41	50	50				
44	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	100	100				
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	203	220	220				
47	Anwara 300 MW Unit-1 (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300				
48	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	80	100	100	100				
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	100	100	100				
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	85	85	85				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	22	22				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	32	20	35				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	6	6				
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	70	100	100	100				
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	17	17	116	116				
Chattogram Zone Total				2442	2382	992	1189	1655	1645	205	180		
58	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	80	80	80	55		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	13	23	26	26				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1175	221	221	184	200	220	220				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	265	260	260	300				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	260	260	320				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	30	25	55	55				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+116	195	195	36	8	26	26	187		Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	20	40	143	143				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	49	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	128	130	135	140				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	180	179	185	185				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdhanvi)	HFO (IPP)	6x8.92	52	52	16	43	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	21	21	21				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x11.4+8x1.915+1x1.915	200	200	0	200	100	200				
76	Feni 11.4 MW Power Plant(Lakdhanvi)	HFO (IPP)	7'18.415+119.78	114	114	80	100	100	100				
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	115	117	113	113				
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
**	Impport (Tripura)	India		160	160	134	150	151	179				
Cumilla Zone Total				3094	3034	1758	2034	2070	2353	505	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	101	119	140	150	83		Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	20	20				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	40	172	200	200				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0				
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	22	22				
Mymensingh Zone Total				717	709	345	441	557	515	83	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.06.21 (Yesterday)		14.06.21 (Today)		13.06.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	42	42		70	Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
89	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	43	47	51	51				
90	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	61	62	62				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	162	163	162	162				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	76	81	80	83				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	192	220	225				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	0	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	15	15				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	290	341	341				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	315	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	393	310	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total						2422	2377	1841	1701	2017	2025	0	118
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	350	360	350	400	50		Gas Shortage	
105	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	19	20	20				
106	Cogaliganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	165	0	220				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	100	50	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	52	91	105	105				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	900	899	917	917				
Khulna Zone Total						2133	2129	1302	1634	1602	1922	50	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	33	33	33				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	84	85	85		110	GT-2 & STG Under	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	12	12	22	22				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	380	520	622	622				
116	Polakhalai 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				170	221	220	220				
Barishal Zone Total						1826	1826	667	886	1092	1202	0	110
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	200	200				
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	50	51	51				
121	Amnura 50 MW PP (Sinthe)	HFO (QRPP)	7x7.79	50	50	35	18	35	35				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	40	96	50	96				
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	23	40	40				
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	35				
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	150		Gas Shortage, STG S/D	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	183	192	200	200				
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	178	193	200	200				
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	395	406	400	400				
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total						2179	2179	1129	1458	1586	1661	321	0
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	149	150	150	125		Coal Shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	18	0	10				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	113	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Maipara, Tatula 6 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 6	6	5	0	8	0	0				
Rangpur Zone Total						685	605	268	280	271	283	295	0
Sub-total: Plants in operation						21474	21060	10836.0	12792	13887	14863	2109	1865
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								10372	12244	13292	14226		
(B) Plants under long term maintenance/ contract expired													
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
147	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0				Contract Expired on 28/05/2021
Sub-Total: Plants under long term maintenance/ contract expired						549	0	0	0	0	0		
Gross Total						22023	21060	10836	12792	13887	14863	2109	1865
(C) Actual data of 13.06.21 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	12792.00 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	12244.00 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	12792.00 MW, at = 21:00 hrs	Dhaka	4427	4427	0	Mymensingh	896	896	0		
04.	Minimum Generation (Generation end)	:	9302.00 MW, at = 7:00 hrs	Chattogram	1240	1240	0	Sylhet	513	513	0		
05.	Day-peak Generation (Generation end)	:	10836.00 MW, at = 12:00 hrs	Khulna	1540	1540	0	Barishal	356	356	0		
06.	Evening-peak Generation (Generation end)	:	12792.00 MW, at = 21:00 hrs	Rajshahi	1293	1293	0	Rangpur	786	786	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 21:00 hrs	Cumilla	1193	1193	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9441.00 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	1609 MW	13.	Fuel cost :	(a) Gas = 154642216 Taka	(c) Coal = 70602410 Taka						
	d) Coal supply Limitation	:	295 MW			(b) Oil = 633745487 Taka	Total = 858990114 Taka						
	b) Low water level in Kaptai lake	:	205 MW										
	c) Plants under shut down/ maintenance	:	1865 MW										
10.	Total Energy (Generation + India Import)	:	268.12 MCKWh	14.	Maximum Temperature in Dhaka was : 33.5 C								
	By Gas = 147.155 MCKWh		By Oil = 79.462 MCKWh	15.	Export through East-West interconnections :								
	By Coal = 15.226 MCKWh		By Hydro = 0.604 MCKWh		At evening peak-hour	:	61 MW, at 21:00 hrs						
	By Solar = 0.709 MCKWh				Maximum	:	-74 MW, at 1:00 hrs						
11.	Total Gas Supplied	:	1134.27 MMCFD		Energy	:	0.245 MCKWh						
(D) Forecast of 14.06.21 (Today) Monday :													
01.	Maximum Demand	:	13000 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	:	14863 MW (Generation end)	05.	Total Generation : 272.48 MCKWh								
03.	Maximum Shortage	:	-1863 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 35.1° C								
* Captive Power ** Imported Power													

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)
Deputy Secretary, Generation