

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		15-Jun-21				Page -2	
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP-Unit-3 (GT	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	185	4378500	
3	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
4	Ghorasah 76.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
5	Ghorasah 108MW PP (Regent)	IPP	34*3.35	108	101	2224727	
6	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
7	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	0	0	Under maint.
8	Haripur 360MW CCGP(HPL)	IPP	1*235+1*125	360	0	0	Gas shortage
9	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	300	7128000	Gas shortage
10	Meghnaghat 100 MW(IEL)	ORPP	12*8.9	100	0	0	Contract Expired
11	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	302	6560436	FGMO
12	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
13	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	1121172	
14	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	74	1242540	Engine problem
15	Narsinghat 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	21	420912	
16	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
17	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	100	100	2378746	
19	Siddhirgonj 335 MW CCGP	EGCB	1*217+1*118	335	335	7338258	
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	102	1947888	
21	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
22	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	1308600	
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	133	3054240	Engine problem
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	961397	
25	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	1003516	
26	Bosilia 108MW PP(OLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
27	Summit Power (Madhabadi-Ashulia)	SIPP, REB	3*3.67+4*8.73	80	55	1273200	Engine problem
28	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	30	731200	
29	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	814600	
30	Gazipur 52 MW PP	IPP	6*8.9	52	42	1009920	Engine problem
31	Tongi 80 MW GTPP	PDB	1* 105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	220	4686980	Engine problem
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	258	1364614	Low demand
34	Bramhangsan 100 MW PP (Aggreko)	IPP	100	100	30	394212	Low demand
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	102	802184	
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	132	2615184	Engine problem
37	Gazipur 100 MW PP	RPCL	100 MW	105	89	2113200	Engine problem
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	72	1454400	Engine problem
39	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	126	2799360	Engine problem
40	Spectra Solar Plant Ltd.	IPP	35	35	0	175980	
Dhaka area Total				5919	3061	61307566	
41	Chattogram TPP-1	PDB	1*210	180	100	2400000	Gas shortage
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
43	Raozan 25 MW PP	IPP	3*8.9	25	17	412853	Engine problem
44	Teknaf 20MW PP (Solartech)	Teknaf Solaratrch Energ	20	20	0	22815	
44	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	46	624000	Engine problem
45	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	25	608000	Low water level & Unit-2 und
46	Sikalbaha 225MW	PDB	1*150+1*175	225	203	4900060	FGMO
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	PDB	1*150	150	100	2395660	Machine problem
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	105	2606109	
49	Hafizabari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
50	Dohazari-Kalashah 100 MW Peaking	PDB	6*17	102	85	975039	Engine problem
51	Juidah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	100	2197920	
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2412480	
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	0	0	Engine problem
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	25	453120	
54	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Fuel shortage
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	25981	
56	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0	Transformer O/L
57	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1299301	
58	Karnaphuli Power Ltd.	IPP	110	110	110	2687224	
59	Juidah unit-2 (Acorn)	IPP	8*13.6	100	100	2177280	
60	Anlima Energy Ltd.	IPP	6*21.2	116	17	495545	Transformer O/L
Chattogram area Total				2382	1187	26697287	
61	Ashuganj TPP Unit-3	APSCL	1*150	135	80	2026630	Gas Shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Under maint.
62	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	213	4834000	FGMO
63	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	280	6923000	Gas shortage
64	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	310	7167000	FGMO
65	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	576144	Engine problem
66	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	977760	Gas shortage
67	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	0	0	230 kV Bus S/D
68	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	642794	230 kV Bus S/D
69	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	1567345	230 kV Bus S/D
70	Tilas 50 MW Peaking PP	PDB	6*8.92	52	48	724896	
71	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	133	3170290	Machine problem
72	Chandpur 200MW (Desh energy)	IPP	0	200	178	4011120	Engine problem
73	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	425808	Engine problem
74	Feni 111 MW PP (Doreen)	SIPP, REB	4*2.90	11	0	235980	Engine problem
**	Import (Tripura)	Imported power	0	160	132	2864640	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	0	76100	Engine problem
76	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	16	235824	Fuel shortage
77	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	19	440310	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	15*11.4	200	100	921984	Low demand
79	Feni Lanka Power	IPP	7*18.415+1*9.78	114	54	571140	Fuel shortage
80	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	120	2751840	
81	Bhairab 54.5 MW	IPP	3*18.2	54	36	669240	33 kV feeder fault.
Cumilla Area Total				3034	1769	41819845	
82	RPCL 210MW CCGP	IPP	4*35+1*70	202	117	2534280	Gas shortage
83	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	4346564	
84	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	8	174720	Engine problem
85	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	10850	
86	Mymensingh 200 MW PP (United)	IPP	200	200	174	3194400	Engine problem
87	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2751600	
88	Sutiakhal 50 MW Solar PP	IPP	50	50	0	286880	
89	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	580080	
Mymensingh Area Total				709	458	10367474	
90	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	0	0	Under maint.
91	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	42	975120	Machine problem
92	Kushiaha 163 MW CCGP (KP)	IPP	1*109+1*54	163	163	3481363	
93	Shajibazar 330 MW CCGP	PDB	3*110	330	161	3606000	GT-1 under maint
94	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	53	1113600	
95	Fenchugonj 44MW (Energyprima)	IPP	12*3.34+5*2	0	0	0	Contract Expired
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	246000	
97	Shajibazar GTPP Unit- 8 & 9	PDB	2*35	66	62	1386528	
98	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	81	1859520	
99	Shajibazar 100 MW GTPP	PDB	1*100	100	0	0	Under Shut down
100	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	192	4590500	Gas shortage
101	Sylhet 20 MW GTPP	PDB	1*20	20	0	0	
102	Sylhet 50MW PP (EPL)	RPP	2*72	0	0	0	Contract Expired
103	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	335496	Engine problem
104	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	300	7300500	FGMO
105	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	315	7558000	Gas shortage
106	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	219240	
107	Bibiyana South 400 MW	PDB	400 MW	383	311	7451800	Gas shortage
Sylhet Area Total				2377	1716	40123467	
108	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	
**	Bheramara (HVDC)	Imported power	2*500	1000	894	21723636	
109	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	115	0	0	Contract Expired
110	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	20	295200	Engine problem
111	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	100	452723	Low demand
112	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
113	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	395	9027360	FGMO
114	Noapara 40 MW PP (Khanjahan Ali)	ORPP	5*8.5	40	0	0	Contract Expired
115	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	100	689280	
116	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	90	1568640	Engine problem
117	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1599	33756839	
118	Barisal 110 MW RP (Summit)	IPP	7*17.076	110	0	4416	Line O/L
119	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	30	565997	
120	Bhola 225 MW CCGP	PDB	2*63+1*68	194	84	2032309	Machine problem
121	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	11	291012	Gas shortage
122	Payra 1320 MW	BCPCL	2*622	1244	500	11572000	Line O/L
	Bhola Nutan Biddut BD LTD	IPP	220	0	221	4551500	On Test
123	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line O/L
Barisal Area Total				1826	846	19017234	
124	Baghabari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage.
125	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	1217632	
126							