

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

| Date : 20-Jun-21      |                                  |                 |                     | Page -2  |                      |                  |                              |
|-----------------------|----------------------------------|-----------------|---------------------|----------|----------------------|------------------|------------------------------|
| No.                   | Name of the Power Stations       | Producer        | Installed Capacity  | Capacity | Peak Hour Generation | Energy Generated | Remarks                      |
|                       |                                  |                 | Unit No. X Capacity | MW       | MW                   | KWH              |                              |
| 1                     | Ghorasal Repowered CCPP Unit-2   | PDB             | 1*260               | 260      | 0                    | 0                | Under maint.                 |
| 2                     | Ghorasal Repowered CCPP Unit-3   | PDB             | 1*210               | 180      | 0                    | 0                | Under maint.                 |
| 3                     | Ghorasal TPP Unit-5              | PDB             | 1*210               | 190      | 185                  | 4378500          |                              |
| 4                     | Ghorasal 365 MW CCPP Unit-7      | PDB             | 1*243+1*122         | 365      | 0                    | 0                | Under maint.                 |
| 5                     | Ghorasal 78.5 MW PP(RUAG)        | QRPP            | 2*40                | 0        | 0                    | 0                | Contract Expired             |
| 6                     | Ghorasal 108MW PP (Regent)       | IPP             | 34*3.35             | 108      | 99                   | 1565045          |                              |
| 7                     | Haripur GTTP                     | SBU, PDB        | 2*32                | 20       | 0                    | 0                | Under maint.                 |
| 8                     | Haripur 412 MW CCPP              | EGCB            | 1*273+1*139         | 412      | 283                  | 7871490          | FGMO                         |
| 9                     | Haripur 360MW CCPP(HPL)          | IPP             | 1*235+1*125         | 360      | 230                  | 6280000          | Gas shortage                 |
| 10                    | Meghnaghat 450 MW CCPP(MPL)      | IPP             | 2*150+1*150         | 450      | 300                  | 7106000          | Gas shortage                 |
| 11                    | Meghnaghat 100 MW(IEI)           | QRPP            | 12*8.9              | 100      | 0                    | 0                | Contract Expired             |
| 12                    | Meghnaghat CCPP(Summit)          | IRPP            | 2*110+1*110         | 305      | 285                  | 6609949          | Gas shortage                 |
| 13                    | Madanganj 102 PP(Summit)         | QRPP            | 6*17                | 0        | 0                    | 0                | Contract Expired             |
| 14                    | Madanganj-55 MW PP(Summit)       | (IPP)           | 3*17.08+1*11.3      | 55       | 30                   | 100785           | Low demand                   |
| 15                    | Keranganj 100 MW PP (Poweres)    | QRPP            | 8*13.45             | 100      | 72                   | 59415            | Engine problem               |
| 16                    | Narshingdi 22 MW PP (Doreen)     | SIPP, REB       | 8*2.90              | 22       | 19                   | 359748           |                              |
| 17                    | 210 MW Siddhirgonj TPP           | PDB             | 1*210               | 115      | 0                    | 0                | Under maint.                 |
| 18                    | Siddhirgonj 2*120 MW GTTP        | EGCB            | 2*105               | 210      | 0                    | 0                | Gas shortage                 |
| 19                    | Siddhirgonj 100 PP(Dutch Bangla  | QRPP            | 12*8.9              | 100      | 100                  | 1331866          |                              |
| 20                    | Siddhirgonj 335 MW CCPP          | EGCB            | 1*217+1*118         | 335      | 190                  | 4341984          | Gas shortage                 |
| 21                    | Gangagar 102 MW PP (Digital Po   | IPP             | 12*8.924            | 102      | 102                  | 1101312          |                              |
| 22                    | Katpali 52 MW PP (Siraha)        | IPP             | 7*7.9               | 51       | 0                    | 0                | Fuel shortage                |
| 23                    | Kamalaghat 54 MW PP(Banco En     | IPP             | 3*18                | 54       | 54                   | 1065600          |                              |
| 24                    | Kodda 150MW PP                   | BPDB-RPCL       | 9*17.06             | 149      | 120                  | 998880           | Engine problem               |
| 25                    | Manikganj 55 MW PP (Northern)    | IPP             | 3*19.3              | 55       | 55                   | 98438            |                              |
| 26                    | Nababganj 55 MW PP (Southern)    | IPP             | 3*19.3              | 55       | 55                   | 824914           |                              |
| 27                    | Bosila 108MW PP(RPCL)            | IPP             | 12*8.775+1*3.5      | 108      | 0                    | 0                | Fuel shortage                |
| 28                    | Summit Power (Madhabadi-Ashuli   | SIPP, REB       | 3*3.67+4*8.73       | 80       | 45                   | 1293540          | Engine problem               |
| 29                    | Maona 33 MW PP(Summit)           | SIPP, REB       | 4*8.73              | 33       | 33                   | 774900           |                              |
| 30                    | Rupganj 33 MW PP(Summit)         | SIPP, REB       | 4*8.73              | 33       | 33                   | 828800           |                              |
| 31                    | Gazipur 52 MW PP                 | IRPP            | 6*8.9               | 52       | 42                   | 683520           | Engine problem               |
| 32                    | Tongi 80 MW GTTP                 | PDB             | 1*105               | 105      | 0                    | 0                | Under maint.                 |
| 33                    | Kodda 300 MW PP Unit-2 (Summ     | IRPP            | 18*17.076           | 300      | 145                  | 863127           | Low demand                   |
| 34                    | Keranganj 300 MW PP (APR)        | IRPP            | 25*11.4             | 300      | 0                    | 0                | Reserve.                     |
| 35                    | Bramhangaan 100 MW PP (Aggr      | IRPP            | 100                 | 100      | 0                    | 0                | Reserve.                     |
| 36                    | Aurahati 100MW PP (Aggreko)      | IRPP            | 0.85*23+0.95*91     | 100      | 0                    | 0                | Reserve.                     |
| 37                    | Kodda 149 MW PP Unit-1 (Summ     | IRPP            | 149                 | 149      | 25                   | 636048           | Low demand                   |
| 38                    | Gazipur 100 MW PP                | RPCL            | 100 MW              | 105      | 90                   | 1791600          | Engine problem               |
| 39                    | Meghnaghat 104 MW PP (OPCL)      | IRPP            | 18.5*6              | 104      | 53                   | 116160           | Low demand                   |
| 40                    | Manikganj 162MW PP(MPGL)         | IPP             | 9*18                | 162      | 126                  | 767520           | Engine problem               |
| 41                    | Spectra Solar Plant Ltd.         | IPP             | 35                  | 35       | 0                    | 61147            |                              |
| Dhaka area Total      |                                  |                 |                     | 5919     | 2771                 | 51910288         |                              |
| 42                    | Chattogram TPP-1                 | PDB             | 1*210               | 180      | 100                  | 2400000          | Gas shortage                 |
| 43                    | Chattogram TPP-2                 | PDB             | 1*210               | 180      | 0                    | 0                | Gas shortage                 |
| 44                    | Razzan 25 MW PP                  | IRPP            | 3*8.9               | 25       | 17                   | 407685           | Engine problem               |
| 45                    | Teknaf 20MW PP (Solartech)Teknaf | Solartech Energ | 20                  | 20       | 0                    | 70335            |                              |
| 46                    | Patenga 50MW PP (Baraka)         | IPP             | 8*6.98              | 50       | 44                   | 101760           |                              |
| 47                    | Kaptai Hydro. Unit-1,2,3,4, 5    | PDB             | 2*40+3*50           | 230      | 25                   | 604000           | Low water level & Unit-2 und |
| 48                    | Sikalbaha 225MW                  | PDB             | 1*150+1*175         | 225      | 203                  | 4872160          | FGMO                         |
| 49                    | Sikalbaha Peaking GT             | PDB             | 1*150               | 150      | 100                  | 1892100          | Machine problem              |
| 50                    | Sikalbaha 105 MW PP (Baraka S    | IRPP            | 105 MW              | 105      | 105                  | 1906072          |                              |
| 51                    | Hathazari 100 MW peaking PP      | PDB             | 11*8.9              | 98       | 0                    | 0                | Under S/D                    |
| 52                    | Dohazari-Kalesh 100 MW Peaker    | PDB             | 6*17                | 102      | 87                   | 551086           | Low demand                   |
| 53                    | Juddah 100 MW Unit-1 (Acom)      | QRPP            | 8*13.45             | 100      | 100                  | 1689720          |                              |
| 54                    | Juddah 100 MW PP Unit-3 (Acom)   | IRPP            | 0                   | 100      | 100                  | 498240           |                              |
| 55                    | Barabkunda 22 MW PP (Regent)     | SIPP, PDB       | 8*2.90              | 22       | 22                   | 517200           |                              |
| 56                    | * Malancha, Cig. EP2 (United)    |                 | 5*8.73+3*9.34       | 0        | 10                   | 379200           |                              |
| 57                    | Chattogram 108 MW PP (ECPV)      | IRPP            | 16*7                | 108      | 0                    | 0                | Fuel shortage                |
| 58                    | Kaptai 7 MW Solar PP             | PDB             | 7.4 MW              | 7        | 0                    | 11400            |                              |
| 59                    | Anwara 300 MW PP (United)        | IRPP            | 300 MW              | 300      | 0                    | 0                | Reserve.                     |
| 60                    | Jodda Power                      | IRPP            | 3*18.55+1*3.6       | 54       | 54                   | 1301298          |                              |
| 61                    | Karnaphuli Power Ltd.            | IRPP            | 110                 | 110      | 68                   | 1042940          | Low demand                   |
| 62                    | Juddah unit-2 (Acom)             | IRPP            | 8*13.6              | 100      | 30                   | 150720           | Transformer O/L              |
| 63                    | Anilma Energy Ltd.               | IRPP            | 6*21.2              | 116      | 0                    | 0                | Transformer O/L              |
| Chattogram area Total |                                  |                 |                     | 2382     | 1065                 | 18395916         |                              |
| 64                    | Ashuganj TPP Unit- 3             | APSCL           | 1*150               | 135      | 80                   | 2076000          | Gas Shortage                 |
| 65                    | Ashuganj TPP Unit- 4             | APSCL           | 1*150               | 129      | 0                    | 0                | Gas shortage                 |
| 66                    | Ashuganj TPP Unit- 5             | APSCL           | 1*150               | 134      | 0                    | 0                | Under maint.                 |
| 67                    | Ashuganj 225 MW CCPP             | APSCL           | 1*142+1*175         | 221      | 183                  | 4711000          | Gas shortage                 |
| 68                    | Ashuganj 450 MW CCPP(North)      | APSCL           | 1*360               | 360      | 265                  | 6862000          | Gas shortage                 |
| 69                    | Ashuganj 450 MW CCPP(South)      | APSCL           | 1*360               | 360      | 295                  | 7083000          | Gas shortage                 |
| 70                    | Ashuganj 50 MW PP                | APSCL           | 14*3.968            | 45       | 26                   | 592272           | Engine problem               |
| 71                    | Ashuganj 55 MW PP (Precision)    | RPP             | 15*4                | 55       | 52                   | 1217760          | Gas shortage                 |
| 72                    | Ashuganj 195MW PP (APSCL-Un      | IRPP            | 20*9.73+1*16        | 195      | 8                    | 418181           | Gas shortage                 |
| 73                    | Ashuganj 51 MW PP (Midland)      | IPP             | 6*9.34              | 51       | 51                   | 598057           |                              |
| 74                    | Ashuganj 150MW PP (Midland)      | IRPP            | 23*7.015            | 150      | 30                   | 205745           | Low demand                   |
| 75                    | Titas 50 MW Peaking PP           | PDB             | 6*9.92              | 52       | 38                   | 59040            | Low demand                   |
| 76                    | Chandpur 150 MW CCPP             | PDB             | 1*106+1*57          | 163      | 86                   | 2125550          | ST under maint               |
| 77                    | Chandipur 200MW (Desh energy)    | IPP             | 0                   | 200      | 160                  | 3282240          | Engine problem               |
| 78                    | Feni 22MW PP (Doreen)            | SIPP, PDB       | 8*2.90              | 22       | 19                   | 426204           |                              |
| 79                    | Feni 11 MW PP (Doreen)           | SIPP, REB       | 4*2.90              | 11       | 11                   | 207360           |                              |
| 80                    | ** Imporrit (Tripura)            | Imported power  | 0                   | 160      | 112                  | 2448000          | Bad weather.                 |
| 81                    | Jangalia 33MW PP (Summit)        | SIPP, PDB       | 4*8.73              | 33       | 33                   | 799000           |                              |
| 82                    | Jangalia 52 MW PP (Lakdanav)     | IRPP            | 6*8.92              | 52       | 25                   | 791174           | Engine problem               |
| 83                    | 71 Cima 25 MW PP (Summit)        | SIPP, PDB       | 3*3.67+2*6.97       | 25       | 21                   | 472190           | Engine problem               |
| 84                    | Davidkandi 200 MW PP (B.Trac)    | IRPP            | 15*11.4             | 200      | 0                    | 0                | Reserve.                     |
| 85                    | Feni Lanka Power                 | IRPP            | 7*18.415+1*9.78     | 114      | 100                  | 951900           | Engine problem               |
| 86                    | Chowmuhani 113 MW                | IRPP            | 12*9.78+2*3.1       | 113      | 121                  | 2806440          |                              |
| 87                    | Bhairab 54.5 MW                  | IRPP            | 3*18.2              | 54       | 35                   | 542880           | 33 KV feeder fault.          |
| Cumilla Area Total    |                                  |                 |                     | 3034     | 1751                 | 38676053         |                              |
| 88                    | RPCL 210MW CCPP                  | IRPP            | 4*35+1*70           | 202      | 158                  | 3792040          | Gas shortage                 |
| 89                    | Tangail 22 MW PP (Doreen)        | SIPP, PDB       | 8*2.90              | 22       | 21                   | 493440           |                              |
| 90                    | Jamalpur 95 MW PP(Powerpac)      | IRPP            | 12*8.924            | 95       | 8                    | 177600           | Engine problem               |
| 91                    | Sarishabari 3 MW Solar Plant     | IRPP            | 1*3                 | 3        | 0                    | 5001             |                              |
| 92                    | Mymensingh 200 MW PP (Unite      | IRPP            | 200                 | 200      | 110                  | 868800           | Low demand                   |
| 93                    | Jamalpur 115 MW PP (Unite)       | IRPP            | 115 MW              | 115      | 115                  | 2398800          |                              |
| 94                    | Sultakhal 50 MW Solar PP         | IRPP            | 50                  | 50       | 0                    | 187340           |                              |
| 95                    | Tangail Pali Power Gen 22 MW     | IRPP            | 4*6.7               | 22       | 24                   | 356400           |                              |
| Mymensingh Area Total |                                  |                 |                     | 709      | 436                  | 8268289          |                              |
| 96                    | Fenchugonj CCPP Phase-1          | PDB             | 2*32+1*33           | 70       | 10                   | 76000            |                              |
| 97                    | Fenchugonj CCPP Phase-2          | PDB             | 2*35+1*35           | 90       | 42                   | 984360           | Machine problem              |
| 98                    | Kushiara 163 MW CCPP (KP)        | IRPP            | 1*109+1*54          | 163      | 130                  | 3402327          |                              |
| 99                    | Shajibazar 330 MW CCPP           | PDB             | 3*110               | 330      | 164                  | 3603000          | GT-1 under maint             |
| 100                   | Fenchugonj 51 MW PP (Barakati    | RPP             | 19*2.90             | 51       | 53                   | 1105800          |                              |
| 101                   | Fenchugonj 44MW (Energyprima     | RPP             | 12*3.3+5*2          | 0        | 0                    | 0                | Contract Expired             |
| 102                   | Hobiganj 11MW PP Confidence-E    | SIPP, REB       | 4*2.90              | 11       | 11                   | 258048           |                              |
| 103                   | Shajibazar GTTP Unit- 8 & 9      | PDB             | 2*35                | 66       | 62                   | 1474560          |                              |
| 104                   | Shajibazar 86MW PP (Shajibaza    | RPP             | 32*2.90             | 86       | 81                   | 1764480          |                              |
| 105                   | Shajibazar 100 MW GTTP           | PDB             | 1*100               | 100      | 0                    | 0                | Under Shut down              |
| 106                   | Sylhet 225 MW CCPP               | PDB             | 1*142+1*99          | 231      | 218                  | 4940680          |                              |
| 107                   | Sylhet 20 MW GTTP                | PDB             | 1*20                | 20       | 18                   | 400000           |                              |
| 108                   | Sylhet 50MW PP (EPL)             | RPP             | 27*2                | 0        | 0                    | 0                | Contract Expired             |
| 109                   | Shahjahanulla 25 MW PP           | SIPP, REB       | 3*9.34              | 25       | 16                   | 390576           | Engine problem               |
| 110                   | Biliana-II 341 MW CCPP (Summ     | IRPP            | 1*222+1*119         | 341      | 270                  | 7109000          | FGMO                         |
| 111                   | Biliana-III 400 MW CCPP          | PDB             | 400 MW              | 400      | 366                  | 8430000          | FGMO                         |
| 112                   | Sylhet 10MW PP (Desh)            | RPP             | 6*1.95              | 10       | 10                   | 230040           |                              |
| 113                   | Bilayana South 400 MW            | PDB             | 400 MW              | 383      | 400                  | 9074800          |                              |
| Sylhet Area Total     |                                  |                 |                     | 2377     | 1851                 | 43243671         |                              |
| 114                   | Bheramara GTTP Unit-3            | PDB             | 1*20                | 16       | 0                    | 0                |                              |
| 115                   | ** Bheramara (HVDC)              | Imported power  | 2*500               | 1000     | 880                  | 21278545         |                              |
| 116                   | Khuila 115 PP MW (KPCL-2)        | QRPP            | 7*17                | 115      | 0                    | 0                | Contract Expired             |
| 117                   | Faridpur 50 MW Peaking PP        | PDB             | 8*6.89              | 54       | 0                    | 0                | Reserve.                     |
| 118                   | Khuila 225 MW CCPP               | NWPGCL          | 1*150+1*75          | 230      | 0                    | 0                | Reserve.                     |
| 119                   | Gopalganj 100 MW Peaking PP      | IRPP            | 12*8.95             | 100      | 0                    | 0                | Reserve.                     |
| 120                   | Bheramara 410 MW CCPP            | NWPGCL          | 1*278+1*132         | 410      | 350                  | 8070048          | FGMO                         |
| 121                   | Noapara 40 MW PP (Khanjahan A    | QRPP            | 5*8.5               | 40       | 0                    | 0                | Contract Expired             |
| 122                   | Noapara 100 MW PP (Bangla Tr     | IRPP            | 70*1.4              | 100      | 0                    | 0                | Reserve.                     |
| 123                   | Rupsha 105 MW PP (Orion rupsh    | IRPP            | 6*18.44             | 105      | 85                   | 493440           | Engine problem               |
| 124                   | Madhumati 100 MW PP              | NWPGCL          | 100 MW              | 105      | 0                    | 0                | Reserve.                     |
| Khuila Area Total     |                                  |                 |                     | 2284     | 1315                 | 29842033         |                              |
| 125                   | Barsail 110 MW PP (Summit)       | IRPP            | 7*17.076            | 110      | 0                    | 0                | Line O/L                     |
| 126                   | Bhola 33 MW PP (Venture)         | RPP             | 1*34.50             | 33       | 25                   | 497000           | Engine problem               |
| 127                   | Bhola 225 MW CCPP                | PDB             | 2*63+1*68           | 194      | 86                   | 2079345          | Machine problem              |
| 128                   | Bhola 95 MW PP (Aggreko)         | QRPP            | 9*6*1.10            | 95       | 12                   | 298623           | Gas shortage                 |
| 129                   | Payra 1320 MW                    | BCPCL           | 2*622               | 1244     | 340                  | 9232400          |                              |
| 130                   | Bhola Nutan Biddut BD LTD        | IRPP            | 220                 | 0        | 202                  | 3478900          | On Test                      |
| 131                   | United Payra Power Ltd.          | IPP             | 8*18.5+1*9.5        | 150      | 0                    | 0                | Line O/L                     |
| Barisal Area Total    |                                  |                 |                     | 1826     | 665                  | 15586268         |                              |
| 132                   | Baghabari 71 MW GTTP             | PDB             | 1*71                | 71       | 50                   | 1185000          | Gas shortage                 |
| 133                   | Baghabari 100 MW GTTP            | PDB             | 1*100               | 100      | 0                    | 0                | Gas shortage.                |
| 134                   | Baghabari 50 MW Peaking PP       | PDB             | 6*8.9               | 52       | 18                   | 191914           |                              |
| 135                   | Bera 70 MW Peaking PP            | PDB             | 9*8.29              | 71       | 10                   | 36484            | Low demand                   |
| 136                   | Amnura 50 MW PP(Siraha)          | QRPP            | 7*7.79              | 50       | 35                   | 56480            | Engine problem               |
| 137                   | Katakhal 50 MW PP (Northern)     | QRPP            | 6*8.9               | 50       |                      |                  |                              |