

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month June, 2021				Day : Monday				Date : 21.06.21			
Probable Maximum Demand : 12900 MW				Probable Maximum Generation : 15113 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.74 ft.	Today = 75.09 ft.	Rule Curve = 81.30 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.06.21 (Yesterday)		21.06.21 (Today)		20.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasah 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	86	99	100	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	211	230	250	250	130	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	349	283	300	300	129	Under maint.
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	221	190	220	220		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	50	100	100	100		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	280	285	285	300		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	55	55		
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	72	70	75		
17	Gargnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	64	102	100	102		
18	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	16	19		
19	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	56	45	55	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	42	42	42		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	88	90		
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	120	133	150		
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	145	250	250		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	33	25	130	130		
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300		
30	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	0	100	100		
31	Auralah 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	0	100	100		
32	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55		
34	Bosila 108MW PP(RCLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	53	90	90		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	126	126	126		
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	3	0	30	0		
Dhaka Zone Total				5976	5819	2218	2771	3455	3669	490	1174
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0	0		
41	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	8	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	44	40	45		
44	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	100	100		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	207	203	220	220		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300		
48	Judah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	50	100	100	100		
49	Judah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	10	100	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	87	100	100		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	10	10	20		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	68	110	110		
56	Judah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	30	100	100		
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	0	116	116		
Chattogram Zone Total				2442	2382	737	1065	1644	1634	205	180
58	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	80	80	80	55	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1175	221	221	199	183	220	220		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	315	295	300	330		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	295	265	310	330		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	51	52	55	55		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+11'6	195	195	8	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	51	30	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	30	120	130		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	38	0	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	86	90	90		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	155	160	160	160		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdhanvi)	HFO (IPP)	6x8.92	52	52	25	25	25	25		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	21	17	21		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x11.4+8x1.915+1x1.915	200	200	0	0	100	200		
76	Feni 11.4 MW Power Plant(Lakdhanvi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	100	100	100		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	120	121	113	113		
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	18	35	35	35		
**	Impport (Tripura)	India		160	160	106	112	151	180		
Cumilla Zone Total				3094	3034	1606	1751	2006	2270	505	0
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	150	158	160	170	44	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	65	115	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	110	175	175		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	36	0	50	0		
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	24	24	22	22		
Mymensingh Zone Total				717	709	297	436	553	511	44	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.06.21 (Yesterday)		21.06.21 (Today)		20.06.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	10	10	10		60	Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
89	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	62	62	62				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	164	164	162	164				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	81	81	83				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	219	218	192	225				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	15	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	270	341	341				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	384	366	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	393	400	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total						2422	2377	1924	1851	1958	1996	0	108
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	290	350	380	400		60	Gas Shortage	
105	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20				
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	50	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	85	90	90				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
Bheramara (HVDC) India						1000	1000	881	880	895	895		
Khulna Zone Total						2133	2129	1171	1315	1595	1885	60	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	18	25	25	25				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	86	85	86		108	GT-2 & STG Under	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	12	12	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	340	622	622				
116	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110				
Bhola Nutan Biddut BD LTD								120	202	220	220		
Barishal Zone Total						1826	1826	536	665	1073	1184	0	108
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	60	50	50	50		21	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	18	50	50				
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	30	40				
121	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	35	35	35				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	5	86	90	100				
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	40	40				
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	35				
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		150	Gas Shortage, STG S/D	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	142	130	200	200				
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	138	165	200	200				
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	404	370	400	400				
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	5	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	100	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	55	90	90				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
Rajshahi Zone Total						2179	2179	766	1177	1632	1681	271	0
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150		124	Coal Shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	95	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Maipara, Tatula 6 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 6	6	6	4	0	8	0				
Rangpur Zone Total						685	605	154	245	271	283	294	0
Sub-total: Plants in operation						21474	21060	9409.0	11276	14187	15113	1869	1570
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								9096	10901	13715	14610		
(B) Plants under long term maintenance/ contract expired													
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
147	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0				Contract Expired on 28/05/2021
Sub-Total: Plants under long term maintenance/ contract expired						549	0	0	0	0	0		
Gross Total						22023	21060	9409	11276	14187	15113	1869	1570
(C) Actual data of 20.06.21 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	11276.00	MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10901.00	MW, at = 19:30 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11276.00	MW, at = 19:30 hrs									
04.	Minimum Generation (Generation end)	:	7929.00	MW, at = 7:00 hrs		Dhaka	4053	4053	0	Mymensingh	894	894	0
05.	Day-peak Generation (Generation end)	:	9409.00	MW, at = 12:00 hrs		Chattogram	1203	1203	0	Sylhet	427	427	0
06.	Evening-peak Generation (Generation end)	:	11276.00	MW, at = 19:30 hrs		Khulna	1220	1220	0	Barishal	280	280	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 19:30 hrs		Rajshahi	1063	1063	0	Rangpur	751	751	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8241.00	MW, at = 5:00 hrs		Cumilla	1010	1010	0				
09.	Generation shortfall at evening peak due to :	:								Total	10901	10901	0
	a) Gas limitation	:	1370	MW		13.	Fuel cost :	(a) Gas = 160236695 Taka	(c) Coal = 60473126 Taka				
	d) Coal supply Limitation	:	294	MW				(b) Oil = 294653743 Taka	Total = 515363564 Taka				
	b) Low water level in Kaptai lake	:	205	MW									
	c) Plants under shut down/ maintenance	:	1570	MW									
10.	Total Energy (Generation + India Import)	:	230.31	MKWh		14.	Maximum Temperature in Dhaka was :	27.9° C					
	By Gas = 152.501 MKWh			By Oil = 40.203 MKWh		15.	Export through East-West interconnections :						
	By Coal = 12.912 MKWh			By Hydro = 0.604 MKWh			At evening peak-hour	-81 MW, at 19:30 hrs					
	By Solar= 0.388 MKWh						Maximum	-81 MW, at 19:30 hrs					
11.	Total Gas Supplied	:	1228.05	MMCFD			Energy	0.2995 MKWh					
(D) Forecast of 21.06.21 (Today) Monday :													
01.	Maximum Demand	:	12900	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15113	MW (Generation end)	05.	Total Generation	:	263.48	MKWh				
03.	Maximum Shortage	:	-2213	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	33.2° C					
* Captive Power, ** Imported Power													

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)
Deputy Secretary, Generation