

20:00 Hrs on 27-Apr-21

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Gas Consumed :	Total =	1264.97 MMCFD.		Oil Consumed (PDB) :				
						HSD :		Liter
						FO :		Liter
Cost of the Consumed Fuel (PDE	Gas :		Tk168,126,603					
	Coal :		Tk62,518,874	Oil :	Tk404,508,274	Total :	Tk635,153,750	

Area	Yesterday		Estimated Demand (S/S end)	Today	
	MW			Estimated Shedding (S/S end)	Rates of Shedding (On Estimated Demand)
Dhaka	0	0:00	4637	0	0%
Chittagong Area	0	0:00	1582	0	0%
Khulna Area	0	0:00	1418	0	0%
Rajshahi Area	0	0:00	1282	0	0%
Cumilla Area	0	0:00	1158	0	0%
Mymensingh Are	0	0:00	935	0	0%
Sylhet Area	0	0:00	516	0	0%
Barisal Area	0	0:00	240	0	0%
Rangpur Area	0	0:00	721	0	0%
Total	0		12490	0	

Planned Shut-Down

Forced Shut-Down

- | | |
|-----------------------------|--|
| 1) Barapukuria ST: Unit-1,2 | |
| 2) Ghorasal-3,4 | |
| 3) Ashuganj-4 | |
| 4) Kaptai-2 | |
| 5) Raozan #2 | |
| 6) Bhola 225 MW GT-2 | |
| 7) Chandpur-150 MW ST | |

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

- | | |
|----|---|
| a) | Ashuganj 230 kV Bus-2 was under shut down from 09:00 to 18:00 for R/H maintenance. |
| b) | Maheasthanjir 132/33 kV T-1 transformer was under shut down from 08:18 to 09:58 for R/H maintenance. |
| c) | Kurigram 132/33 kV T-1 transformer was under shut down from 11:48 to 16:00 for tan delta test. |
| d) | Siddhiganj 33S MW CPPG GT was synchronized at 11:18. |
| e) | Shalpuj 132/33 kV T-2 transformer was under shut down from 10:08 to 13:15 for R/H maintenance at 33 kV Y-phase Bushing. |
| f) | Aminbaraz 230 kV Bus-2 was under shut down from 11:31 to 13:41 for 400 kV project work. |
| g) | Banani 132/33 kV T-1 transformer was charged at 16:26. |
| h) | Aminbaraz 400/230 kV ART-01 transformer was switched on at 16:26. |
| i) | Fairdipur-Bheramara 132 kV Ckt-1 was switched on at 17:50. |
| j) | Kamrangranchir-Zigatala 132 kV Ckt-1 & 2 was charged at 16:15 & 16:20 respectively from Kamrangranchir. |
| k) | Kurigram 132/33 kV T-2 transformer was under shut down from 11:48 to 16:00 for tan delta test. |
| l) | Ghorashal unit-7 GT was synchronized at 18:07. |
| m) | Payra Unit-2 was synchronized at 23:41. |
| n) | Payra Unit-1 was shutdown at 05:04(23/06/2021). |
| o) | Mymensingh-Mymensingh RPCL 132 kV Ckt-2 was shut down at 07:01(23/06/2021) for D/W. |

Executive Engineer
Network Operation Division

Superintendent Engineer
Load Despatch Circle