

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month June, 2021				Day : Thursday				Date : 24.06.21					
Probable Maximum Demand : 13200 MW				Probable Maximum Generation : 15802 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.22 ft.	Today = 75.28 ft.	23.06.21 (Yesterday)		24.06.21 (Today)		Rule Curve = 82.11 ft.			
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Actual Peak Generation (MW)		Probable Peak Generation (MW)		23.06.21 Gen. shortfall for : Gas/water/Coal limitation MW		Status of Machines under shut-down/ Maintenance	
						Day	Evening	Day	Evening	MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0		260	Under maint.	
a)	Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering	
b)	Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	190	190	200	200				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	92	97	100	100				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Under Maint.	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	207	226	350	360	134		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	347	338	350	380				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	215	220	220	220				
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	91	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	285	255	290	300				
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55				
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	10	70	100				
17	Gargnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	100	102				
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	18	22	22				
19	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	55	55	55	55				
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33				
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	28	51	51	51				
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	64	150	133	150				
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	300	281	290	290				
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	100	126	135	135				
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300				
30	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
31	Auralah 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
32	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	35	55	55				
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55				
34	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	104	90	104				
36	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	126	126	162				
37	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	31	0	30	0				
Dhaka Zone Total				5976	5819	2660	3295	3887	4206	494	680		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	24	24	51	51	206		Low Water Level	
a)	Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100				
b)	Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0				
41	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	12	40	45				
44	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	100	100				
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	213	203	220	220				
47	Anwara 300 MW Unit-1 (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300				
48	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	80	100	100	100				
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	70	100	100	100				
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	102	102				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	21	10	20				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	51	54	54	54				
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	99	110	110	110				
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	30	100	100	100				
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	17	116	116				
Chattogram Zone Total				2442	2382	925	1187	1672	1662	206	180		
58	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	100	80	100	35		Gas Shortage	
b)	Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
c)	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	26	26				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	196	182	220	220				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	280	295	315	330				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	285	310	325	330				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	49	54	55	55				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	36	36	36	36	159		Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	50	50				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	53	50	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	86	90	90				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	103	178	160	180				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdhanvi)	HFO (IPP)	6x8.92	52	52	34	34	34	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	17	21				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x11.4+8x1.915+1x1.088	200	200	0	0	100	200				
76	Feni 11.4 MW Power Plant(Lakdhanvi)	HFO (IPP)	7*18.415+1*9.78	114	114	70	100	100	100				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	1	115	113	113				
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	18	36	35	35				
**	Impport (Tripura)	India		160	160	100	132	151	180				
Cumilla Zone Total				3094	3034	1566	1919	2123	2375	457	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	114	153	120	150	49		Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115				
83	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	150	175	175	192				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	56	0	50	0				
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	24	24	22	22				
Myensingh Zone Total				717	709	491	496	513	508	49	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.06.21 (Yesterday)		24.06.21 (Today)		23.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	44	44		26	Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
89	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	62	62				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	160	164	162	164				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	84	84	84				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	189	131	192	225				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	15	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	341	341				
100	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	381	367	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	385	400	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total						2422	2377	1910	1845	1995	2031	0	74
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	380	385	380	380				
105	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20				
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	160				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	100	50	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	6	91	90	90				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	888	793	923	923				
Khulna Zone Total						2133	2129	1274	1369	1623	1833	0	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	33	25	25				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	83	85	86		111	GT-2 & STG Under	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	12	12	12	12				
115	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	370	550	622	622				
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110				
Bhola Nutan Biddut BD LTD								203	221	220	220		
Barishal Zone Total						1826	1826	688	899	1074	1185	0	111
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	60	40	65	65	31		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	50	50				
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	34	30	40				
121	Amnura 50 MW PP (Sinthe)	HFO (QRPP)	7x7.79	50	50	0	35	35	35				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	54	95	90	100				
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	40	40				
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	24	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	35				
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	150		Gas Shortage, STG S/D	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	165	183	200	200				
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	174	188	200	200				
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	405	360	400	400				
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total						2179	2179	972	1338	1670	1719	281	0
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Maipara, Tatula 6 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 6	6	6	0	0	8	0				
Rangpur Zone Total						685	605	190	263	271	283	294	0
Sub-total: Plants in operation						21474	21060	10676.0	12611	14828	15802	1781	1045
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								10143	11981	14087	15013		
(B) Plants under long term maintenance/ contract expired													
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
147	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0				Contract Expired on 28/05/2021
Sub-Total: Plants under long term maintenance/ contract expired						549	0	0	0	0	0		
Gross Total						22023	21060	10676	12611	14828	15802	1781	1045
(C) Actual data of 23.06.21 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	12611.00 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11981.00 MW, at =	21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12611.00 MW, at =	21:00 hrs									
04.	Minimum Generation (Generation end)	:	8988.00 MW, at =	7:00 hrs		Dhaka	4267	4267	0	Mymensingh	975	975	0
05.	Day-peak Generation (Generation end)	:	10676.00 MW, at =	12:00 hrs		Chattogram	1294	1294	0	Sylhet	481	481	0
06.	Evening-peak Generation (Generation end)	:	12611.00 MW, at =	21:00 hrs		Khulna	1384	1384	0	Barishal	353	353	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at =	21:00 hrs		Rajshahi	1292	1292	0	Rangpur	791	791	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9434.00 MW, at =	5:00 hrs		Cumilla	1144	1144	0				
09.	Generation shortfall at evening peak due to :	:								Total	11981	11981	0
	a) Gas limitation	:	1281 MW			13.	Fuel cost :	(a) Gas = 172465229 Taka	(c) Coal = 67555037 Taka				
	d) Coal supply Limitation	:	294 MW					(b) Oil = 426933765 Taka	Total = 666954030 Taka				
	b) Low water level in Kaptai lake	:	206 MW										
	c) Plants under shut down/ maintenance	:	1045 MW										
10.	Total Energy (Generation + India Import)	:	261.16 MKWh			14.	Maximum Temperature in Dhaka was :	33.7° C					
	By Gas = 164.642 MKWh		By Oil = 57.218 MKWh			15.	Export through East-West interconnections :						
	By Coal = 14.524 MKWh		By Hydro = 0.770 MKWh				At evening peak-hour	-168 MW, at 21:00 hrs					
	By Solar = 0.744 MKWh						Maximum	-168 MW, at 21:00 hrs					
11.	Total Gas Supplied	:	1303.26 MMCFD				Energy	0.563 MKWh					
(D) Forecast of 24.06.21 (Today) Thursday :													
01.	Maximum Demand	:	13200 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)					
02.	Maximum Generation	:	15802 MW (Generation end)		05.	Total Generation	:	273.36 MKWh					
03.	Maximum Shortage	:	-2602 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	32.7° C					
* Captive Power, ** Imported Power													

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)
Deputy Secretary, Generation