

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month June, 2021				Day: Sunday				Date: 27.06.21					
Probable Maximum Demand : 13600 MW				Probable Maximum Generation : 15612 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.55 ft.	Today = 75.67 ft.	Rule Curve = 82.92 ft.							
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.06.21 (Yesterday)		27.06.21 (Today)		26.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Machines shut down (MW)			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW		Description/ Remarks	Probable start-up date
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	190	190	200	200				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	97	101	100	100				
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	242	220	200	200	140	Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	347	338	0	350				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	210	222	220	220				
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	280	250	300	300				
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55				
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	70	70	100				
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	102	100	102				
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	21	22	22				
19	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	54	55	55	55				
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	27	51	51				
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	110	150	150	150				
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	40	54	54	54				
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	9	276	250	280				
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	65	131	149	149				
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300				
30	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	0	100	100				
31	Auralah 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	0	100	100				
32	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55				
34	Bosila 108MW PP(RCLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	104	90	104				
36	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	104	126	126	126				
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	13	0	30	0				
Dhaka Zone Total				5976	5819	2693	3358	3388	3984	500	680		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	26	25	25	25	205	Low Water Level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	6	0	5	0				
41	Raczan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	44	40	45				
44	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	100	100				
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	138	131	130	140				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	200	300				
48	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	92	100	100	100				
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	70	100	100	100				
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	23	10	30				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	95	96	97	97				
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	54	54				
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	65	110	110	110				
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	30	100	100	100				
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	116	116	116	116				
Chattogram Zone Total				2442	2382	983	1282	1527	1637	205	180		
58	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	135	135	100	135	0	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	26	26				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	196	218	220	220				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	290	310	330	350				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	200	330				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	48	55	55	55				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	55	177	102	36	18	Gas shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	50	50				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	81	56	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	86	90	90				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	94	200	170	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	19	19				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
73	Jangalia 52 MW PP (Lakdhanvi)	HFO (IPP)	6x8.92	52	52	24	34	34	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x11.4+8x1.915+1x1.081	200	200	0	0	100	200				
76	Feni 11.4 MW Power Plant(Lakdhanvi)	HFO (IPP)	7*18.415+1*9.78	114	114	90	100	100	100				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	107	106	113	113				
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	35	35				
**	Impport (Tripura)	India		160	160	108	134	151	180				
Cumilla Zone Total				3094	3034	1499	1861	2110	2447	281	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	151	147	150	130	55	Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	70	198	175	200				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	19	0	50	0				
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	23	24	22	22				
Mymensingh Zone Total				717	709	409	513	543	496	55	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.06.21 (Yesterday)		27.06.21 (Today)		26.06.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	44	44		27	Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
89	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	62	62	62				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	161	162	162	164				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	84	84	84				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	218	218	225	225				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	341	341				
100	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	346	364	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	15	400	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total						2422	2377	1514	1926	2029	2031	0	75
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	370	350	350	370				
105	Farpdur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	16	20	20				
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	160				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	100	50	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	90	90	91				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	893	898	918	918				
Khulna Zone Total						2133	2129	1263	1454	1588	1819	0	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	33	25	28				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	84	85	86		110	GT-2 & STG Under	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	12	12				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	390	500	622	622				
116	Polokhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	110				
Bhola Nutan Biddut BD LTD								150	220	220	220		
Barishal Zone Total						1826	1826	656	865	1074	1188	0	110
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	50	65	65	65				
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	60	65	65	65	35		Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	43	43				
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	36	30	40				
121	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	35	35	35				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	95	95				
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	40	40				
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0				
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	150		Gas Shortage, STG S/D	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	165	169	200	200				
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	195	160	200	200				
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	348	382	400	400				
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	42	42	42				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	0	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2179	2179	895	1416	1723	1727	185	0
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Maipara, Tatula 6 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 6	6	6	1	0	8	0				
Rangpur Zone Total						685	605	151	263	271	283	294	0
Sub-total: Plants in operation						21474	21060	10063.0	12938	14253	15612	1520	1045
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								9537	12262	13508	14796		
(B) Plants under long term maintenance/ contract expired													
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
147	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0				Contract Expired on 28/05/2021
Sub-Total: Plants under long term maintenance/ contract expired						549	0	0	0	0	0		
Gross Total						22023	21060	10063	12938	14253	15612	1520	1045
(C) Actual data of 26.06.21 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	12938.00	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12262.00	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12938.00	MW, at =	21:00 hrs	Dhaka	4360	4360	0	Mymensingh	1050	1050	0
04.	Minimum Generation (Generation end)	:	9213.00	MW, at =	8:00 hrs	Chattogram	1330	1330	0	Sylhet	489	489	0
05.	Day-peak Generation (Generation end)	:	10063.00	MW, at =	12:00 hrs	Khulna	1484	1484	0	Barisal	353	353	0
06.	Evening-peak Generation (Generation end)	:	12938.00	MW, at =	21:00 hrs	Rajshahi	1259	1259	0	Rangpur	786	786	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Cumilla	1151	1151	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9637.00	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:								Total	12262	12262	0
	a) Gas limitation	:	1021	MW		13.	Fuel cost :	(a) Gas = 174440914 Taka	(c) Coal = 65182358 Taka				
	d) Coal supply Limitation	:	294	MW				(b) Oil = 445896519 Taka	Total = 685519792 Taka				
	b) Low water level in Kaptai lake	:	205	MW									
	c) Plants under shut down/ maintenance	:	1045	MW									
10.	Total Energy (Generation + India Import)	:	261.73	MKWh		14.	Maximum Temperature in Dhaka was :	32.9° C					
	By Gas = 160.619 MKWh			By Oil = 61.516 MKWh		15.	Export through East-West interconnections :						
	By Coal = 13.987 MKWh			By Hydro = 0.526 MKWh			At evening peak-hour	: -98 MW, at 21:00 hrs					
	By Solar= 0.680 MKWh						Maximum	: -98 MW, at 21:00 hrs					
11.	Total Gas Supplied	:	1304.23	MMCFD			Energy	: 0.842 MKWh					
(D) Forecast of 27.06.21 (Today) Sunday :													
01.	Maximum Demand	:	13600	MW (Generation end)		04.	Maximum Load-shed	:	0	MW At evening peak (Sub-station end)			
02.	Maximum Generation	:	15612	MW (Generation end)		05.	Total Generation	:	275.12	MKWh			
03.	Maximum Shortage	:	-2012	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.6° C				
* Captive Power, ** Imported Power													

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)
Deputy Secretary, Generation