

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month June, 2021				Day : Monday		Date : 28.06.21							
Probable Maximum Demand : 13400 MW				Probable Maximum Generation : 15566 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.67 ft.	Today = 75.77 ft.	Rule Curve = 81.19 ft.							
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.06.21 (Yesterday)		28.06.21 (Today)		27.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW			
						Day	Evening	Day	Evening	Machines shut down (MW)			
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0		260	Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	190	190	200	200				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	93	98	100	100				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Under Maint.	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	207	201	250	250	159		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	30	350	350				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	208	214	0	220				
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	98	98	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	290	290	300	300				
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	55	55				
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	86	86	86				
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	102	100	102				
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	21	22	22				
19	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	33	53	55	55				
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	33	33	33				
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	24	51	51				
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	84	100	105	105				
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150				
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	52	276	250	280				
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	70	148	149	149				
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300				
30	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
31	Auralah 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	27	100	100				
32	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	104	90	104				
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	126	126	126	126				
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	29	0	30	0				
Dhaka Zone Total				5976	5819	2437	3108	3584	4020	519	680		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	26	25	25	25	205		Low Water Level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0				
41	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	8	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	46	40	45				
44	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	100	100				
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	138	133	130	140				
47	Anwara 300 MW Unit-1 (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	200	300				
48	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	92	100	100	100				
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	10	100	100	100				
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	68	68	68				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	22	10	30				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	74	25	97	97				
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	35	54	54				
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	50	100	100	100				
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	109	116	116	116				
Chattogram Zone Total				2442	2382	1071	1232	1527	1637	205	180		
58	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	100	80	100	135	55		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	26	26	26				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	210	214	220	220				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	310	300	330	350				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	200	295	350	360				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	55	55	55				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	83	45	45	100	150		Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	50	50				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	30	130	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	91	90	90	90				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	161	200	170	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	19	19				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33				
73	Jangalia 52 MW PP (Lakdhanvi)	HFO (IPP)	6x8.92	52	52	34	43	34	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	20	21	21				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x11.4+8x1.915+1x10.088	200	200	0	10	100	200				
76	Feni 11.4 MW Power Plant(Lakdhanvi)	HFO (IPP)	7*18.415+1*9.78	114	114	90	100	100	100				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	107	108	113	113				
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
**	Impport (Tripura)	India		160	160	126	138	151	180				
Cumilla Zone Total				3094	3034	1732	2049	2203	2541	468	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	116	150	154	154	52		Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	105	115	115				
83	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	120	186	175	200				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0				
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	23	24	22	22				
Myensingh Zone Total				717	709	460	494	547	520	52	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.06.21 (Yesterday)		28.06.21 (Today)		27.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	44	44			26	Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42			48	Under maint.	
89	Fenchugonj 51 MW PP (Barakattulah)	Gas (RPP)	19x2.90	51	51	47	53	51	51					
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	0	0	0					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	62	62					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	160	161	162	164					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	84	84	84					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	219	218	225	225					
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	341	341					
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	381	380	400	400					
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	395	400	400					
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total				2422	2377	1938	1783	1866	1868	0	74			
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	390	400	400	400					
105	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	5	15	20	20					
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60					
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	160					
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+5.15	100	100	0	100	50	100					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	91	90	91					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	902	901	916	916					
Khulna Zone Total				2133	2129	1314	1507	1636	1847	0	0			
111	Bansail 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	22	32	25	28					
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	84	86	85	86			108	GT-2 & STG Under	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	12	11	12	12					
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	340	530	622	622					
116	Potuaikhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	110					
Bhola Nutan Biddut BD LTD						180	221	220	220					
Barishal Zone Total				1826	1826	638	915	1074	1188	0	108			
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	60	65	65	65					
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	55	0	0	0			100	Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	43	43					
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	43	30	40					
121	Amnura 50 MW PP(Sinthe)	HFO (QRPP)	7x7.79	50	50	12	35	35	35					
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	88	94	95	95					
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	39	40	40					
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	43	43					
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0					
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			150	Gas Shortage, STG S/D	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	191	189	200	200					
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	200	191	200	200					
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	403	413	400	400					
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22					
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	43	42	42					
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113					
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	94	113	113					
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0					
Rajshahi Zone Total				2179	2179	1147	1441	1658	1662	250	0			
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Coal Shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150			124	Coal Shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	113	113	113					
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
141	Maipara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0					
Rangpur Zone Total				685	605	151	263	271	283	294	0			
Sub-total: Plants in operation				21474	21060	10888.0	12792	14366	15566	1788	1042			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10310	12113	13603	14740					
(B) Plants under long term maintenance/ contract expired														
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021	
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020	
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021	
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0				Contract Expired on 28/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired				549	0	0	0	0	0					
Gross Total				22023	21060	10888	12792	14366	15566	1788	1042			
(C) Actual data of 27.06.21 (Yesterday) Sunday :														
01.	Max. Demand at eve. peak (Generation end)	:	12792.00	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12113.00	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	12815.00	MW, at =	22:00 hrs	Dhaka	4330	4330	0	Mymensingh	999	999	0	
04.	Minimum Generation (Generation end)	:	9637.00	MW, at =	8:00 hrs	Chattogram	1239	1239	0	Sylhet	475	475	0	
05.	Day-peak Generation (Generation end)	:	10888.00	MW, at =	12:00 hrs	Khulna	1475	1475	0	Barishal	339	339	0	
06.	Evening-peak Generation (Generation end)	:	12792.00	MW, at =	21:00 hrs	Rajshahi	1355	1355	0	Rangpur	727	727	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Cumilla	1174	1174	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9856.00	MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:												
	a) Gas limitation	:	1289	MW		13.	Fuel cost :	(a) Gas = 168887724	Taka	(c) Coal = 69270941	Taka			
	d) Coal supply Limitation	:	294	MW				(b) Oil = 544822032	Taka	Total = 782980697	Taka			
	b) Low water level in Kaptai lake	:	205	MW										
	c) Plants under shut down/ maintenance	:	1042	MW										
10.	Total Energy (Generation + Indie Import)	:	272.92	MKWh		14.	Maximum Temperature in Dhaka was :	34° C						
	By Gas = 157.564	MKWh				15.	Export through East-West interconnections :							
	By Coal = 14.916	MKWh					At evening peak-hour	-22	MW, at	21:00 hrs				
	By Solar= 0.677	MKWh					Maximum	-144	MW, at	24:00				
							Energy	0	MKWh					
11.	Total Gas Supplied	:	1255.80	MMCFD										
(D) Forecast of 28.06.21 (Today) Monday :														
01.	Maximum Demand	:	13400	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15566	MW	(Generation end)	05.	Total Generation	:	285.37	MKWh				
03.	Maximum Shortage	:	-2166	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :		33.2° C					