

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 28-Jun-21				Page -2			
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
				Unit No. X Capacity	MW	MW	KWH
1	Ghorasal Repowered CCPP Unit-1	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	185	4221000	
4	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	190	4068000	Machine problem
5	Ghorashal 78.5 MW PP (QUAQ)	QRPP	2*40	0	0	0	Contract Expired
6	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	98	1995772	
7	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	338	8246270	FGMO
9	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	214	5702000	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	300	7121250	Gas shortage
11	Meghnaghat 100 MW(IEL)	QRPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	290	6654109	FGMO
13	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	30	402204	Low demand
15	Keranganj 100 MW PP (Powerco)	QRPP	8*13.45	100	14	187540	Low demand
16	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	356544	Engine problem
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	98	2397120	
20	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	0	843055	Tripped at 15:24
21	Gangagar 102 MW PP (Digital Po	IPP	12*8.924	102	7	895868	Low demand
22	Kapotli 52 MW PP (Siraha)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1229760	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	2724960	
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	835460	Low demand
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1049673	
27	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
28	Summit Power (Madhabaddi-Ashuli	SIPP, REB	3*3.67+4*8.73	80	55	1269960	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	777700	
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	693100	
31	Gazipur 52 MW PP	IPP	6*8.9	52	25	467520	Engine problem
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	262	2298326	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve.
35	Bramhanggan 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
36	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	124	2579900	Low demand
38	Gazipur 100 MW PP	RPCL	100 MW	105	104	2293680	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	65	682560	Low demand
40	Manikganj 162MW PP(MPGL)	IPP	9*18	162	126	2861280	Engine problem
41	Spectra Solar Plant Ltd.	IPP	35	35	0	138046	
Dhaka area Total				5819	2901	62992757	
42	Chattogram TPP-1	PDB	1*210	180	100	2300000	Gas shortage
43	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
44	Razzan 25 MW PP	IPP	3*8.9	25	25	264335	
45	Teknaf 20MW PP (Solartech)Tektat SolarTech Energ	IPP	3*8.9	20	0	70065	
46	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	12	135840	Low demand
47	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	25	543000	Low water level & Unit-2 und
48	Sikalbaha 225MW	PDB	1*150+1*175	225	131	3096349	ST under maint
49	Sikalbaha Peaking GT	PDB	1*150	150	100	2408970	Machine problem
50	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	105	2572643	
51	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
52	Dohazari-Kalesh 100 MW Peaker	PDB	8*17	102	68	1568955	Engine problem
53	Juddah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	100	2369880	
54	Juddah 100 MW PP Unit-3 (Acom)	IPP	0	100	10	993600	Low demand
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	505488	
56	* Malancha, Cig. EP2 (United)		5*8.73+3*9.34	0	14	435840	
57	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	97	961920	Engine problem
58	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	18600	
59	Arwara 300 MW PP (United)	IPP	300 MW	300	0	0	Transformer O/L
60	Jodda Power	IPP	3*18.55+1*3.6	54	35	611420	Low demand
61	Karnaphuli Power Ltd.	IPP	110	110	108	2700606	
62	Juddah unit-2 (Acom)	IPP	8*13.6	100	100	1860480	
63	Arnilma Energy Ltd.	IPP	6*21.2	116	116	2760000	
Chattogram area Total				2382	1168	26177991	
64	Ashuganj TPP Unit- 3	APSCL	1*150	135	90	2046402	Gas Shortage
65	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
66	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Under maint.
67	Ashuganj 225 MW CCPP	APSCL	1*142+1*175	221	215	4876000	FGMO
68	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	310	7379000	FGMO
69	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	280	6918000	FGMO
70	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	587232	Engine problem
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	55	1293120	
72	Ashuganj 195MW PP (APSCL-UK)	IPP	20*9.73+1*16	195	45	1120727	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1223025	
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	140	429980	Engine problem
75	Titas 50 MW Peaking PP	PDB	6*9.92	52	41	674454	Engine problem
76	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	91	2111230	ST under maint
77	Chandpur 200MW (Desh energy)	IPP	0	200	103	2478240	Low demand
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	437400	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	248220	
80	** Impoport (Tripura)	Imported power	0	160	132	2857920	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	816700	
82	Jangalia 52 MW PP (Lakdanava)	IPP	6*8.92	52	34	898416	Engine problem
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	403680	Engine problem
84	Dauidandi 200 MW PP (B.Trac)	IPP	15*11.4	200	0	0	Reserve.
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	90	2313060	Engine problem
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	120	2611560	
87	Bharob 54.5 MW	IPP	3*18.2	54	36	549000	33 KV feeder fault.
Cumilla Area Total				3034	1942	42278686	
88	RPCL 210MW CCPP	IPP	4*35+1*70	202	150	3527200	Gas shortage
89	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	391428	
90	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	8	183360	Engine problem
91	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11750	
92	Mymensingh 200 MW PP (United)	IPP	200	200	184	3343200	Engine problem
93	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2605200	
94	Sutakhal 50 MW Solar PP	IPP	50	50	0	260420	
95	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	492480	
Mymensingh Area Total				709	481	10725038	
96	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1038000	Machine problem
97	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	42	990120	Machine problem
98	Kushara 163 MW CCPP (KP)	IPP	1*109+1*54	163	0	0	Under maintenance
99	Shajibazar 330 MW CCPP	PDB	3*110	330	163	3649000	GT-1 under maint
100	Fenchugonj 51 MW PP (Barakati)	RPP	18*2.90	51	53	1077000	
101	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
102	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	81072	
103	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	61	1424832	
104	Shajibazar 86MW PP (Shajibaza	RPP	32*2.90	86	84	1801920	
105	Shajibazar 100 MW GTTP	PDB	1*100	100	0	0	Under Shut down
106	Sylhet 225 MW CCPP	PDB	1*142+1*99	231	225	5176030	
107	Sylhet 20 MW GTTP	PDB	1*20	20	16	389000	
108	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
109	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	347952	Engine problem
110	Biliana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	275	7123500	FGMO
111	Biliana-III 400 MW CCPP	PDB	400 MW	400	365	8393000	FGMO
112	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	252360	
113	Biliana South 400 MW	PDB	400 MW	383	400	9162300	
Sylhet Area Total				2377	1766	49060686	
114	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
115	** Bheramara (HVDC)	Imported power	2*500	1000	900	21732364	
116	Khuila 115 PP MW (KPCL-2)	QRPP	7*17	0	0	0	Contract Expired
117	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	17	89280	Engine problem
118	Khuila 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
119	Chopaganj 100 MW Peaking PP	PDB	1*100	108	0	0	Reserve.
120	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	390	9605376	FGMO
121	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	0	0	0	Contract Expired
122	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	100	840000	
123	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	91	1572000	Engine problem
124	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
Khuila Area Total				2129	1498	33839920	
125	Bansal 110 MW PP (Summit)	IPP	7*17.076	110	16	21996	Line O/L
126	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	33	588716	
127	Bhola 225 MW CCPP	PDB	2*63+1*68	194	86	2112091	Machine problem
128	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	11	274319	Gas shortage
129	Payra 1320 MW	BCPCL	2*622	1244	500	11388500	
130	Bhola Nutan Biddut BD LTD	IPP	220	0	223	5163100	On Test
131	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line O/L
Barisal Area Total				1826	869	19684694	
132	Baghabari 71 MW GTTP	PDB	1*71	71	65	1520000	
133	Baghabari 100 MW GTTP	PDB	1*100	100	75	521000	Gas shortage.
134	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	776864	
135	Bera 70 MW Peaking PP	PDB	9*8.29	71	43	391954	Engine problem
136	Ammura 50 MW PP(Siraha)						