

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month July, 2021					Day : Thursday		Date : 08.07.21							
Probable Maximum Demand : 12000 MW					Probable Maximum Generation : 15050 MW					Rule Curve = 85.12 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 79.90 ft		Today = 80.00 ft		07.07.21 (Today)		07.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derailed/ Present Capacity (MW)	Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/water/Coal limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
					07.07.21	07.07.21	08.07.21	08.07.21						
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0		260	Under maint.		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300					
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	92	96	100	100					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Under Maint.		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	316	351	360	360					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	260	260	260	260		190	Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	322	324	350	360					
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	331	332	330	330					
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100					
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	260	280	300	300					
15	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55					
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	70	100					
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	24	100	102					
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	20	20					
19	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.07+1x8.73	80	80	53	46	55	55					
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	16	33	33					
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	25	25	25					
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	50	105	50	50					
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	64	150	150	150					
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0					
26	Karnalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54					
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	195	250	250					
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	100	130	135					
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x1.4	300	300	0	0	100	300					
30	Bramhangon 100 MW PP (Aggrico)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100					
31	Aurahi 100MW PP (Aggrico)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100					
32	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	53	55	55	55					
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	30	0	55	55					
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	90	104					
36	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	126	126	126	162					
37	Manikgonj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	7	0	30	0					
Dhaka Zone Total					5976	5819	2780	2991	3781	4048	400	870		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	54	55	55	55	175		Low Water Level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	2	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	50	50					
44	Sikalbaha 105 MW PP (Baraka Sikalab)	HFO (IPP)	6x18.415	105	105	105	105	105	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	110	110	110					
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	210	210	215					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	0	200	300					
48	Juldah 100 MW Unit-1 (Accorn)	HFO (QRPP)	8x13.45	100	100	90	88	100	100					
49	Juldah 100 MW PP Unit-3 (Accorn)	HFO (IPP)	8x13.45	100	100	50	70	100	100					
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51					
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0					
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			7	20	5	15					
53	Chattogram 108 MW PP (ECPIV)	HFO (IPP)	16x7.00	108	108	0	0	12	12					
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54					
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	82	110	110	110					
56	Juldah unit-2 (Accorn)	HFO (IPP)	8x13.6	100	100	50	100	100	100					
57	Chattogram 116 MW PP (Anlima Ener	HFO (IPP)	6x21.06	116	116	94	91	112	112					
Chattogram Zone Total					2442	2382	983	1151	1540	1630	175	180		
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	110	110	135	25		Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	186	196	210	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	290	330	350					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	260	325	350	360					
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	53	49	55	55					
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	26	26	187		Gas shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	34	43	43	43					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	142	135	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	50	50	0	50					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0					
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	100	170	200					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	21	21	21					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+4x0.1315+1x1.108	200	200	0	0	100	200					
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	114	114	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	118	118	113	113					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	18	18	36	36					
**	Impoirt (Tripura)	India		160	160	102	114	148	172					
Cumilla Zone Total					3094	3034	1593	1826	2111	2370	475	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	161	157	190	190	45		Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	21	21					
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	75	115	115	115					
83	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	120	175	200					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	1	0	50	0					
86	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22					
Myensingh Zone Total					717	709	289	445	583	556	45	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.07.21 (Yesterday)		08.07.21 (Today)		07.07.21 (Yesterday)		07.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date						
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)								
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	Under maint.							
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	Under maint.							
89	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	47	53	51	51										
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0										
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11										
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	56	62	63										
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	163	162	160	160										
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	84	84										
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	218	225	225	225										
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18										
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10										
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16										
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	290	315	341										
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400	Under maint.								
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400										
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0										
Sylhet Zone Total				2422	2377	1368	1377	1425	1452	0	487								
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0										
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	350	410	400	400										
105	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	3	0	0	20										
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60										
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	100	220										
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	40	50	100										
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	90	90	90										
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100										
**	Bheramara (HVDG)	India		1000	1000	799	800	807	807										
Khulna Zone Total				2133	2129	1205	1340	1547	1797	0	0								
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110										
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	29	25	33										
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	86	85	86	108	GT-2 & STG Under maint.								
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	12	11	11	11										
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	370	490	622	622										
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110										
Bhola Nutan Biddut BD LTD						220	221	220	220										
Barishal Zone Total				1826	1826	708	837	1073	1192	0	108								
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	60	60	60	65										
117	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage								
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	43										
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200										
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	20	40	0	40										
121	Amnura 50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	18	35	35	35										
122	Chapainawaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	48	87	50	95										
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	0	35										
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	43	43	50	50										
125	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	44	0	42										
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	150	Gas Shortage, STG S/D								
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	171	182	210	210										
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	183	168	200	200										
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	394	418	400	400										
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	18	18										
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11										
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52										
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	35	113	113	113										
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	112	113	113										
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0										
Rajshahi Zone Total				2179	2179	1087	1468	1518	1722	250	0								
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage								
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage								
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124	Coal Shortage								
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10										
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2/3	113	113	0	113	113	113										
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10										
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	2	0	8	0	0										
Rangpur Zone Total				685	605	152	263	271	283	294	0								
Sub-total: Plants in operation				21474	21060	10165.0	11698	13849	15050	1639	1645								
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9740	11209	13270	14421										
(B) Plants under long term maintenance/ contract expired																			
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021							
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0										
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021							
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020							
146	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020							
147	Meghnaghat 100 MW(IEU)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021							
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021							
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0			Contract Expired on 28/05/2021							
Sub-Total: Plants under long term maintenance/ contract expired				549	0	0	0	0	0										
Gross Total				22023	21060	10165	11698	13849	15050	1639	1645								
(C) Actual data of 07.07.21 (Yesterday) Wednesday :																			
01.	Max. Demand at eve. peak (Generation end)	:	11698.00	MW,	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :												
02.	Max. Demand at eve. peak (Sub-station end)	:	11209.00	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed					
03.	Highest Generation (Generation end)	:	11741.00	MW,	at =	22:00 hrs		MW	MW	MW		MW	MW	MW					
04.	Minimum Generation (Generation end)	:	9247.00	MW,	at =	7:00 hrs	Dhaka	3934	3934	0	Mymensingh	956	956	0					
05.	Day-peak Generation (Generation end)	:	10165.00	MW,	at =	12:00 hrs	Chattogram	1100	1100	0	Sylhet	443	443	0					
06.	Evening-peak Generation (Generation end)	:	11698.00	MW,	at =	21:00 hrs	Khulna	1320	1320	0	Barishal	319	319	0					
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Rajshahi	1235	1235	0	Rangpur	804	804	0					
08.	Minimum Generation Forecast up to 8.00 hrs.	:	8693.00	MW,	at =	5:00 hrs	Cumilla	1098	1098	0									
09.	Generation shortfall at evening peak due to :	:									Total	11209	11209	0					
a) Gas limitation		:	1170	MW			13. Fuel cost :	(a) Gas = 158446610 Taka		(c) Coal = 68168509 Taka									
d) Coal supply Limitation		:	294	MW				(b) Oil = 450679630 Taka		Total = 677294749 Taka									
b) Low water level in Kapila lake		:	175	MW															
c) Plants under shut down/ maintenance		:	1645	MW			14. Maximum Temperature in Dhaka was : 31.1° C												
10. Total Energy (Generation + India Import)		:	252.63	MKWh			15. Export through East-West interconnections :												
By Gas = 152.075 MKWh					By Oil =	62.238 MKWh	At evening peak-hour												
By Coal = 14.665 MKWh					By Hydro =	1.232 MKWh	Maximum												
By Solar = 0.278 MKWh							Energy												
11.	Total Gas Supplied	:	1153.80	MMCFD															
(D) Forecast of 08.07.21 (Today) Thursday :																			
01.	Maximum Demand	:	12000	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)							
02.	Maximum Generation	:	15050	MW	(Generation end)		05.	Total Generation	:	258.20	MKWh								
03.	Maximum Shortage	:	-3050	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.5° C									