

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month July, 2021				Day : Tuesday				Date : 13.07.21			
Probable Maximum Demand : 13400 MW				Probable Maximum Generation : 15331 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 80.46 ft				Today = 80.97 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.07.21 (Yesterday)		13.07.21 (Today)		Rule Curve = 85.92 ft		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : (Yesterday)		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	100	160	0	100		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	96	105	100	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	232	225	300	300		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	240	240	240	240	210	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	327	326	325	325		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	320	326	330	330		
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	95	100	100	100		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	285	275	300	300		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55		
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	50	84	84	85		
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	85	94	100	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	16	20	20		
19	Summit Power, (Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.87+1x8.73	80	80	34	50	55	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	33	43	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	100	100		
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150		
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Karnalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	20	288	250	300		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	105	149	130	132		
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x1.4	300	300	0	26	100	300		
30	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
31	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
32	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	55	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	11	104	90	104		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	126	126	126	126		
37	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	27	0	30	0		
Dhaka Zone Total				5976	5819	2846	3577	3767	4106	420	680
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	54	77	77	77	153	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	46	50	50		
44	Sikalbaha 105 MW PP (Baraka Sikab	HFO (IPP)	6x18.415	105	105	89	89	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	110	110	110	110		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	214	203	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	0	200	300		
48	Juldah 100 MW Unit-1 (Accorn)	HFO (QRPP)	8x13.45	100	100	83	85	100	100		
49	Juldah 100 MW PP Unit-3 (Accorn)	HFO (IPP)	8x13.45	100	100	30	100	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	19	22	22		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	26	10	25		
53	Chattogram 108 MW PP (ECPU)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	95	110	110	110		
56	Juldah unit-2 (Accorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100		
57	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	96	92	116	116		
Chattogram Zone Total				2442	2382	1011	1233	1580	1670	153	180
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	80	100	100	55	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	210	213	210	210		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	310	280	330	350		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	315	285	350	360		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	50	54	55	55		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	16	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	34	34	34	34		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	140	145	150	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	41	49	42	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	90	90	90		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	160	170	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	8	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	21	21		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	98x1.4+8x1.315+1x1.108	200	200	0	0	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	90	52	100	100		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	113	115	113	113		
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	36	36		
**	Impoirt (Tripura)	India		160	160	140	138	148	172		
Cumilla Zone Total				3094	3034	1865	1894	2192	2384	505	0
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	144	144	160	160	58	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	21	21		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	106	95	115	115		
83	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	60	192	175	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0		
85	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	56	0	50	0		
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	24	24	22	22		
Myensingh Zone Total				717	709	417	482	553	526	58	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.07.21 (Yesterday)		13.07.21 (Today)		12.07.21 (Yesterday)		12.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for		Machines shut down (MW)	Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Gen. shortfall for				
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43			27	Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30			60	Under maint.		
89	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	50	53	51	51						
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0						
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	0	11	11						
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	62	63						
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	160	161	160	160						
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	83	84	84						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	219	219	225	225						
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16						
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	300	300						
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	404	400	400						
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	390	400	400						
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0						
Sylhet Zone Total						2422	2377	1794	1777	1810	1811	0	87		
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	395	405	400	400						
105	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	15	0	20						
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60						
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	100	0	160						
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	21	105	90	105						
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100						
**	Bheramara (HVDC)	India		1000	1000	798	798	821	821						
Khulna Zone Total						2133	2129	1214	1523	1461	1766	0	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110						
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	33	25	33						
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	88	85	86						
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11						
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	350	520	622	622						
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	0	110						
Bhola Nutan Biddut BD LTD								220	221	220	220				
Barishal Zone Total						1826	1826	688	943	1073	1192	0	0		
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0						
117	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage			
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	50	43	50	50						
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200						
120	Bera 70 MW Peaking PP	HFO (PDB)	9x6.29	71	71	21	48	30	40						
121	Amnura 50 MW PP (Siraha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0						
122	Chapainawaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	92	91	95	95						
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	32	30	40						
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	43	43	43						
125	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	41						
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	150		Gas Shortage, STG S/D			
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	170	175	210	210						
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	197	191	200	200						
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	408	409	400	400						
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22						
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	46	52	52						
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	55	95	95	95						
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	94	94	94						
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0						
Rajshahi Zone Total						2179	2179	1139	1330	1538	1593	250	0		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage			
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage			
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage			
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10						
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	45	113	113	113						
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10						
141	Magpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0						
Rangpur Zone Total						685	605	202	263	271	283	294	0		
Sub-total: Plants in operation						21474	21060	11176.0	13022	14245	15331	1680	947		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								10646	12405	13570	14605				
(B) Plants under long term maintenance/ contract expired															
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0					Contract Expired on 08/01/2021	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0						
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0					Contract Expired on 14/02/2021	
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0					Contract Expired on 04/01/2020	
146	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0					Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEU)	HFO (QRPP)	12x8.9	100	0	0	0	0	0					Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0					Contract Expired on 31/05/2021	
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0					Contract Expired on 28/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired						549	0	0	0	0	0				
Gross Total						22023	21060	11176	13022	14245	15331	1680	947		
(C) Actual data of 12.07.21 (Yesterday) Monday :															
01.	Max. Demand at eve. peak (Generation end)	:	13022.00	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	12405.00	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	13022.00	MW, at =	21:00 hrs	Dhaka	4330	4330	0	Mymensingh	1046	1046	0		
04.	Minimum Generation (Generation end)	:	10089.00	MW, at =	7:00 hrs	Chattogram	1212	1212	0	Sylhet	520	520	0		
05.	Day-peak Generation (Generation end)	:	11176.00	MW, at =	12:00 hrs	Khulna	1545	1545	0	Barishal	376	376	0		
06.	Evening-peak Generation (Generation end)	:	13022.00	MW, at =	21:00 hrs	Rajshahi	1378	1378	0	Rangpur	786	786	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Cumilla	1212	1212	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9837.00	MW, at =	5:00 hrs					Total	12405	12405	0		
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 168966750 Taka (c) Coal = 69263300 Taka (b) Oil = 549442351 Taka Total = 787672402 Taka							
	a) Gas limitation	:	1233	MW		14.	Maximum Temperature in Dhaka was :	35.8° C							
	d) Coal supply Limitation	:	294	MW		15.	Export through East-West interconnections :								
	b) Low water level in Kaptai lake	:	153	MW			At evening peak-hour	:	-280	MW, at	21:00 hrs				
	c) Plants under shut down/ maintenance	:	947	MW			Maximum	:	-310	MW, at	22:00 hrs				
10.	Total Energy (Generation + India Import)	:	279.65	MKWh			Energy	:	2.836	MKWh					
	By Gas = 164.306 MKWh			By Oil = 75.499 MKWh											
	By Coal = 14.918 MKWh			By Hydro = 1.592 MKWh											
	By Solar = 0.877 MKWh														
11.	Total Gas Supplied	:	1240.90	MMCFD											
(D) Forecast of 13.07.21 (Today) Tuesday :															
01.	Maximum Demand	:	13400	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	15331	MW	(Generation end)	05.	Total Generation	:	287.76	MKWh					
03.	Maximum Shortage	:	-1931	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	34.9° C						

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation