

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month July, 2021					Day : Friday				Date : 16.07.21					
Probable Maximum Demand : 12800 MW					Probable Maximum Generation : 15407 MW					Rule Curve = 86.40 ft.				
Water Level of Kaptai Lake at 06:00 AM					Today = 82.34 ft.					16.07.21 (Today)				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derailed/ Present Capacity (MW)	15.07.21 (Today)		16.07.21 (Today)		15.07.21 (Yesterday)		15.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Gas/water/Coal limitation MW	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0			260	Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under Repowering	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110			80	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300					
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	100	105	100	106					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			20	Under Maint.	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	198	180	300	300	180			Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	220	220	240	240	230			Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	275	275	325	325	137			Gas Shortage	
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210				
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	326	334	335	335					
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	91	99	100	100					
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	250	260	300	300					
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55					
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	10	86	86	86					
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	72	93	100	102					
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	17	16	20	20					
19	Summit Power, (Madhabadi-Ashulia)	Gas (SIPP, REB)	6x3.87+1x8.73	80	80	39	47	55	55					
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
21	Ruganaj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	52	52					
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	100	100					
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150					
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0					
26	Karnalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54					
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	232	274	250	300					
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	70	149	149	149					
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x1.4	300	300	0	157	100	300					
30	Bramhangonj 100 MW PP (Aggrico)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100					
31	Auralah 100MW PP (Aggrico)	HSD (IPP)	23x0.85+91x.959	100	100	0	102	100	100					
32	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	104	104	104					
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162					
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	27	0	30	0					
Dhaka Zone Total					5976	5819	3135	3764	3953	4181	757	760		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	88	89	89	142			Low Water Level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0					
41	Raczan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	26	25	26					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	27	50	50	50					
44	Sikalbaha 105 MW PP (Baraka Sikabha)	HFO (IPP)	6x18.415	105	105	105	105	105	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	110	110	110	110					
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	204	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	0	200	300					
48	Juldah 100 MW Unit-1 (Accorn)	HFO (QRPP)	8x13.45	100	100	80	94	100	100					
49	Juldah 100 MW PP Unit-3 (Accorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100					
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51					
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0					
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	25	10	25					
53	Chattogram 108 MW PP (ECPIV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54					
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110					
56	Juldah unit-2 (Accorn)	HFO (IPP)	8x13.6	100	100	100	99	100	100					
57	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	94	107	116	116					
Chattogram Zone Total					2442	2382	1184	1291	1592	1683	142	180		
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	100	100	100	100	35			Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	183	216	210	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	295	265	300	300					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	355	360	360					
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	56	55	55					
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	102	8	8	8	187			Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	34	34	34	34					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	142	140	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	49	48	50	50					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	131	135	135					
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	120	195	170	200					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	8	8	11	11					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	21	21	21					
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	19x14.40+1.57x11.08	200	200	0	200	100	200					
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	110	114	105	105					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	103	104	113	113					
78	Bharoi 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	36	36					
**	Impoport (Tripura)	India		160	160	94	140	148	172					
Cumilla Zone Total					3094	3034	1742	2295	2230	2384	485	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	148	144	160	160	58			Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21					
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	106	106	115	115					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	143	183	175	200					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	27	0	50	0					
86	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	18	24	22	22					
Mymensingh Zone Total					717	709	473	486	553	526	58	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.07.21 (Yesterday)		16.07.21 (Today)		15.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance							
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : MW	Machines shut down (MW)								
						Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date						
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	Under maint.							
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	0	0		60	Under maint.							
89	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	47	53	51	51										
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.							
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11										
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	56	62	63										
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	162	161	163	163										
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	83	84	84										
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	218	219	225	225										
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18										
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10										
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	16	16										
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	290	300	300										
100	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	330	365	400	400										
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	395	400	400	400										
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0										
Sylhet Zone Total				2422	2377	1702	1747	1783	1784	0	250								
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0										
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	300	290	400	400										
105	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	20	0	20										
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60										
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	108	0	160										
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100										
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105										
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100										
Bheramara (HVD) India				1000	1000	815	793	812	812										
Khulna Zone Total				2133	2129	1224	1416	1467	1757	0	0								
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110										
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	22	32	26	33										
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	86	85	86										
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11										
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	390	440	622	622										
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	103	110	110										
Bhola Nutan Biddut BD LTD						218	220	220	220										
Barishal Zone Total				1826	1826	727	892	1184	1192	0	0								
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage							
117	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage							
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50										
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	200	200										
120	Bera 70 MW Peaking PP	HFO (PDB)	9x6.29	71	71	5	40	20	40										
121	Amnura 50 MW PP(Siraha)	HFO (QRPP)	7x7.79	50	50	0	35	35	35										
122	Chapainawaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	52	89	95	95										
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	22	30	40	40										
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	43	43	43	43										
125	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	0	30										
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		150	Gas Shortage, STG S/D							
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	140	140	210	210										
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	182	176	200	200										
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	385	406	400	400										
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	13	22	22										
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11										
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52										
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	95	113	95	95										
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	94	94										
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0										
Rajshahi Zone Total				2179	2179	1096	1371	1573	1617	321	0								
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage							
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage							
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150		124	Coal Shortage							
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10										
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	113	113	113	113										
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10										
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0										
Rangpur Zone Total				685	605	266	263	271	283	294	0								
Sub-total: Plants in operation				21474	21060	11549.0	13525	14606	15407	2057	1190								
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10895	12759	13778	14534										
(B) Plants under long term maintenance/ contract expired																			
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021							
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0										
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021							
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020							
146	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020							
147	Meghnaghat 100 MW(IEU)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021							
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021							
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0			Contract Expired on 28/05/2021							
Sub-Total: Plants under long term maintenance/ contract expired				549	0	0	0	0	0										
Gross Total				22023	21060	11549	13525	14606	15407	2057	1190								
(C) Actual data of 15.07.21 (Yesterday) Thursday :																			
01.	Max. Demand at eve. peak (Generation end)	:	13525.00	MW,	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :												
02.	Max. Demand at eve. peak (Sub-station end)	:	12759.00	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed					
03.	Highest Generation (Generation end)	:	13525.00	MW,	at =	21:00 hrs		MW	MW	MW		MW	MW	MW					
04.	Minimum Generation (Generation end)	:	10230.00	MW,	at =	8:00 hrs	Dhaka	4465	4465	0	Mymensingh	1042	1042	0					
05.	Day-peak Generation (Generation end)	:	11549.00	MW,	at =	12:00 hrs	Chattogram	1319	1319	0	Sylhet	535	535	0					
06.	Evening-peak Generation (Generation end)	:	13525.00	MW,	at =	21:00 hrs	Khulna	1599	1599	0	Barishal	398	398	0					
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Rajshahi	1386	1386	0	Rangpur	783	783	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9916.00	MW,	at =	5:00 hrs	Cumilla	1232	1232	0									
09.	Generation shortfall at evening peak due to :	:									Total	12759	12759	0					
a) Gas limitation : 1621 MW							13.	Fuel cost :	(a) Gas = 164425742 Taka		(c) Coal = 69663597 Taka								
d) Coal supply Limitation : 294 MW									b) Oil = 681848310 Taka										
b) Low water level in Kapila lake : 142 MW																			
c) Plants under shut down/ maintenance : 1190 MW							14. Maximum Temperature in Dhaka was : 35.7° C												
10. Total Energy (Generation + India Import) : 287.51 MCKWh							15.	Export through East-West interconnections :											
By Gas = 157.222 MCKWh									At evening peak-hour : -454 MW, at 21:00 hrs										
By Coal = 15.010 MCKWh									Maximum : -548 MW, at 20:00 hrs										
By Solar = 0.635 MCKWh									Energy : 3.939 MCKWh										
11. Total Gas Supplied : 1215.58 MCMCFD																			
Forecast of 16.07.21 (Today) Friday :																			
01.	Maximum Demand	:	12800	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)							
02.	Maximum Generation	:	15407	MW	(Generation end)		05.	Total Generation	:	272.10	MCKWh	</							
03.	Maximum Shortage	:	-2607	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	35.2° C									