

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month July, 2021					Day : Sunday		Date : 18.07.21						
Probable Maximum Demand : 13300 MW					Probable Maximum Generation : 15478 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 82.58 ft		Today = 82.58 ft		Rule Curve = 86.72 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.07.21 (Yesterday)		18.07.21 (Today)		17.07.21 (Yesterday) Gen. shortfall for: Gas/water/Coal limitation MW	18.07.21 (Today) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	103	189	190	190				
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	32	99	108	108				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Under Maint.	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	208	135	260	270	225		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	220	220	220	220	230		Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	277	277	325	325	135		Gas Shortage	
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	324	334	335	335				
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	90	95	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	265	275	300	305				
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55				
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	87	85	100				
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	94	100	102				
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	16	20	20				
19	Summit Power, (Madhab+Ashulia)	Gas (SIPP, REB)	6x3.87+1x8.73	80	80	47	47	55	55				
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Ruganaj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	24	52	52				
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	100	100				
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	115	150	150	150				
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
26	Karnalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	260	250	300				
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	87	149	149	149				
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x1.4	300	300	0	58	100	300				
30	Bramhangon 100 MW PP (Aggrico)	HSD (IPP)	23x0.85+91x.959	100	100	0	25	100	100				
31	Aushali 100MW PP (Aggrico)	HSD (IPP)	23x0.85+91x.959	100	100	0	53	100	100				
32	Nababaganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	55	55	55	55				
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55				
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	104	104	104				
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162				
37	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	18	0	30	0				
Dhaka Zone Total				5976	5819	2834	3543	3980	4232	990	420		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	89	119	88	88	111		Low Water Level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0				
41	Racozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	14	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50				
44	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	110	120	110	110				
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	203	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	0	200	300				
48	Juldah 100 MW Unit-1 (Accorn)	HFO (QRPP)	8x13.45	100	100	82	94	100	100				
49	Juldah 100 MW PP Unit-3 (Accorn)	HFO (IPP)	8x13.45	100	100	40	100	100	100				
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	0	22	22				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	23	10	25				
53	Chattogram 108 MW PP (ECPU)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54				
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	68	110	110	110				
56	Juldah unit-2 (Accorn)	HFO (IPP)	8x13.6	100	100	70	100	100	100				
57	Chattogram 116 MW PP (Anlima Ener	HFO (IPP)	6x21.06	116	116	91	95	116	116				
Chattogram Zone Total				2442	2382	1026	1295	1591	1681	111	180		
58	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	80	80	100	135	55		Gas Shortage	
	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	212	194	210	210				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	275	275	300	320				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	290	285	360	360				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	56	55	55				
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	34	34	34	34				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	135	150	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	41	50	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	135	136	135	135				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	200	170	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	20	21	21				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	98x1.4+8x1.315+1x1.108	200	200	0	100	100	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	114	34	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	104	117	113	113				
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	36	36				
**	Impoirt (Tripura)	India		160	160	94	122	148	172				
Cumilla Zone Total				3094	3034	1662	2103	2159	2448	505	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	142	117	155	140	85		Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	21	21				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	2	8	8	8				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	107	115	115				
83	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	202	195	175	200				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	16	0	50	0				
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	24	24	22	22				
Myensingh Zone Total				717	709	414	472	548	506	85	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.07.21 (Yesterday)		18.07.21 (Today)		17.07.21 (Yesterday)		17.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening						
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27		Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90		Under maint.		
89	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	47	50	51	51						
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163		Under maint.		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11						
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	61	62	63						
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	163	162	163	163						
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	84	84						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	219	225	225	225						
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16						
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	300	300						
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	364	417	400	400						
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400						
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0						
Sylhet Zone Total						2422	2377	1709	1787	1783	1784	0	280		
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	315	260	350	350						
105	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	15	0	20						
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60						
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	130	0	160						
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	70	105	105	105						
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100						
**	Bheramara (HSDC)	India		1000	1000	791	791	823	823						
Khulna Zone Total						2133	2129	1180	1401	1428	1718	0	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	64	110	110						
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	25	34	26	33						
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0						
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	72	81	70	70						
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	280	280	622	622						
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	150	110	110						
Bhola Nutan Biddut BD LTD								181	221	220	220				
Barishal Zone Total						1826	1826	558	830	1158	1165	0	0		
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71		Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100		Gas Shortage		
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50						
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	200	200						
120	Bera 70 MW Peaking PP	HFO (PDB)	9x6.29	71	71	0	20	20	40						
121	Amnura 50 MW PP(Sirha)	HFO (QRPP)	7x7.79	50	50	35	35	35	35						
122	Chapainawaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	60	91	95	95						
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	40	40						
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	43	0	43	43						
125	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	0	30						
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		150		Gas Shortage, STG S/D		
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	140	140	210	210						
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	182	175	200	200						
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	410	400	400						
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22						
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11						
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	25	16	8	8						
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	90	113	113	113						
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	5	94	94	94						
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0						
Rajshahi Zone Total						2179	2179	1027	1291	1547	1591	321	0		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	74	72	70	70		13		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85		Coal Shortage		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	149	150	150		125		Coal Shortage		
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10						
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	34	113	113	113						
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10						
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0						
Rangpur Zone Total						685	605	260	334	341	353	223	0		
Sub-total: Plants in operation						21474	21060	10670.0	13056	14535	15478	2235	880		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss															
						10216	12501	13917	14820						
(B) Plants under long term maintenance/ contract expired															
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021		
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0						
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021		
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020		
146	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW(IEU)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021		
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0				Contract Expired on 28/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired						549	0	0	0	0	0				
Gross Total						22023	21060	10670	13056	14535	15478	2235	880		
(C) Actual data of 17.07.21 (Yesterday) Saturday :															
01.	Max. Demand at eve. peak (Generation end)	:	13056.00	MW,	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	12501.00	MW,	at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	13056.00	MW,	at =	21:00 hrs	Dhaka	4313	4313	0	Mymensingh	1022	1022	0	
04.	Minimum Generation (Generation end)	:	9712.00	MW,	at =	8:00 hrs	Chattogram	1307	1307	0	Sylhet	500	500	0	
05.	Day-peak Generation (Generation end)	:	10670.00	MW,	at =	12:00 hrs	Khulna	1626	1626	0	Barishal	397	397	0	
06.	Evening-peak Generation (Generation end)	:	13056.00	MW,	at =	21:00 hrs	Rajshahi	1341	1341	0	Rangpur	786	786	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Cumilla	1209	1209	0					
08.	Minimum Generation Forecast up to 8.00 hrs.	:	9707.00	MW,	at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:													
a) Gas limitation							13.	Fuel cost :	(a) Gas = 167071642		(c) Coal = 62651524				
d) Coal supply Limitation									b) Oil = 561690931		Taka Total = 791414097				
b) Low water level in Kaptai lake															
c) Plants under shut down/ maintenance															
10. Total Energy (Generation + India Import)							14. Maximum Temperature in Dhaka was : 33.4° C								
By Gas = 159.714 MKWH							15. Export through East-West interconnections :								
By Coal = 12.782 MKWH							At evening peak-hour : -526 MW, at 21:00 hrs								
By Solar= 0.446 MKWH							Maximum : -560 MW, at 19:30 hrs								
11. Total Gas Supplied							Energy : 2.644 MKWh								
(D) Forecast of 18.07.21 (Today) Sunday :															
01.	Maximum Demand	:	13300	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	15478	MW	(Generation end)	05.	Total Generation	:	280.13	MKWh					
03.	Maximum Shortage	:	-2178	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	33.3° C						