

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month July, 2021					Day : Tuesday				Date : 20.07.21				
Probable Maximum Demand : 10600 MW					Probable Maximum Generation : 15283 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 82.98 ft		Today = 83.34 ft		(15283)		Rule Curve = 87.04 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.07.21 (Yesterday)		20.07.21 (Today)		19.07.21 (Yesterday)		20.07.21 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0		260	Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300				
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	27	106	108	108				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Under Maint.	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	262	350	360	360	10		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	220	220	220	220	230		Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	277	277	280	280	135		Gas Shortage	
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	270	335	335	335				
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	85	90	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	270	290	300	300				
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	55	55				
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	0	100	102				
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	13	19	20	20				
19	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.87+1x8.73	80	80	41	41	55	55				
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	28	33	33				
21	Ruganaj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	52	52				
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	35	100	100				
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	133	64	133	133				
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
26	Karnalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	94	195	270	270				
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	64	35	149	149				
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	100	300				
30	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x10.85+91x.959	100	100	0	0	100	100				
31	Aushali 100MW PP (Aggreko)	HSD (IPP)	23x10.85+91x.959	100	100	0	0	100	100				
32	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	17	55	55				
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	17	55	55				
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	70	92	104				
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	143	162	162	162				
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	1	0	30	0				
Dhaka Zone Total					5976	5819	2606	2819	3851	4035	585	870	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	117	123	120	120	107		Low Water Level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	22	50	50				
44	Sikalbaha 105 MW PP (Baraka Sikabha)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	120	120	120				
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	202	0	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	104	200	300				
48	Juldah 100 MW Unit-1 (Accorn)	HFO (QRPP)	8x13.45	100	100	82	82	82	100				
49	Juldah 100 MW PP Unit-3 (Accorn)	HFO (IPP)	8x13.45	100	100	10	70	100	100				
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			10	40	20	40				
53	Chattogram 108 MW PP (ECPIV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	36	54	54				
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	110	110	110				
56	Juldah unit-2 (Accorn)	HFO (IPP)	8x13.6	100	100	60	100	100	100				
57	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	112	112	112	112				
Chattogram Zone Total					2442	2382	1031	1220	1621	1734	107	180	
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	70	135	100	135	0		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	26	26	26				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	191	192	210	210				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	260	285	300	320				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	260	25	0	250				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	20	56	55	55				
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	73	16	73	122		Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	147	150	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	85	90	90	90				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	141	170	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	8	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	32	43	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	20	21	21				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x11.4+8x11.315+1x11.08	200	200	0	0	100	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	100				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	103	106	113	113				
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	36	36	36				
**	Impoiti (Tripura)	India		160	160	110	130	148	172				
Cumilla Zone Total					3094	3034	1549	1780	1754	2353	385	0	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	154	152	210	210	50		Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	105	115	115	115				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	70	194	175	200				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	20	0	50	0				
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	24	24	22	22				
Mymensingh Zone Total					717	709	404	514	603	576	50	0	

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.07.21 (Yesterday)		20.07.21 (Today)		19.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
87	Fenchugonj CCPP Phase-1	Gas	(PDB)	2x32+1x33	97	70	43	43	43	43		27	Under maint.		
88	Fenchugonj CCPP Phase-2	Gas	(PDB)	2x35+1x35	104	90	30	30	30	30		60	Under maint.		
89	Fenchugonj 51 MW PP (Barakatalullah)	Gas	(RPP)	19x2.90	51	51	47	53	51	51					
90	Kushara 163 MW CCPP (KP)	Gas	(IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.		
91	Hobiganj 11MW PP Confidence-E	Gas	(SIPP, REB)	4x2.90	11	11	2	11	11	11					
92	Shahjibazar GTTP Unit- 8 & 9	Gas	(PDB)	2x35	70	66	61	56	62	63					
93	Shahjibazar 330 MW CCPP	Gas	(PDB)	2x110+1x110	330	330	161	162	163	163					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas	(RPP)	32x2.90	86	86	40	84	84	84					
95	Sylhet 225 MW CCPP	Gas	(PDB)	1x142+1x89	231	231	185	218	225	225					
96	Sylhet 20 MW GTTP	Gas	(PDB)	1 x 20	20	20	18	18	18	18					
97	Sylhet 10MW PP (Desh)	Gas	(RPP)	6x1.95	10	10	9	10	10	10					
98	Shahjahanulla 25 MW PP	Gas	(CIPP, REB)	3x9.34	25	25	8	16	16	16					
99	Bibiana-II 341 MW CCPP (Summit)	Gas	(IPP)	1x222+1x119	341	341	290	290	341	341					
100	Bibiyana-II 400 MW CCPP	Gas	(PDB)	1x285+1x115	400	400	414	400	400	400					
101	Bibiyana South 383 MW CCPP	Gas	(PDB)	1x252+1x131	383	383	400	400	400	400					
102	Shahjibazar 100 MW GTTP	Gas	(PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total					2422	2377	1708	1791	1854	1855	0	250			
103	Bheramara GTTP Unit- 3	HSD	(PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CCPP	Gas	(NWPGL)	1 x 278+1 x 132	410	410	270	285	340	340					
105	Faridpur 50 MW Peaking PP	HFO	(PDB)	8x6.98	54	54	0	16	0	20					
106	Gopalganj 100 MW Peaking PP	HFO	(PDB)	16x6.98	109	109	0	0	0	60					
107	Khulna 225 MW CCPP	HSD	(NWPGL)	1 x 150+1x75	230	230	0	158	0	160					
108	Noapara 100 MW PP (Bangla Trac)	HSD	(IPP)	70x1.4+7x1.515	100	100	0	100	50	100					
109	Rupsha 105 MW PP (Orion rupsha)	HFO	(IPP)	6x18.445	105	105	85	105	105	105					
110	Madhumat 100 MW PP	HFO	(NWPGL)	6x18.415	105	105	0	15	100	100					
**	Bheramara (HVDC)	India			1000	1000	808	808	824	824					
Khulna Zone Total					2133	2129	1163	1487	1419	1709	0	0			
111	Barisal 110 MW PP (Summit)	HFO	(IPP)	7 x 17.076	110	110	0	48	110	110					
112	Bhola 33 MW PP (Venture)	Gas	(RPP)	1x34.50	33	33	24	34	33	33					
113	Bhola 225 MW CCPP	Gas	(PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.		
114	Bhola 95 MW PP (Aggreko)	Gas	(QRPP)	1.1x96	95	95	76	76	76	76					
115	Payra 1320 MW TPP	Coal	(BCPCL)	2x622	1244	1244	370	280	622	622					
116	Potakhali 150MW PP (UPPL)	HFO	(IPP)	8x18.415+1x9.78	150	150	0	116	110	110					
117	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD	(IPP)	2x75+1x70	220	220	218	220	220	220					
Barishal Zone Total					2046	2046	688	774	1171	1171	0	194			
118	a) Baghabari 71 MW GTTP	Gas	(PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas	(PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage		
119	Baghabari 50 MW Peaking PP	HFO	(PDB)	6x8.9	52	52	0	50	50	50					
120	Baghabari 200 MW PP (Paramount)	HSD	(IPP)	135x1.6	200	200	0	0	200	200					
121	Bera 70 MW Peaking PP	HFO	(PDB)	9x8.29	71	71	0	0	20	20					
122	Amnura 50 MW PP(Sintha)	HFO	(QRPP)	7x7.79	50	50	35	35	35	35					
123	Chapanawabganj 100 MW Peaking PP	HFO	(PDB)	12x8.924	104	104	46	92	95	95					
124	Katakhal 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	36	31	31					
125	Katakhal 50 MW PP (Northern)	HFO	(QRPP)	6x8.9	50	50	0	0	0	0					
126	Santhar 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	27	0	30					
127	Sirajgonj 225MW CCPP Unit-1	Gas	(NWPGL)	1x150+1x75	210	210	0	0	0	0		150	Gas Shortage, STG S/D		
128	Sirajgonj 225MW CCPP Unit-2	Gas	(NWPGL)	1x150 + 1x75	220	220	140	140	140	140					
129	Sirajgonj 225MW CCPP Unit-3	Gas	(NWPGL)	1x141+1x79	220	220	173	178	200	200					
130	Sirajgonj 400 MW CCPP Unit-4	Gas	(IPP)	1x282+1x132	414	414	314	415	400	400					
131	Bogra 22 MW PP (SBB)	Gas	(RPP)	6x4.0	22	22	21	22	22	22					
132	Ullapara 11 MW PP (Summit)	Gas	(SIPP, REB)	4x2.90	11	11	11	11	11	11					
133	Natore 52 MW PP (Rajlanka)	HFO	(IPP)	6x8.92	52	52	25	52	52	52					
134	Bagura 113 MW PP (Confidence) Unit-1	HFO	(IPP)	6*18.55	113	113	50	113	113	113					
135	Bagura 113 MW PP (Confidence) Unit-2	HFO	(IPP)	6x18.55	113	113	35	45	94	94					
136	Sirajgonj 6.55 MW Solar	Solar	(NWPGL)	1x6	6	6	2	0	6	0					
Rajshahi Zone Total					2179	2179	852	1216	1469	1493	321	0			
137	a) Barapukuria TPP Unit-1	Coal	(PDB)	1 x 125	125	85	78	76	74	74		9	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal	(PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
138	Barapukuria 275 MW TPP Unit-3	Coal	(PDB)	1 x 274	274	274	149	150	150	150		124	Coal Shortage		
139	Rangpur 20 MW GTTP	HSD	(PDB)	1 x 20	20	20	0	0	0	10					
140	Rangpur 113 MW PP (Confidence)	HFO	(IPP)	7*16x 2*3	113	113	0	113	113	113					
141	Saidpur 20 MW GTTP	HSD	(PDB)	1 x 20	20	20	0	0	0	10					
142	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar	(IPP)	1 x 8	8	8	4	0	8	0					
Rangpur Zone Total					685	605	231	339	345	357	218	0			
Sub-total: Plants in operation					21694	21280	10232.0	11940	14087	15283	1666	1494			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							9792	11427	13481	14626					
(B) Plants under long term maintenance/ contract expired															
143	Madaganj 102 PP(Summit)	HFO	(QRPP)	6x17	102	0	0	0	0	0					
144	Bogura 20 MW PP (Energysprima)	Gas	(RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
145	Meghnaghat 100 MW(IEI)	HFO	(QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
146	Khulna 115 MW PP (KPCL-2)	HFO	(QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired					337	0	0	0	0	0					
Gross Total					22031	21280	10232	11940	14087	15283	1666	1494			
(C) Actual data of 19.07.21 (Yesterday) Monday :															
01.	Max. Demand at eve. peak (Generation end)	:		11940.00	MW,	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:		11427.00	MW,	at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:		12268.00	MW,	at =	1:00 hrs	Dhaka	3368	3368	0	Mymensingh	1009	1009	0
04.	Minimum Generation (Generation end)	:		9616.00	MW,	at =	8:00 hrs	Chattogram	1273	1273	0	Sylhet	519	519	0
05.	Day-peak Generation (Generation end)	:		10232.00	MW,	at =	11:00 hrs	Khulna	1547	1547	0	Barishal	403	403	0
06.	Evening-peak Generation (Generation end)	:		11940.00	MW,	at =	21:00 hrs	Rajshahi	1281	1281	0	Rangpur	822	822	0
07.	Evening Peak Load-shed (Sub-station end)	:		0.00	MW,	at =	21:00 hrs	Cumilla	1205	1205	0				
08.	Minimum Generation Forecast up to 8.00 hrs.	:		7804.00	MW,	at =	5:00 hrs					Total	11427	11427	0
09.	Generation shortfall at evening peak due to :	:						13.	Fuel cost :	(a) Gas = 155954100 Taka (c) Coal = 74115888 Taka (b) Oil = 487229227 Taka Total = 717299216 Taka					
	a) Gas limitation	:		1341	MW			14.	Maximum Temperature in Dhaka was :	31.9° C					
	d) Coal supply Limitation	:		218	MW			15.	Export through East-West interconnections :	At evening peak-hour : -440 MW, at 21:00 hrs Maximum : -482 MW, at 19:30 hrs Energy : -14433.403 MKWh					
	b) Low water level in Kaptai lake	:		107	MW										
	c) Plants under shut down/ maintenance	:		1494	MW										
10.	Total Energy (Generation + India Import)	:		260.33	MKWh										
	By Gas = 150.850 MKWh														
	By Coal = 15.345 MKWh														
	By Hydro = 2.868 MKWh														
	By Solar= 0.452 MKWh														
11.	Total Gas Supplied	:		1144.79	MMCFD										
(D) Forecast of 20.07.21 (Today) Tuesday :															
01.	Maximum Demand	:		10600	MW	(Generation end)		04.	Maximum Load-shed	:		0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:		15283	MW	(Generation end)		05.	Total Generation	:		224.93	MKWh		
03.	Maximum Shortage	:		-4683	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:		32.1° C			