

Date : 11-Aug-21		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
			Unit No. X Capacity	MW	Generation	KWH	
				MW	MW	KWH	
1	Ghorasal Rewerced CAPP Unit-3	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Rewerced CAPP Unit-2	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	110	2709000	Gas shortage
4	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	310	7427245	Gas shortage
5	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	3*43.35	108	0	0	Gas shortage
7	Harihar GTPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Harihar 412 MW CCPP	EGCB	1*273+1*139	412	210	5275850	ST Under maint.
9	Harihar 360MW CCPP(HPL)	IPP	1*235+1*125	360	162	4589000	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	240	5559000	Dirty Gas
11	Meghnaghat 100 MW(IELE)	QRPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	265	6651433	FGMO
13	Madangan 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
14	Madangan 35 MW PP(Summit)	(IPP)	3*11.08+1*11.3	55	55	1306985	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	12	546536	Engine problem
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	21	446040	
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirgonj 100 PPI/Dutch Bangla	QRPP	12*8.9	100	0	0	Contract Expired
20	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	337	7862031	
21	Gaguar 102 MW PP (Digital Po	IPP	12*8.924	102	102	2200176	
22	Kalpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1311480	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	2573760	
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1331442	
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1189524	
27	Bostia 108MW PP(LO)	IPP	12*8.775+1*9.5	108	0	0	Fuel shortage
28	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	52	1146840	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	760200	
30	Ruggan 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	820600	
31	Gazipur 52 MW PP	IPP	6*8.9	52	52	990720	
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	280	5728252	
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	206	1254685	
35	Bramhangonj 100 MW PP (Aggr	IPP	100	100	50	513560	Low demand
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	102	979416	
37	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	149	3045600	
38	Gazipur 100 MW PP	RPCL	100 MW	105	105	2533200	
39	Meghnaghat 104 MW PP (PQCL)	IPP	18*9.5	104	95	2181126	Engine problem
40	Manikganj 162MW PP(MPL)	IPP	9*18	162	162	3536640	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	176663	
<b>Dhaka area Total</b>				<b>5819</b>	<b>3457</b>	<b>74654688</b>	
42	Chattogram TPP-1	PDB	1*210	180	100	2400000	Gas shortage
43	Chattogram TPP-2	PDB	1*210	180	120	3000000	Gas shortage
44	Rozari 25 MW PP	IPP	3*8.9	25	25	321004	
45	Teknaf 20MW PP (Solartech/Teknaf Solartech Energ	IPP	20	20	0	826200	
46	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	30	232320	Cable fault.
47	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	121	2873251	Low water level
48	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
49	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	2401199	
51	Hathazari 100 MW Peaking PP	PDB	11*8.9	98	0	0	Under S/D
52	Dohazari -Kalesh 100 MW Peakin	PDB	6*17	102	102	718857	
53	Judah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	100	1475520	
54	Judah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2319360	
55	Baralkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	489600	
56	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	20	435840	
57	Chattogram 108 MW PP (ECPV)	IPP	18*6	108	86	2210880	Engine problem
58	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	20641	
59	Anwara 300 MW PP (United)	IPP	300 MW	300	69	1465309	Transformer OIL
60	Jodica Power	IPP	3*18.55+1*3.6	54	0	0	Transformer OIL
61	Karnaphuli Power Ltd.	IPP	110	110	94	2402034	Transformer OIL
62	Judah unit-2 (Acorn)	IPP	8*13.6	100	100	2338560	
63	Anilma Energy Ltd.	IPP	6*21.2	116	116	2714836	
<b>Chattogram area Total</b>				<b>2382</b>	<b>1319</b>	<b>27801831</b>	
64	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
65	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
66	Ashuganj TPP Unit-5	APSCL	1*150	134	80	1913438	Gas shortage
67	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	207	4736000	FGMO
68	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	270	7070500	FGMO
69	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	270	6871000	FGMO
70	Ashuganj 50 MW CCPP	APSCL	14*3.988	45	23	457128	Engine problem
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	30	489600	Engine problem
72	Ashuganj 195MW PP (APSCL-UH)	IPP	20*9.73+1*16	195	8	200727	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	1003776	Engine problem
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	142	3330400	
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	50	779240	
76	Chandpur 150 MW CCPP	IPP	1*106+1*57	163	85	963980	Machine problem
77	Chandpur 200MW (Desh energy)	IPP	0	200	200	4239840	
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	457416	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	251820	
80	Impoport (Tripura)	Imported power	0	160	150	3244800	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	808800	
82	Jangalia 52 MW PP (Lakshinar)	IPP	6*8.92	52	52	1050283	
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	21	5014430	
84	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	100	509952	Low demand
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	2147000	
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	107	2517480	
87	Bhairab 54.5 MW	IPP	3*18.2	54	17	443160	33 kV feeder fault.
<b>Cumilla Area Total</b>				<b>3034</b>	<b>2034</b>	<b>43952470</b>	
88	RPCL 210MW CCPP	IPP	4*35+1*70	202	133	3195920	
89	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	478440	Gas shortage
90	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	8	191040	Engine problem
91	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	1800	
92	Mymensingh 200 MW PP (Unite)	IPP	200	200	181	3945600	Engine problem
93	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	111	2550000	
94	Sylhet 50 MW Solar PP	IPP	50	50	0	68770	
95	Tangail Fall Power 22 MW	IPP	4*6.7	22	24	594900	
<b>Mymensingh Area Total</b>				<b>709</b>	<b>478</b>	<b>11025730</b>	
96	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1035000	Machine problem
97	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	42	995040	Machine problem
98	Kushihara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3865254	
99	Shahbazar 330 MW CCPP	PDB	3*110	330	237	4533000	Machine problem
100	Fenchugonj 51 MW PP (Barakati)	IPP	1*92.90	51	53	1290000	
101	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
102	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	0	85440	Engine problem
103	Shahibazar GTPP Unit- 8 & 9	PDB	2*35	66	64	1491072	
104	Shahibazar 86MW PP (Shahibaz	RPP	32*2.90	86	83	1968960	
105	Shahibazar 100 MW GTTP	PDB	1*100	100	0	0	Under Shut down
106	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	105	2809990	ST Under maint.
107	Sylhet 20 MW GTTP	PDB	1*20	20	18	399000	Engine problem
108	Sylhet 50MW PP (EPL)	RPP	2*22	0	0	0	Contract Expired
109	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	492504	
110	Bibiana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	280	7245000	FGMO
111	Bibiana-III 400 MW CCPP	PDB	400 MW	400	365	8805000	FGMO
112	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	219600	
113	Bibiana South 400 MW	PDB	400 MW	383	70	917800	ST sync process.
<b>Sylhet Area Total</b>				<b>2377</b>	<b>1657</b>	<b>36072260</b>	
114	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve.
115	Bheramara (HVDC)	Imported power	2*500	1000	692	16749091	
116	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	0	0	0	Contract Expired
117	Fairdipur 50 MW Peaking PP	PDB	6*8.99	54	23	130560	Engine problem
118	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	220	70	273236	Low demand
119	Gopalganj 100 MW Peaking PP	PDB	16*8.98	109	0	0	Reserve.
120	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	290	7509024	Gas shortage
121	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	0	0	0	Contract Expired
122	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	100	576960	
123	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	2276640	
124	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
<b>Khulna Area Total</b>				<b>2128</b>	<b>1280</b>	<b>27515511</b>	
125	Basail 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
126	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	31	651110	
127	Bhola 225 MW CCPP	PDB	2*63+1*68	194	87	2115507	Machine problem
128	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	11	289365	Gas shortage
129	Payra 1320 MW	BCPCL	2*622	1244	580	11844400	
130	Bhola Nutan Biddu BD LTD	IPP	220	220	216	5146773	
131	Unite Payra Power Ltd.	IPP	8*18.8+1*9.5	150	54	372000	Line O/L
<b>Barisal Area Total</b>				<b>2046</b>	<b>979</b>	<b>20519155</b>	
132	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
133	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
134	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	43	407712	Engine problem
135	Bera 70 MW Peaking PP	PDB	9*8.29	71	40	296899	Engine problem
136	Amnara 50 MW PP(Sinha)	QRPP	7*7.9	50	35	608510	Engine problem
137	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Fuel shortage
138	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	31	190083	Engine problem
139	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
140	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	144	3686227	FGMO
141	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	172	4282682	FGMO
142	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	394	9256036	FGMO
143	Santihar 50 MW Peaking PP	PDB	6*8.9	50	25	281800	Engine problem
144	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	449040	
145	Bogura 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	Contract Expired
146	Lilapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	262836	
147	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	1066080	
148	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	93	1162016	Coal demand
149	Bagura 200 MW PP (Paramou	IPP	200 MW	200	150	7430025	Engine problem
150	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	94	2094528	Engine problem
151	Confidence Power Bogura Unit-1	IPP	6*18.55	113	95	2015328	Engine problem
152	Sirajgonj						