

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 26-Aug-21							Page 2
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-5	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	300	7280773	Machine problem
4	Ghorasal 78.5 MW PP(RP/MA)	ORPP	2*40	0	0	0	Contract Expired
5	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
6	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
7	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	353	8429670	
8	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	144	4400000	Gas shortage
9	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	270	6296250	Gas shortage
10	Meghnaghat 100 MW(IEL)	ORPP	12*8.9	0	0	0	Contract Expired
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	295	6489513	FGMO
12	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
13	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	40	879332	Engine problem
14	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	74	1035390	Engine problem
15	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	21	444600	
16	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
17	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirgonj 100 PP(Dutch Bangla	ORPP	12*8.9	100	0	0	Contract Expired
19	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	300	7378612	
20	Gangagar 102 MW PP (Digital Po	IPP	12*8.92	102	102	1741104	
21	Katpali 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
22	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	972720	
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	150	149	1875840	
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1317831	
25	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1246521	
26	Bosila 108MW RP(PLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
27	Summit Power (Madhabdi-Ashuli	SIPP, REB	3*3.67+4*8.73	80	47	1112820	Engine problem
28	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	824000	
29	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	767800	
30	Gazipur 52 MW PP	IPP	6*8.9	52	35	533280	
31	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	283	5286653	Engine problem
33	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	155	377558	
34	Bramhangaan 100 MW PP (Aggr	IPP	100	100	70	244666	Engine problem
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	102	572233	
36	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	149	3546140	
37	Gazipur 100 MW PP	RPCL	100 MW	105	90	1387200	Engine problem
38	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.9	104	95	2213760	Engine problem
39	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	162	3872160	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	45365	
Dhaka area Total				5819	3467	70671641	
40	Chattogram TPP-1	PDB	1*210	180	0	1600000	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	120	1000000	Gas shortage
41	Razzan 25 MW PP	IPP	3*8.9	25	25	313218	
42	Teknaf 20MW PP (SolarTech/Teknaf SolarTech Energ	IPP	20	20	0	99900	
43	Palanga 50MW PP (Baraka)	IPP	8*6.98	50	50	761760	
44	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	123	2955265	Low water level
45	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka St	IPP	105 MW	105	105	2449709	
48	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
49	Dohazari-Kalesh 100 MW Peakir	PDB	6*17	102	85	1179053	Engine problem
50	Juidah 100 MW Unit-1 (Acom)	ORPP	8*13.45	100	87	1549440	Engine problem
51	Juidah 100 MW PP Unit-3 (Acom)	IPP	0	100	96	2174400	Engine problem
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	452592	
	* Malancha, Cig, EP2 (United)		5*8.73+9*3.34	0	16	437760	
53	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	960	Engine problem
54	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	25559	
55	Anwara 300 MW PP (United)	IPP	300 MW	300	160	3033491	Transformer O/L
56	Jodiac Power	IPP	3*18.55+1*3.6	54	0	0	Transformer O/L
57	Karnaphuli Power Ltd.	IPP	110	110	110	2656279	
58	Juidah unit-2 (Acom)	IPP	8*13.6	100	100	2375040	
59	Anilma Energy Ltd.	IPP	6*21.2	116	114	2605691	
Chattogram area Total				2382	1211	25869307	
60	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	70	1673006	Gas shortage
61	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	188	4099000	FGMO
62	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	260	6775000	FGMO
63	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	260	6597000	FGMO
64	Ashuganj 50 MW PP	APSCL	14*3.968	45	5	144144	Gas shortage
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	0	0	Gas shortage
66	Ashuganj 195MW PP (APSCL-UN	IPP	20*9.73+1*16	195	8	217454	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	814052	Engine problem
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	128	3133018	Engine problem
69	Titas 50 MW Peaking PP	PDB	6*8.92	52	50	562848	
70	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	137	3241700	Engine problem
71	Chandpur 200MW (Desh energy)	IPP	0	200	200	4093920	
72	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	469152	
73	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	222120	
**	Impoport (Tripura)	Imported power	0	160	138	2894400	
74	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	747700	
75	Jangalia 52 MW PP (Lakdhanav)	IPP	6*8.92	52	43	759562	Engine problem
76	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	21	516880	
77	Daudkandi 200 MW PP (B. Trac)	IPP	15*11.4	200	80	469632	
78	Feni 54.5 MW	IPP	7*18.415+1*9.78	114	114	1680360	
79	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	97	2334360	Engine problem
80	Bhairab 54.5 MW	IPP	3*18.2	54	17	513360	33 KV feeder fault.
Cumilla Area Total				3034	1914	41958618	
81	RPCL 210MW CCPP	IPP	4*35+1*70	202	83	2391440	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	467856	
83	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	0	0	Engine problem
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	4200	
85	Mymensingh 200 MW PP (United	IPP	200	200	187	2527200	Engine problem
86	Jamalpur 115 MW PP (United)	IPP	115 MW	115	107	2563200	
87	Sultakhal 50 MW Solar PP	IPP	50	50	0	100300	
88	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	566640	
Mymensingh Area Total				709	422	8620636	
89	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1037000	Machine problem
90	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	42	990960	Machine problem
91	Kushiara 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3588627	
92	Shahjibazar 330 MW CCPP	PDB	3*110	330	235	5343000	Machine problem
93	Fenchugonj 51 MW PP (Barakati	RPP	12*3.5+2	51	53	1257000	
94	Fenchugonj 44MW PP (Energyprima	RPP	12*2.33+5*2	0	0	0	Contract Expired
95	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	221472	
96	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	0	0	Under maint.
97	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	84	2009280	
98	Sylhet 225 MW CCPP	PDB	1*100	100	0	0	Under Shut down
99	Sylhet 20 MW GTTP	PDB	1*142+1*89	231	0	75500	Under Shut down
	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	392900	
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	568824	Engine problem
101	Bibiana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	310	7166500	FGMO
102	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	381	8853000	
103	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	248940	
104	Bibiyana South 400 MW	PDB	400 MW	383	350	8363600	Gas shortage
Sylhet Area Total				2377	1691	40115703	
105	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	690	16674182	
106	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
107	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	12	88800	Engine problem
108	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	50	288000	Low demand
109	Gopalganj 100 MW Peaking PP	IPP	16*6.98	109	0	0	Reserve.
110	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	260	6933600	Gas shortage
	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Tre	IPP	70*1.4	100	100	694080	
112	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	2220960	
113	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
Khulna Area Total				2129	1217	26899622	
114	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
115	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	33	696328	
116	Bhola 225 MW CCPP	PDB	2*63+1*68	194	88	2103252	Machine problem
117	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	11	278057	Gas shortage
118	Payra 1320 MW	BCPCL	2*622	1244	540	12062800	
119	Bhola Nutan Biddut BD LTD	IPP	220	220	218	5060836	
120	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	17	346880	Line O/L
Barisal Area Total				2046	907	20533073	
121	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
122	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	640752	
123	Bera 70 MW Peaking PP	PDB	9*8.29	71	39	254701	Engine problem
124	Ammura 50 MW PP(Sinna)	ORPP	7*7.79	50	0	0	Fuel shortage
125	Katakhal 50 MW PP (Northern)	ORPP	6*8.9	50	0	0	Fuel shortage
126	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	32	152	