

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel.: 9564667, 9551095

Month September, 2021				Day : Wednesday				Date : 01.09.21					
Probable Maximum Demand : 13500 MW				Probable Maximum Generation : 14170 MW				Rule Curve = 99.00 ft.					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.78 ft.	Today = 98.90 ft.	01.09.21 (Yesterday)		01.09.21 (Today)		31.08.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Actual Peak Generation (MW)		Probable Peak Generation (MW)		31.08.21 Gen. shortfall for Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Gas shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	310	310				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0		108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	172	173	200	200		187	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	290	320	320	320		130	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0		412	Under maint.	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	94	93	100	100		117	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	205	208	210	210		127	STG Under maint.	
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	0	0	0				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	295	275	305	305				
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	60	73	75	75				
17	Gargagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	100	102				
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	22	22	22				
19	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	45	53	54	55				
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	52	52				
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	90	100				
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	82	133	135	135				
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	283	281	300	300				
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	143	149	149	149				
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	84	305	100	300				
30	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	70	101	100	100				
31	Aurshah 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	96	101	50	100				
32	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55				
34	Bosila 108MW PP(RCLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	95	94	94	95				
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162				
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	35	0	30	0				
Dhaka Zone Total				5976	5819	3050	3381	3243	3477	752	1199		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	102	132	130	130	98	Low Water Level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	120	120	120				
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0				
41	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50				
44	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Under maint.		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	162	214	300	300		Xfr Overload		
48	Judah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	92	92	100	100				
49	Judah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	75	100	100	100				
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue		
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	20	20				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	25	5	25				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	79	20	97				
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54		Xfr Overload		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	94	110	110	110				
56	Judah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	80	60	80	100				
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	110	114	116	116				
Chattogram Zone Total				2442	2382	1068	1312	1428	1520	278	375		
58	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage		
	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	70	70	70	70	64	Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	23	23	23				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	175	181	215	215	40	Gas Shortage		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	280	330	360				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	365	300	330	360				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	20	30	30				
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	25	25	35	35				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	118	125	135	140				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	137	140	140				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25				
73	Jangalia 52 MW PP (Lakdani)	HFO (IPP)	6x8.92	52	52	43	43	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	20	21				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x11.4+8x1.915+1x1.088	200	200	200	195	100	200				
76	Feni 11.4 MW Power Plant(Lakdani)	HFO (IPP)	7*18.15+1*9.78	114	114	99	114	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	96	95	98	98				
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	17	17				
**	Impport (Tripura)	India		160	160	120	142	138	164				
Cumilla Zone Total				3094	3034	2076	2122	2154	2346	555	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	118	111	122	122	91	Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	0	8	8				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	78	45	100				
83	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	47	175	175	180				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0				
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	18	24	22	22				
Myensingh Zone Total				717	709	306	409	445	453	91	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.08.21 (Yesterday)		01.09.21 (Today)		31.08.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	44	44		26	GT1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT 4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)		19x2.90	51	51	47	53	51	51			
90	Kushnara 163 MW CCPP (KP)	Gas (IPP)		1x109+1x54	163	163	163	163	163	163			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)		4x2.90	11	11	8	11	11	11			
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)		2x35	70	66	0	0	0	66		Gas Shortage	
93	Shahjibazar 330 MW CCPP	Gas (PDB)		2x110+1x110	330	330	231	240	235	235			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)		32x2.90	86	86	76	80	84	84			
95	Sylhet 225 MW CCPP	Gas (PDB)		1x142+1x89	231	231	221	228	225	225			
96	Sylhet 20 MW GTTP	Gas (PDB)		1 x 20	20	20	18	18	18	18			
97	Sylhet 10MW PP (Desh)	Gas (RPP)		6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)		3x9.34	25	25	24	22	24	24			
99	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)		1x222+1x119	341	341	280	315	341	341			
100	Bitiyana-II 400 MW CCPP	Gas (PDB)		1x285+1x115	400	400	405	403	400	400			
101	Bitiyana South 383 MW CCPP	Gas (PDB)		1x252+1x131	383	383	350	350	350	350			
102	Shahjibazar 100 MW GTTP	Gas (PDB)		1x100	100	100	0	0	0	0	100	Under maint.	
Sylhet Zone Total						2422	2377	1918	1979	1998	66	74	
103	Bheramara GTTP Unit- 3	HSD (PDB)		1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CCPP	Gas (NWPGLCL)		1 x 278+1 x 132	410	410	210	190	320	320	220	Gas Shortage	
105	Fandpur 50 MW Peaking PP	HFO (PDB)		8x6.98	54	54	0	25	0	26			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)		16x6.98	109	109	0	0	0	60			
107	Khulna 225 MW CCPP	HSD (NWPGLCL)		1 x 150+1x75	230	230	0	158	0	158			
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)		70x1.4+7x1.5x15	100	100	0	100	50	100			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)		6x18.445	105	105	89	89	88	88			
110	Madhumati 100 MW PP	HFO (NWPGLCL)		6x18.415	105	105	0	50	100	100		Line Overload	
**	Bheramara (HVDC)	India			1000	1000	714	711	726	726			
Khulna Zone Total						2133	2129	1013	1323	1284	1578	220	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)		7 x 17.076	110	110	0	0	110	110		Line Overload	
112	Bhola 33 MW PP (Venture)	Gas (RPP)		1x34.50	33	33	28	34	33	33			
113	Bhola 225 MW CCPP	Gas (PDB)		2x63+1x68	194	194	88	87	88	88	107	Under maint.	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)		1.1x96	95	95	76	85	11	11			
115	Payra 1320 MW TPP	Coal (BCPCL)		2x622	1244	1244	430	620	622	622	624	Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)		8x18.415+1x9.78	150	150	0	100	150	150			
117	Bhola 220MW CCPP (Nutan Bidyut Bt)	Gas/HSD (IPP)		2x75+1x70	220	220	104	60	220	220			
Barishal Zone Total						2046	2046	726	986	1234	1234	0	731
118	a) Baghabari 71 MW GTTP	Gas (PDB)		1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)		1 x 100	100	100	0	0	0	0	100	Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)		6x8.9	52	52	0	40	43	43			
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)		135x1.6	200	200	0	189	200	200			
121	Bera 70 MW Peaking PP	HFO (PDB)		9x8.29	71	71	0	27	40	42			
122	Amnura 50 MW PP (Sinha)	HFO (QRPP)		7x7.79	50	50	0	0	0	0			
123	Chapainawabganj 100 MW Peaking PP	HFO (PDB)		12x8.924	104	104	0	96	95	95			
124	Katakhali 50 MW Peaking PP	HFO (PDB)		6x8.7	50	50	0	37	30	31			
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)		6x8.9	50	50	0	0	0	0			
126	Santahar 50 MW Peaking PP	HFO (PDB)		6x8.7	50	50	0	33	0	33			
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGLCL)		1x150+1x75	210	210	70	43	130	130	75	STG S/D	
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGLCL)		1x150 + 1x75	220	220	119	118	180	180	102	Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGLCL)		1x141+1x79	220	220	119	149	220	220	71	Gas Shortage	
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)		1x282+1x132	414	414	374	385	0	0			
131	Bogra 22 MW PP (GBB)	Gas (RPP)		6x4.0	22	22	22	22	22	22			
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)		4x2.90	11	11	11	11	11	11			
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)		6x8.92	52	52	43	34	43	43			
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)		6x18.55	113	113	113	113	113	113			
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)		6x18.55	113	113	113	113	113	113			
136	Sirajgonj 6.55 MW Solar	Solar (NWPGLCL)		1x6	6	6	5	0	6	0			
Rajshahi Zone Total						2179	2179	989	1410	1246	1276	344	75
137	a) Barapukuria TPP Unit-1	Coal (PDB)		1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)		1 x 125	125	85	0	0	0	0	85	Under maint.	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)		1 x 274	274	274	152	157	155	155	117	Coal Shortage	
139	Rangpur 20 MW GTTP	HSD (PDB)		1 x 20	20	20	0	0	0	10			
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)		7x16x 2x3	113	113	106	106	113	113			
141	Saidpur 20 MW GTTP	HSD (PDB)		1 x 20	20	20	0	0	0	10			
142	Maipara, Tutula 6 MW Solar PP (Sympa Power)	Solar (IPP)		1 x 6	6	6	0	0	8	0			
Rangpur Zone Total						685	605	264	263	276	288	202	85
Sub-total: Plants in operation						21694	21280	11410.0	13185	13308	14170	2508	2539
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								10742	12413	12528	13340		
(B) Plants under long term maintenance/ contract expired													
143	Madanganj 102 PP(Summit)	HFO (QRPP)		6x17	102	0	0	0	0	0			
144	Bogura 20 MW PP (Energyprima)	Gas (RPP)		5x3.3+5x2.0	20	0	0	0	0	0		Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW(EL)	HFO (QRPP)		12x8.9	100	0	0	0	0	0		Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)		7x17	115	0	0	0	0	0		Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired						337	0	0	0	0	0		
Gross Total						22031	21280	11410	13185	13308	14170	2508	2539
(C) Actual data of 31.08.21 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	13185.00	MW, at = 21:00 hrs		12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12413.00	MW, at = 21:00 hrs		Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13185.00	MW, at = 21:00 hrs		MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	9804.00	MW, at = 7:00 hrs		Dhaka	4403	4403	0	Mymensingh	924	924	0
05.	Day-peak Generation (Generation end)	:	11410.00	MW, at = 12:00 hrs		Chattogram	1362	1362	0	Sylhet	552	552	0
06.	Evening-peak Generation (Generation end)	:	13185.00	MW, at = 21:00 hrs		Khulna	1567	1567	0	Barishal	405	405	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 21:00 hrs		Rajshahi	1227	1227	0	Rangpur	768	768	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9966.00	MW, at = 5:00 hrs		Cumilla	1205	1205	0				
09.	Generation shortfall at evening peak due to :	:								Total	12413	12413	0
	a) Gas limitation	:	2208	MW		13.	Fuel cost :	(a) Gas = 145922236 Taka	(c) Coal = 77009110 Taka				
	d) Coal supply Limitation	:	202	MW				(b) Oil = 808618165 Taka	Total = 1031549510 Taka				
	b) Low water level in Kaptai lake	:	98	MW									
	c) Plants under shut down/ maintenance	:	2539	MW		14.	Maximum Temperature in Dhaka was :	33.4° C					
10.	Total Energy (Generation + India Import)	:	275.89	MWWh		15.	Export through East-West interconnections :						
	By Gas = 136.413 MKWh	By Oil = 98.593 MKWh					At evening peak-hour	-204	MW, at 21:00 hrs				
	By Coal = 16.655 MKWh	By Hydro = 3.111 MKWh					Maximum	-368	MW, at 15:00 hrs				
	By Solar= 0.785 MKWh						Energy	3.2155	MKWh				
11.	Total Gas Supplied	:	1132.20	MMCFD									
(D) Forecast of 01.09.21 (Today) Wednesday :													
01.	Maximum Demand	:	13500	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14170	MW (Generation end)		05.	Total Generation	:	282.48	MKWh			
03.	Maximum Shortage	:	-670	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.2° C				

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)
Deputy Secretary, Generation