

**Bangladesh Power Development Board  
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 956467, 955195

Month September, 2021			Day : Thursday				Date : 02.09.21				
Probable Maximum Demand : 13300 MW			Probable Maximum Generation : 14205 MW				Rule Curve = 99.23 ft.				
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 98.90 ft.	Today = 100.05 ft.							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.09.21 (Yesterday)		02.09.21 (Today)		01.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation (MW)	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	310	310		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hariapur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Hariapur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	176	170	180	180	190	Gas Shortage
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	320	320	320	320	130	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hariapur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Under maint.
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	90	91	100	100	119	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	210	209	0	335	126	STG Under maint.
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	305	305	290	280	290	300		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	41	41	41	41		
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	44	51	50	65		
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	100	102		
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22		
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x7.3	80	80	51	54	54	55		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x7.3	33	33	33	33	33	33		
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x7.3	33	33	33	33	33	33		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	42	25	52		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	90	90	100		
23	Kodda 150MW PP	HFO (B/PDB-RPCL)	9x17.06	149	149	82	133	32	115		
24	Katipati 52 MW PP (Sirtha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
25	Kamalshah 54 MW PP (Banoo Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
26	Kodda 200 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	298	281	300	300		
27	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	125	132	116	135		
28	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	52	307	100	300		
29	Bramhangaan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	60	100	100	100		
30	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	98	101	50	100		
31	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
32	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
33	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
34	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	94	94	94	95		
35	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
36	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	14	0	30	0		
<b>Dhaka Zone Total</b>			<b>5876</b>	<b>5719</b>	<b>2896</b>	<b>3322</b>	<b>2796</b>	<b>3519</b>	<b>757</b>	<b>1198</b>	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	135	136	146	146	94	Low Water Level
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	120	120	120		
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
41	Takraf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50		
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	90	86	105	105		
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
45	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Under maint.
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	179	250	300	300		
47	Judah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	80	80	100	100		
48	Judah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	80	80	100	100		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	85	68	68		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	20	20		Environment Issue
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	27	5	25		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	25	75	12	80		
53	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	36	54	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110		
55	Judah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	60	50	80	100		
56	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	97	114	116	116		
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>1151</b>	<b>1345</b>	<b>1436</b>	<b>1519</b>	<b>274</b>	<b>375</b>	
57	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	70	70	70	70	64	Gas Shortage
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	23	23	23		
59	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1x75	221	221	169	177	175	175	44	Gas Shortage
60	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	280	280	330	360		
61	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	300	290	330	360		
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	154	55	55	20	20	30	30		
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	25	35	35	35		
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	127	129	135	140		
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50		
67	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	137	137	140	140		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	193	200	200		
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11		
71	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	17	25	25	25		
72	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43		
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	20	21		
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9914+4x81.515+15x1.056	200	200	0	90	100	200		
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	114	114	114	114		
76	Chowmahani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	99	99	98	98		
77	Bharoi 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
**	Imoport (Tripura)	India		160	160	104	134	138	164		
<b>Cumilla Zone Total</b>			<b>3094</b>	<b>3034</b>	<b>1801</b>	<b>1988</b>	<b>2114</b>	<b>2306</b>	<b>559</b>	<b>0</b>	
78	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	87	108	122	122	94	Gas Shortage
79	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8		Engine problem
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	115	45	100		
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	46	176	175	180		
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
84	Subikhalhi 50 MW Solar PP	Solar (IPP)	1x50	50	50	7	0	50	0		
85	Tangali 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22		
<b>Mymensingh Zone Total</b>			<b>717</b>	<b>709</b>	<b>242</b>	<b>452</b>	<b>445</b>	<b>453</b>	<b>94</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.09.21 (Yesterday)		02.09.21 (Today)		01.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Water/Coal limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas	Water			
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	44	44			GT1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42			GT 4 Under maint.	
88	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
89	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage	
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	241	243	235	235				
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	77	81	84	84				
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	221	225	225				
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	18	18	18				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x3.34	25	25	24	24	24	24				
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	315	341	341				
99	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	397	396	400	400				
100	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	350	350	350				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under maint.	
<b>Sylhet Zone Total</b>				<b>2422</b>	<b>2377</b>	<b>1925</b>	<b>1970</b>	<b>1998</b>	<b>1998</b>	<b>66</b>	<b>75</b>		
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	345	370	320	320	40		Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	19	0	26			Line Overload	
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60			Line Overload	
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	158	0	158				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	60	100	50	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	89	105	88	88				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	100	100			Line Overload	
**	Bheramara (HVDC)	India		1000	1000	713	713	726	726				
<b>Khulna Zone Total</b>				<b>2133</b>	<b>2129</b>	<b>1207</b>	<b>1480</b>	<b>1284</b>	<b>1578</b>	<b>40</b>	<b>0</b>		
110	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110			Line Overload	
111	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	26	34	33	33				
112	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	88	87	88	88	107		Under maint.	
113	Bhola 95 MW PP (Aggregate)	Gas (QRPP)	1.1x96	95	95	0	0	11	11				
114	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	370	600	622	622	644		Line Overload	
115	Potukhali 150MW PP (UPPL)	Gas (IPP)	8x18.415+1x9.78	150	150	0	17	150	150				
116	Bhola 220MW CAPP (Nutan Bidyt Bl)	Gas/HSD (IPP)	2x75+1x70	220	220	221	224	220	220				
<b>Barisal Zone Total</b>				<b>2046</b>	<b>2046</b>	<b>705</b>	<b>978</b>	<b>1234</b>	<b>1234</b>	<b>0</b>	<b>751</b>		
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	43	43				
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	150	187	200	200				
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	37	40	42				
121	Amnara 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	93	95	95				
123	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	31				
124	Katakhalai 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	33				
126	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	123	144	144	144	75		STG S/D	
127	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	180	200	200	200				
128	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	194	200	220	220				
129	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0	414		Under maint.	
130	Bogra 22 MW PP (SBB)	Gas (RPP)	6x4.0	22	22	20	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	35	43	43	43				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6'18.55	113	113	113	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
<b>Rajshahi Zone Total</b>				<b>2179</b>	<b>2179</b>	<b>944</b>	<b>1269</b>	<b>1280</b>	<b>1310</b>	<b>171</b>	<b>489</b>		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under maint.	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	152	158	155	155	116		Coal Shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x2'3	113	113	106	113	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Majpara, Tatulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
<b>Rangpur Zone Total</b>				<b>685</b>	<b>605</b>	<b>264</b>	<b>271</b>	<b>276</b>	<b>288</b>	<b>201</b>	<b>85</b>		
<b>Sub-total: Plants in operation</b>				<b>21594</b>	<b>21180</b>	<b>11135.0</b>	<b>13075</b>	<b>12863</b>	<b>14205</b>	<b>2162</b>	<b>2973</b>		
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>						<b>10577</b>	<b>12420</b>	<b>12218</b>	<b>13493</b>				
<b>(B) Plants under long term maintenance/contract expired</b>													
142	Sidhirganj 100 PP (Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW (EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
<b>Sub-Total: Plants under long term maintenance/contract expired</b>				<b>437</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>		
<b>Gross Total</b>				<b>22031</b>	<b>21180</b>	<b>11135</b>	<b>13075</b>	<b>12863</b>	<b>14205</b>	<b>2162</b>	<b>2973</b>		
<b>(C) Actual data of 01.09.21 (Yesterday) Wednesday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 13075.00 MW, at = 21:00 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 12420.00 MW, at = 21:00 hrs											
03.	Highest Generation (Generation end)	: 13141.00 MW, at = 23:00 hrs											
04.	Minimum Generation (Generation end)	: 9966.00 MW, at = 8:00 hrs	Dhaka	4358	4358	0	0	0	0	Mymensingh	966	966	
05.	Day-peak Generation (Generation end)	: 11135.00 MW, at = 12:00 hrs	Chattogram	1318	1318	0	0	0	0	Sylhet	540	540	
06.	Evening-peak Generation (Generation end)	: 13075.00 MW, at = 21:00 hrs	Khujna	1582	1582	0	0	0	0	Barishal	389	389	
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs	Rajshahi	1242	1242	0	0	0	0	Rangpur	804	804	
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9850.00 MW, at = 5:00 hrs	Cumilla	1221	1221	0	0	0	0				
09.	Generation shortfall at evening peak due to :												
	a) Gas limitation	: 1867 MW											
	d) Coal supply Limitation	: 201 MW											
	b) Low water level in Kaptai lake	: 94 MW											
	c) Plants under shut down/ maintenance	: 2973 MW											
10.	Total Energy (Generation + India Import)	: 281.07 MCKWh											
	By Gas = 140.260 MCKWh	By Oil = 100.623 MCKWh											
	By Coal = 16.374 MCKWh	By Hydro = 3.196 MCKWh											
	By Solar = 0.481 MCKWh												
11.	Total Gas Supplied	: 1125.19 MMCFD											
<b>(D) Forecast of 02.09.21 (Today) Thursday :</b>													
01.	Maximum Demand	: 13300 MW (Generation end)											
02.	Maximum Generation	: 14205 MW (Generation end)											
03.	Maximum Shortage	: -905 MW (Generation end)											
04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)											
05.	Total Generation	: 284.47 MCKWh											
06.	Probable Max. Temperature in Dhaka	: 32.6° C											

\* Captive Power \*\* Imported Power  
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazool Islam Shaker)  
Deputy Secretary, Generation