

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 955095

Month September, 2021				Day : Sunday				Date : 05.09.21					
Probable Maximum Demand : 13800 MW				Probable Maximum Generation : 14592 MW									
Water Level of Kaptai Lake at 06:00 AM				Rule Curve = 99.92 ft.									
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.09.21 (Yesterday)		05.09.21 (Today)		04.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190		Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	203	203	203	203				
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0		108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	CB Problem
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20		Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	283	217	330	330		143		Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	320	320		170		Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	386	394	360	360		18		Gas Shortage
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	100	100		210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	323	328	335	335				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	250	270	270	270				
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	41	41	41	41				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	60	81	86	86				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	100	102				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22				
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x3.73	80	80	54	54	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33				
20	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	17	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	51	8	52				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	53	90	90	100				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	115	16	133				
24	Kalpott 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	51	0	0	0	0				
25	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54				
26	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	300	300	300	300				
27	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	116	149				
28	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	33	305	100	300				
29	Bramhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	98	100	100				
30	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	26	98	50	100				
31	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55				
32	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
33	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
34	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	90	95	95				
35	Manikgonj 162MW PP(MPLG)	HFO (IPP)	9x18	162	162	162	162	162	162				
36	Manikgonj 35MW Solar PP (Inspectra Solar)	Solar (IPP)	1x35	35	35	34	0	30	0				
Dhaka Zone Total				5876	5719	3048	3661	3519	3945	859	660		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	106	109	125	125		121		Low Water Level
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	120	120	120				
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0				
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	15	25	25	25				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	50	50	50				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	55	71	105	105				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0			225	Under maint.
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x3.84	300	300	64	305	300	300				
47	Judah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	80	100	100	100				
48	Judah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	63	100	100	100				
49	Dohazani -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	85	68	85				
50	Hathazani 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				Environment issue
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	17	20	20				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x3.34			2	17	5	10				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	95	12	95				
53	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	27	54	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	106	110	110	110				
55	Judah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	50	100	80	100				
56	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	4	116	116	116				
Chattogram Zone Total				2442	2382	798	1474	1415	1515	301	375		
57	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0		135		Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0		129		Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	70	0	0	0		134		Gas Shortage
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	23	23	23				
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	193	209	210	210				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	270	275	330	360				
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	265	330	360				
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	40	55	55			15	Gas shortage
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8			187	Gas shortage
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	35	35	35				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	103	108	142	145				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	140	136	140	140				
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	178	198	200	200				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	22	22				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	20				
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89*1.4+84*1.515+15*1.058	200	200	50	200	100	200				
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	100	100				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	98	97	98	98				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
**	Imoport (Tripura)	India		160	160	124	146	138	163				
Cumilla Zone Total				3094	3034	1716	2040	2047	2285	600	0		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	117	119	160	160		83		Gas Shortage
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	21	21				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	1	8	8	8				Engine problem
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	115	110	110				
82	Mymsensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	46	174	175	190				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
84	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	50	0	50	0				
85	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	24	24	22	22				
Mymsensingh Zone Total				717	709	307	459	548	511	83	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.09.21 (Yesterday)		05.09.21 (Today)		04.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	44	44		27	GT1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	42	42		49	GT 4 Under maint.	
88	Fenchugonj 51 MW PP (Barakutullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	11	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage	
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	158	160	160	160				
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	44	44	84	84				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	222	210	225	225				
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	18	18				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	300	341	341				
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	239	160	300	300				
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	387	393	300	350				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under maint.	
Sylhet Zone Total				2422	2377	1611	1602	1773	1823	66	76		
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 276+1 x 132	410	410	395	405	375	375				
104	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	3	20	0	26			Line Overload	
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60			Line Overload	
106	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	158	0	158				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	88	88	88	88				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			Line Overload	
**	Bheramara (HVDC)	India		1000	1000	716	713	729	729				
Khulna Zone Total				2133	2129	1202	1484	1342	1636	0	0		
110	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
111	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	28	34	33	33				
112	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	65	88	88		129	Under maint.	
113	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x56	95	95	21	22	11	11				
114	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	370	610	622	622		634	Line Overload	
115	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	79	150	150				
116	Bhola 220MW CCPP (Nutan Bidyut Bt)	Gas/HSD (IPP)	2x75+1x70	220	220	212	220	220	220				
Barishal Zone Total				2046	2046	696	1030	1234	1234	0	763		
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	43	43				
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	181	200	200				
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	33	40	42				
121	Amura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	35	35	35	35				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	93	95	95				
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	30	40				
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	0	0				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	18	0	33				
126	Siragajonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	144	144	135	145		75	STG S/D	
127	Siragajonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	201	211	200	200				
128	Siragajonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	197	184	220	220				
129	Siragajonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0		414	Under maint.	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	18	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	43	43				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
135	Siragajonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total				2179	2179	885	1323	1306	1355	171	489		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under maint.	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	156	157	155	155	117		Coal Shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	108	113	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Majpara, Tatalia 8 MW Solar PP (Sympa Powe	Solar (IPP)	1 x 8	8	8	3	0	8	0				
Rangpur Zone Total				685	605	267	270	276	288	202	85		
Sub-Total: Plants in operation				21594	21180	10530.0	13343	13460	14592	2282	2448		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9985	12652	12763	13836				
(B) Plants under long term maintenance/ contract expired													
142	Sidhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired				437	0	0	0	0	0				
Gross Total				22031	21180	10530	13343	13460	14592	2282	2448		
(C) Actual data of 04.09.21 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	13343.00	MW,	at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	12652.00	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	13343.00	MW,	at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	9938.00	MW,	at =	9:00 hrs	Dhaka	4344	4344	0	Mymensingh	955	955
05.	Day-peak Generation (Generation end)	:	10530.00	MW,	at =	12:00 hrs	Chattogram	1257	1257	0	Sylhet	587	587
06.	Evening-peak Generation (Generation end)	:	13343.00	MW,	at =	21:00 hrs	Khulna	1673	1673	0	Barishal	370	370
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Rajshahi	1366	1366	0	Rangpur	803	803
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10120.00	MW,	at =	5:00 hrs	Cumilla	1297	1297	0			
09.	Generation shortfall at evening peak due to :	:									Total	12652	12652
	a) Gas limitation	:	1959	MW			13.	Fuel cost :	(a) Gas = 141379627 Taka	(c) Coal = 75361669 Taka			
	d) Coal supply Limitation	:	202	MW					(b) Oil = 801892838 Taka	Total = 1018634134 Taka			
	b) Low water level in Kaptai lake	:	121	MW									
	c) Plants under shut down/ maintenance	:	2448	MW									
10.	Total Energy (Generation + India Import)	:	277.07	MKWh			14.	Maximum Temperature in Dhaka was :		34.5° C			
	By Gas = 139.455 MKWh			By Oil = 97.465 MKWh			15.	Export through East-West interconnections :					
	By Coal = 16.274 MKWh			By Hydro = 2.808 MKWh				At evening peak-hour	:	-322	MW,	at	21:00 hrs
	By Solar= 0.711 MKWh							Maximum	:	-394	MW,	at	24:00
11.	Total Gas Supplied	:	1096.76	MMCFD				Energy	:	2.503	MKWh		
(D) Forecast of 05.09.21 (Today) Sunday :													
01.	Maximum Demand	:	13800	MW	(Generation end)		04.	Maximum Load-shed		:	0	MW	At evening peak (Sub-station end)
02.	Maximum Generation	:	14592	MW	(Generation end)		05.	Total Generation		:	286.56	MKWh	
03.	Maximum Shortage	:	-792	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :		:	34.1° C		

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzl Islam Shaker)
Deputy Secretary, Generation