

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month September, 2021					Day : Tuesday		Date : 07.09.21						
Probable Maximum Demand : 13300 MW					Probable Maximum Generation : 14395 MW								
Water Level of Kaptai Lake at 06:00 AM					Rule Curve = 100.38 ft.								
Sl. No.	Name of Power Station	Unit	No. of Unit x Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Today = 103.93 ft.		07.09.21 (Today)		06.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW			
						Day	Evening	Day	Evening	MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas	(PDB)	1 x 260	260	260	0	0	0	0	260	Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas	(PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering	
	b) Ghorasal TPP Unit-5	Gas	(PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas	(PDB)	1x 254+1x 126	365	365	203	203	203	203	126	STG Under maint	
4	Ghorashal 108MW PP (Regent)	Gas	(IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas	(PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Haripur GTPP	Gas	(PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas	(IPP)	1x235+1x125	360	360	204	180	220	220	180	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas	(IPP)	2x140+1x170	450	450	320	320	320	320	130	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas	(PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas	(EGCB)	1x273+1x139	412	412	365	363	360	360	49	Gas Shortage	
11	Siddhirgonj 2120 MW GTPP	Gas	(EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas	(EGCB)	1 x 217+1x118	335	335	260	270	335	335	65	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS	(IPP)	2x110+1x110	305	305	265	295	305	305			
14	Madanganj-55 MW PP(Summit)	HFO	(IPP)	5x17.06+1x11.3	55	55	40	40	41	41			
15	Keraniganj 100 MW PP (Powerpac)	HFO	(QRPP)	8x13.45	100	100	39	60	65	65			
16	Gagragar 102 MW PP (Digital Power)	HFO	(IPP)	12x8.924	102	102	102	102	64	102			
17	Narsingdi 22 MW PP (Doreen)	Gas	(SIPP, REB)	8x2.90	22	22	18	21	22	22			
18	Summit Power, (Madhabdi-Ashulia)	Gas	(SIPP, REB)	6x3.67+3x3.73	80	80	53	53	55	55			
19	Maona 33 MW PP(Summit)	Gas	(SIPP, REB)	4x3.73	33	33	33	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas	(SIPP, REB)	4x3.73	33	33	17	33	33	33			
21	Gazipur 52 MW PP	HFO	(RPCL)	6x8.90	52	52	25	51	51	51			
22	Gazipur 100 MW PP	HFO	(RPCL)	6x18.415	105	105	53	90	90	90			
23	Kodda 150MW PP	HFO	(BPDB-RPCL)	9x17.06	149	149	48	133	32	133			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO	(IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO	(IPP)	18x17.076	300	300	300	300	300	300			
26	Kodda 140 MW PP Unit-1 (Summit)	HFO	(IPP)	8x18.415+1x8.97	149	149	132	132	116	149			
27	Keraniganj 300 MW PP (APR)	HSD	(IPP)	256x1.4	300	300	200	230	100	300			
28	Bramhangon 100 MW PP (Aggreko)	HSD	(IPP)	23x0.85+91x.959	100	100	92	94	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD	(IPP)	23x0.85+91x.959	100	100	99	100	50	100			
30	Nababganj 55 MW PP (Southern power)	HFO	(IPP)	3x19.3	55	55	35	35	55	55			
31	Manikganj 55 MW PP (Northern)	HFO	(IPP)	3x19.3	55	55	37	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO	(IPP)	6x18.5	104	104	74	75	95	95			
33	Manikgonj 162MW PP(MPGL)	HFO	(IPP)	9x18	162	162	162	162	162	162			
34	Manikgonj 35MW Solar PP (Inspectra)	Solar	(IPP)	1x35	35	35	36	0	30	0			
Dhaka Zone Total				5717	5560	3266	3484	3346	3738	952	786		
35	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro	(PDB)	2x40, 3x50	230	230	105	145	145	145	85	Low Water Level	
36	a) Chattogram TPP-1	Gas	(PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
37	b) Chattogram TPP-2	Gas	(PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage	
38	Kaptai 7 MW Solar PP	Solar	(PDB)	7	7	7	0	0	5	0			
39	Razcan 25 MW PP	HFO	(RPCL)	3x8.9	25	25	25	25	25	25			
40	Teknaf 20MW PP (Solartech)	Solar	(IPP)	1x20	20	20	0	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO	(IPP)	8x6.89	50	50	48	50	50	50			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO	(IPP)	6x18.415	105	105	71	71	89	89			
43	Sikalbaha Peaking GT	Gas	(PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCPP	Gas	(PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Under maint.	
45	Anwara 300 MW PP (United)	HFO	(IPP)	17x17.076+3x4.94	300	300	305	285	300	300			
46	Judha 100 MW Unit-1 (Acom)	HFO	(QRPP)	8x13.45	100	100	80	80	100	100			
47	Judha 100 MW PP Unit-3 (Acom)	HFO	(IPP)	8x13.45	100	100	76	100	100	100			
48	Dohazari -Kalaish 100 MW Peaking	HFO	(PDB)	6x17.0	102	102	0	85	85	85			
49	Hathazari 100 MW peaking PP	HFO	(PDB)	11x8.9	98	98	0	0	0	0		Environment Issue	
50	Barakunda 22 MW PP (Regent)	Gas	(SIPP, PDB)	8x2.90	22	22	18	20	20	20			
51	* Malancha, Ctg EPZ (United)	Gas		5x8.73+3x9.34			10	9	5	10			
52	Chattogram 108 MW PP (IECPV)	HFO	(IPP)	16x7.00	108	108	6	90	50	95			
53	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO	(IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
54	Karnaphuli Power Ltd.	HFO	(IPP)	6x18.41+1x6.4	110	110	104	110	110	110			
55	Judha unit-2 (Acom)	HFO	(IPP)	8x13.6	100	100	80	100	80	100			
56	Chattogram 116 MW PP (Anima Ener)	HFO	(IPP)	6x21.06	116	116	116	114	116	116			
Chattogram Zone Total				2442	2382	1218	1458	1474	1519	325	375		
57	a) Ashuganj TPP Unit-3	Gas	(APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
58	b) Ashuganj TPP Unit-4	Gas	(APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
59	c) Ashuganj TPP Unit-5	Gas	(APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
60	Ashuganj 50 MW PP	Gas	(APSCL)	14x3.968	53	45	23	23	23	23			
61	Ashuganj 225 MW CCPP	Gas	(APSCL)	1x142+1775	221	221	181	207	210	210			
62	Ashuganj 450 MW CCPP(South)	Gas	(APSCL)	1x360	360	360	300	300	300	330			
63	Ashuganj 450 MW CCPP(North)	Gas	(APSCL)	1x361	360	360	280	280	300	330			
64	Ashuganj 55 MW PP (Precision)	Gas	(RPP)	15'4	55	55	20	20	5	5	35	Gas shortage	
65	Ashuganj 106MW PP (APSCL-United)	Gas	(IPP)	20'9.73+11'6	195	195	8	8	8	8	187	Gas shortage	
66	Ashuganj 51 MW PP (Midland)	Gas	(IPP)	6x9.34	51	51	35	35	35	35			
67	Ashuganj 150MW PP (Midland)	HFO	(IPP)	23x7.015	150	150	132	138	142	145			
68	Titas 50 MW Peaking PP	HFO	(PDB)	6x8.92	52	52	0	48	0	50			
69	Chandpur 150 MW CCPP	Gas	(PDB)	1X106+1x57	163	163	140	141	140	140			
70	Chandpur 200MW (Desh energy)	HFO	(IPP)	12x18.415	200	200	200	190	200	200			
71	Feni 22MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	19	21	22	22			
72	Feni 11 MW PP (Doreen)	Gas	(SIPP, REB)	4x2.90	11	11	8	8	11	11			
73	Jangalia 33MW PP (Summit)	Gas	(SIPP, PDB)	4x8.73	33	33	25	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO	(IPP)	6x8.92	52	52	43	43	43	43			
75	Cumilla 25 MW PP (Summit)	Gas	(SIPP, REB)	3x3.67+2x6.97	25	25	18	19	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD	(IPP)	96'1.4+86'1.515+15x1.058	200	200	200	150	100	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO	(IPP)	7'18.415+1'9.78	114	114	114	98	114	114			
78	Chowmuhani 113 MW	HFO	(IPP)	12'9.78+2'3.1	113	113	98	98	98	98			
79	Bharob 54 MW PP	HFO	(IPP)	3x18.2	54	54	18	35	17	35			
80	** Imoport (Tripura)	India			160	160	122	148	138	163			
Cumilla Zone Total				3094	3034	1984	2035	1951	2207	620	0		
81	RPCL 210MW CCPP	Gas	(IPP)	4x35+1x70	210	202	108	119	135	135	83	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	21	21	21	21			
83	Jamalpur 95 MW PP(Powerpac)	HFO	(IPP)	12x8.924	95	95	8	8	8	8		Dependable cap. : 8MW	
84	Jamalpur 115 MW PP (United)	HFO	(IPP)	12x9.87	115	115	38	115	115	115			
85	Mymensingh 200 MW PP (United)	HFO	(IPP)	21x9.780	200	200	37	184	175	190			
86	Sarishabari 3 MW Solar Plant	Solar	(IPP)	1x3	3	3	0	0	1.6	0			
87	Sutakhal 50 MW Solar PP	Solar	(IPP)	1x50	50	50	23	0	50	0			
88	Tangail 22 MW PP(PGL)	HFO	(IPP)	4x6.7	22	22	18	24	22	22			
Mymensingh Zone Total				717	709	253	471	528	491	83	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.09.21 (Yesterday)		07.09.21 (Today)		06.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	44		27	GT1 Under maint.	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	42	42	49	GT 4 Under maint.	
86	Fenchugonj 51 MW PP (Barakatalullah)	Gas (RPP)	19x2.90	51	51	47	50	51	51			
87	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163			
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
89	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66	Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	158	160	160	160	170	Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	44	81	84	84			
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	221	228	225	225			
93	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	18	18			
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10			
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24			
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	320	341	341			
97	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	316	315	315	315			
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	325	325	325	325			
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under maint.	
Sylhet Zone Total					2422	2377	1644	1761	1813	1813	236	76
100	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	335	260	260	260			
102	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	26	0	26		Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60		Line Overload	
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	40	158	0	158			
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	41	100	50	100			
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	88	88	88	88			
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100		Line Overload	
**	Bheramara (HVDC)	India		1000	1000	718	717	729	729			
Khulna Zone Total					2133	2129	1222	1349	1227	1521	0	0
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110		Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	29	33	33			
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	15	88	88	88	106	Under maint.	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x56	95	95	61	11	11	11			
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	380	520	622	622		Line Overload	
113	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	150	150			
114	Bhola 220MW CCPP (Nutan Bidyt BL)	Gas/HSD (IPP)	2x75+1x70	220	220	200	220	220	220			
Barisal Zone Total					2046	2046	676	919	1234	1234	0	830
115	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	43	50			
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	100	50	200	200			
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	39	40	42			
119	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	35	35	35	35			
120	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	85	84	85			
121	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	40			
122	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0			
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	18	0	33			
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	120	0	0	0	210	Gas Shortage	
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	181	163	200	200			
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	177	182	200	200			
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	6	410	410	410			
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	22	22			
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
130	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	25	25	25	25			
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	113	113	113	113			
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	110	113	113	113			
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0			
Rajshahi Zone Total					2179	2179	900	1342	1532	1579	381	0
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under maint.	
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	152	150	155	155	124	Coal Shortage	
136	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	15			
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	99	113	113	113			
138	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10			
139	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
Rangpur Zone Total					685	605	258	263	276	293	209	85
Sub-total: Plants in operation					21435	21021	11421.0	13082	13381	14395	2806	2152
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss							10833	12409	12692	13654		
(B) Plants under long term maintenance/ contract expired												
140	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
141	Bosila 108MW PP(LCL)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0		Contract Expired	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
144	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0		Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0		Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0		Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	159	0	0	0	0		
Gross Total					22031	21180	11421	13082	13381	14395	2806	2152
(C) Actual data of 06.09.21 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	13082.00	MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12409.00	MW, at = 19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13082.00	MW, at = 19:30 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	9847.00	MW, at = 7:00 hrs	Dhaka	4547	4547	0	Mymensingh	962	962	0
05.	Day-peak Generation (Generation end)	:	11421.00	MW, at = 12:00 hrs	Chattogram	1236	1236	0	Sylhet	475	475	0
06.	Evening-peak Generation (Generation end)	:	13082.00	MW, at = 19:30 hrs	Khulna	1534	1534	0	Barisal	345	345	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 19:30 hrs	Rajshahi	1337	1337	0	Rangpur	770	770	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9634.00	MW, at = 5:00 hrs	Cumilla	1203	1203	0				
09.	Generation shortfall at evening peak due to :	:							Total	12409	12409	0
	a) Gas limitation	:	2512	MW	13.	Fuel cost :	a) Gas = 138869674 Taka	(c) Coal = 72844060 Taka				
	d) Coal supply Limitation	:	209	MW			b) Oil = 839449675 Taka	Total = 1051163408 Taka				
	b) Low water level in Kapit lake	:	85	MW								
	c) Plants under shut down/ maintenance	:	2152	MW	14.	Maximum Temperature in Dhaka was :	34.8° C					
10.	Total Energy (Generation + India Import)	:	278.83	MKWh	15.	Export through East-West interconnections :						
	By Gas = 137.622 MKWH			By Oil = 101.780 MKWh		At evening peak-hour	:	-332	MW, at 19:30 hrs			
	By Coal = 15.709 MKWH			By Hydro = 2.909 MKWh		Maximum	:	-482	MW, at 1:00 hrs			
	By Solar = 0.745 MKWH					Energy	:	3.1725	MKWh			
11.	Total Gas Supplied	:	1094.94	MMCFD								
(D) Forecast of 07.09.21 (Today) Tuesday :												
01.	Maximum Demand	:	13300	MW (Generation end)	04.	Maximum Load-shed	:	0	MW At evening peak (Sub-station end)			
02.	Maximum Generation	:	14395	MW (Generation end)	05.	Total Generation	:	283.48	MKWh			
03.	Maximum Shortage	:	-1095	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	34.4° C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation