

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2021					Day : Wednesday				Date : 08.09.21				
Probable Maximum Demand : 13500 MW					Probable Maximum Generation : 14315 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 103.93		Today = 104.56		Rule Curve = 100.61				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.09.21 (Yesterday)		08.09.21 (Today)		07.09.21 (Yesterday)		08.09.21 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW		Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Gas shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+ 1x 126	365	365	203	203	203	203		126	STG Under maint	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0		108	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	167	152	200	200		208	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280		170	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	362	358	350	350		54	Gas Shortage	
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	270	270	270	270		65	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	280	285	305	305				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	41	41				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	12	12	65	85				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	64	102				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	21	22	22				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x3.73	80	80	53	54	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	33	33	33	33				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	33	47	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	90	90	90				
23	Kodda 150MW PP	HFO (BRDB-RPCL)	9x17.06	149	149	64	133	32	133				
24	Kamalshah 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	285	300	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	116	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	28	308	100	300				
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	75	100	100				
29	Aurshah 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	93	99	50	100				
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	94	95	95	95				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162				
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	22	0	30	0				
Dhaka Zone Total				5717	5560	3012	3465	3211	3623	1025	786		
35	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	150	148	163	163		40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	120	120	120		60	Gas Shortage	
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0				
38	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	45	50	50	50				
41	Sikalbaha 105 MW PP (Baraka Sikab	HFO (IPP)	6x18.415	105	105	88	88	89	89				
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+ 1 x 75	225	225	0	0	0	0		225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	142	305	300	300				
45	Julda 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	92	100	100	100				
46	Julda 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	84	100	100	100				
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	85	85				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment Issue	
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	20	20				
50	* Malancha Ctg.EPZ (United)	Gas	5x8.73+3x9.34			4	20	5	20				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	51	50	51				
52	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	36	54	54				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
54	Julda unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	80	100	80	100				
55	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	114	114	116	116				
Chattogram Zone Total				2442	2382	1137	1470	1492	1503	240	415		
56	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	0	0	0	0		135	Gas Shortage	
57	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0		129	Gas Shortage	
58	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0		134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	20	23	23	23				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	183	196	210	210				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	300	320	300	330				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	300	300	300				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5		50	Gas shortage	
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8		187	Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	35	35	35				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	128	130	142	145				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	142	139	140	140				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	20	20				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	36x1.4+40x1.035+15x1.036	200	200	200	200	100	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	98	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	98	98	98	98				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	35	35				
79	Imporgt (Tripura)	India		160	160	102	142	138	163				
				3094	3034	1932	2098	1969	2177	635	0		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	105	109	135	135		93	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8			Dependable cap. 8MW	
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	38	115	115	115				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	39	188	175	190				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0				
87	Tangail 22 MW PP(PDGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22				
Mymensingh Zone Total				717	709	282	465	528	491	93	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.09.21 (Yesterday)		08.09.21 (Today)		07.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	44	44		27	GT1 Load gear problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	42	42		49	GT 4 Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	51	51				
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	156	163	160	160	167		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	80	81	84	84				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	221	207	225	225				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	300	341	341				
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	315	315	315	315				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	325	325	325	325				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
Sylhet Zone Total						2422	2377	1689	1723	1813	1813	253	76
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	225	210	260	260				
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	20	0	26			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60			Line Overload	
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	10	230	110	230				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	70	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	88	88	88	88				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			Line Overload	
**	Bheramara (HVDC)	India		1000	1000	715	718	731	731				
Khulna Zone Total						2133	2129	1038	1336	1339	1595	0	0
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	34	33	33				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	89	88	88	88		106	Arrival of GT2 HGPI experts delayed due to covid 19	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	12	12	12	12				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	360	570	622	622		674	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	220	218	220	220				
Barishal Zone Total						2046	2046	702	922	1235	1235	0	780
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	120	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	38	40	42				
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	35	35	35	35				
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	86	86				
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	30	40				
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	19	0	33				
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	127	120	200	200				
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	152	129	200	200				
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	386	400	410	410				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	18	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	25	25	25	25				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total						2179	2179	976	1313	1541	1580	381	0
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	152	155	160	160	119		Coal Shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	79	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
Rangpur Zone Total						685	605	235	268	281	298	204	85
Sub-total: Plants in operation						21435	21021	11003.0	13060	13409	14315	2831	2142
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10447	12400	12731	13592				
(B) Plants under long term maintenance/ contract expired													
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired						596	159	0	0	0	0		
Gross Total						22031	21180	11003	13060	13409	14315	2831	2142
(C) Actual data of 07.09.21 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	13060.00	MW,	at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	12400.00	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	13060.00	MW,	at =	21:00 hrs		MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	9634.00	MW,	at =	8:00 hrs	Dhaka	4463	4463	0	Mymensingh	1030	1030
05.	Day-peak Generation (Generation end)	:	11003.00	MW,	at =	12:00 hrs	Chattogram	1279	1279	0	Sylhet	564	564
06.	Evening-peak Generation (Generation end)	:	13060.00	MW,	at =	21:00 hrs	Khulna	1475	1475	0	Barishal	354	354
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Rajshahi	1255	1255	0	Rangpur	790	790
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9638.00	MW,	at =	5:00 hrs	Cumilla	1190	1190	0			
09.	Generation shortfall at evening peak due to :	:									Total	12400	12400
a)	Gas limitation	:	2627	MW			13.	Fuel cost :	(a) Gas = 139517538	Taka	(c) Coal = 71710490	Taka	
d)	Coal supply Limitation	:	204	MW				(b) Oil = 773580863	Taka	Total = 984808890	Taka		
b)	Low water level in Kapitai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	2142	MW			14.	Maximum Temperature in Dhaka was :	32.0° C				
10.	Total Energy (Generation + India Import)	:	275.81	MKWh			15.	Export through East-West interconnections :					
	By Gas = 139.651	MKWh	By Oil = 96.439	MKWh				At evening peak-hour	:	-268	MW,	at	21:00 hrs
	By Coal = 15.447	MKWh	By Hydro = 3.500	MKWh				Maximum	:	-384	MW,	at	1:00 hrs
	By Solar= 0.682	MKWh						Energy	:	2.3135	MKWh		
11.	Total Gas Supplied	:	1075.72	MMCFD									
(D) Forecast of 08.09.21 (Today) Wednesday :													
01.	Maximum Demand	:	13500	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14315	MW	(Generation end)		05.	Total Generation	:	285.11	MKWh		
03.	Maximum Shortage	:	-815	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.3° C			

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation