

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		8-Sep-21				Page -2	
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
3	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	203	4827200	ST Under maint.
4	Ghorashal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	355	8632320	Gas shortage
7	Haripur 360MW CCGP(HPL)	IPP	1*235+1*125	360	140	4240000	Gas shortage
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	280	6841750	Gas shortage
9	Meghnaghat 100 MW(IEL)	ORPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	265	6418589	FGMO
11	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	40	965955	Engine problem
13	Keranganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	52	920685	Fuel shortage
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	21	484894	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	0	0	0	Contract Expired
18	Siddhirgonj 335 MW CCGP	EGCB	1*217+118	335	270	6620448	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	102	2175408	
20	Katpali 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	1281240	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	133	1397280	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1251373	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	1291064	
25	Bosila 108MW PP(ELCL)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
26	Summit Power (Madhabadi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	5	1258260	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	821400	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	707400	
29	Gazipur 52 MW PP	IPP	6*8.9	52	51	663360	Fuel shortage
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	298	6375598	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	307	2707976	
33	Bramhangsan 100 MW PP (Aggreko)	IPP	100	100	99	1096347	
34	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	98	1236980	
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3411360	
36	Gazipur 100 MW PP	RPCL	100 MW	105	90	843600	Fuel shortage
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	94	2211840	Engine problem
38	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	3915360	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	219201	
Dhaka area Total				5719	3493	72816878	
40	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	120	3000000	Gas shortage
41	Raozan 25 MW PP	IPP	3*8.9	25	25	421419	
42	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energ	20	20	0	124065	
43	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	511200	
44	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	118	2926353	Low water level
45	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	88	2118509	Engine problem
48	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
49	Dohazari-Kalash 100 MW Peaking	PDB	8*17	102	85	598445	Engine problem
50	Jaldah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	100	1672560	
51	Jaldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	2142720	
52	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	450288	
*	Malancha Ctg. EP2 (United)		5*8.73+3*9.34	0	3	405120	
53	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	51	396480	Fuel shortage
54	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	33959	
55	Anwara 300 MW PP (United)	IPP	300 MW	300	305	3864000	
56	Jodica Power	IPP	3*18.55+1*3.6	54	54	1145438	
57	Karnaphuli Power Ltd.	IPP	110	110	110	2325080	
58	Jaldah unit-2 (Acorn)	IPP	8*13.6	100	100	2287680	
59	Anlima Energy Ltd.	IPP	6*21.2	116	114	2742436	
Chattogram area Total				2382	1433	27165752	
60	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
61	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	213	5039000	
62	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	280	7194000	Gas shortage
63	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	280	7015000	Gas shortage
64	Ashuganj 50 MW PP	APSCL	14*3.968	45	23	521568	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	30	460560	Gas shortage
66	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	217454	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	821124	Engine problem
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	128	3181527	Engine problem
69	Titas 50 MW Peaking PP	PDB	6*8.92	52	50	655416	
70	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	141	3355400	Engine problem
71	Chandpur 200MW (Desh energy)	IPP	0	200	200	4475520	
72	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	478476	
73	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	219960	
**	Impoport (Tripura)	Imported power	0	160	148	2998080	
74	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	25	612600	Engine problem
75	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	43	1039142	Engine problem
76	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	21	527270	
77	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	200	2399916	
78	Feni Lanka Power	IPP	7*18.415+1*9.78	114	98	2250360	Engine problem
79	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	98	2321760	Engine problem
80	Bhairab 54.5 MW	IPP	3*18.2	54	17	761760	33 kV feeder fault.
Cumilla Area Total				3034	2067	46551593	
81	RPCL 210MW CCGP	IPP	4*35+1*70	202	110	2763680	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	487944	
83	Jamalpur 95 MW PP (Powerpac)	IPP	12*9.924	95	2	79680	Engine problem
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12500	
85	Mymensingh 200 MW PP (United)	IPP	200	200	185	2188800	Engine problem
86	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1566000	
87	Sutiakhal 50 MW Solar PP	IPP	50	50	0	287160	
88	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	24	496320	
Mymensingh Area Total				769	458	782084	
89	Fenchuganj CCGP Phase-1	PDB	2*32+1*33	70	43	103000	Machine problem
90	Fenchuganj CCGP Phase-2	PDB	2*35+1*35	90	41	981240	Machine problem
91	Kushmara 163 MW CCGP (KP)	IPP	1*109+1*54	163	163	3733527	
92	Shahjibazar 330 MW CCGP	PDB	3*110	330	161	3722000	GT-2 under maint.
93	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	50	1155000	
94	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
95	Hobiganj 11MW PP (Confidence-E	SIPP, REB	4*2.90	11	11	174816	
96	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	0	0	Gas shortage
96	Shahjibazar 66MW PP (Shahjibazar)	RPP	32*2.90	86	80	1809600	
97	Shahjibazar 100 MW GTPP	PDB	1*100	100	0	0	Under Shut down
98	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	220	5135940	
99	Sylhet 20 MW GTPP	PDB	1*20	20	0	0	Gas shortage
100	Sylhet 50MW PP (EPL)	RPP	2*72	0	0	0	Contract Expired
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	446160	Engine problem
101	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	280	7233500	FGMO
102	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	316	7574000	Gas shortage
103	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	0	0	Gas shortage
104	Bibiyana South 400 MW	PDB	400 MW	383	325	7805300	
Sylhet Area Total				2377	1706	48007083	
105	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	716	17338181	
106	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
107	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	22	149280	Engine problem
108	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	230	4463040	
109	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Line O/L
110	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	210	5271840	Gas shortage
110	Noapara 40 MW PP (Khanjahan Ali)	ORPP	5*8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	100	905280	
112	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	88	1960320	Engine problem
113	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	134208	Line O/L
Khulna Area Total				2129	1366	30222149	
114	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	12768	Line O/L
115	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	34	891586	
116	Bhola 225 MW CCGP	PDB	2*63+1*68	194	88	1821710	Machine problem
117	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	11	330798	Gas shortage
118	Payra 1320 MW	BCPCL	2*622	1244	560	10637300	Line O/L
119	Bhola Nutan Biddut BD LTD	IPP	220	220	222	4417882	
120	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	35	184400	Line O/L
Barisal Area Total				2046	950	18076444	
121	Baghabari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW G						