

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2021										Day : Tuesday				Date : 14.09.21				
Probable Maximum Demand : 13500 MW										Probable Maximum Generation : 14230 MW								
Water Level of Kaptai Lake at 06:00 AM										Yesterday = 105.50 ft				Today = 105.49 ft				
										Rule Curve = 101.99 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.09.21 (Yesterday)		14.09.21 (Today)		13.09.21 (Yesterday)	14.09.21 (Today)		13.09.21 (Yesterday)	14.09.21 (Today)		Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)			Probable Peak Generation (MW)			Probable Peak Generation (MW)					
					Day	Evening	Day	Evening		Day	Evening		Day	Evening				
(A) Plants in operation:																		
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0				260		Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				180		Under project work			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0				190		Gas shortage			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+ 1x 126	365	365	203	55	203	203				126		STG Under maint			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0			108			Gas Shortage			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0				105		CB Problem			
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				20		Gas Shortage			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	161	251	300	300				109		Gas Shortage			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300				150		Gas Shortage			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0					115		Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	111	111	120	120			301			Gas Shortage			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	37	87	100	100			123			Gas Shortage			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	300	329	326	335									
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	285	300	305	305									
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	41	55	55	55									
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	47	13	10	10									
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102									
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	17	22	22									
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x0.67+1x0.73	80	80	54	46	46	46									
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x0.73	33	33	25	25	25	25									
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	6x0.73	33	33	33	33	33	33									
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	51	25	51									
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	72	70	72									
23	Kodda 150MW PP	HFO (BRDB-RPCL)	9x17.06	149	149	133	150	149	149									
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54									
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	275	277	300	300									
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	133	149	149	149									
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	228	100	300									
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	100	100	100									
29	Aurhatt 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	88	93	50	100									
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	55	55	55	55									
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55									
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	89	92	90	92									
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162									
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	28	0	30	0									
Dhaka Zone Total				5717	5560	2917	3262	3336	3595	1001	786							
35	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	169	169	156	169				40		Unit 2 under overhauling			
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	110	110	110			70			Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180			Gas Shortage			
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0									
38	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25									
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0									
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50									
41	Sikalbaha 105 MW PP (Baraka Sikab	HFO (IPP)	6x18.415	105	105	88	105	105	105									
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0				150		Under maint.			
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+ 1 x 75	225	225	0	0	0	0				225		HGPI awaiting for purchase committee approval			
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	107	303	300	300									
45	Julda 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	92	100	100	100									
46	Julda 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90									
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	68	85	85	85									
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0						Environment Issue			
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	20	21									
	* Malancha Ctg.EPZ (United)	Gas	5x8.73+3x9.34			6	16	15	20									
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0									
51	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54									
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110									
53	Julda unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	95	100	100	100									
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	100	114	116	116									
Chattogram Zone Total				2442	2382	1185	1452	1461	1455	250	415							
55	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	0	0	0	0			135			Gas Shortage			
	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0			129			Gas Shortage			
	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			134			Gas Shortage			
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	23	23	23									
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	205	213	210	210									
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	285	280	300	300									
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	285	280	300	300									
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	40	40	55	55									
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	26	26			187			Gas shortage			
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	35	35	35									
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	135	130	135									
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	47	0	50									
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	140	139	140	141									
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	179	180	180	180									
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22									
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11									
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33									
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43									
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	9	9	9									
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	36x1.4+0x1.015+15x1.036	200	200	100	200	100	200									
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	114	114	98	114									
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	98	99	100	100									
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	18	17	18									
**	Imporgt (Tripura)	India		160	160	114	144	138	164									
				3094	3034	1882	2073	1970	2169	585	0							
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	105	132	130	150			70			Gas Shortage			
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	19	22	22									
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8						Dependable cap. : BMW			
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	27	115	115										

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.09.21 (Yesterday)		14.09.21 (Today)		13.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	22	30	30		48	GT1 Load gear problem		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	Under maint.		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	25	25	25					
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage		
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	155	161	160	162	169		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	74	80	80	80					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	221	225	225					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	22	24	24					
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	285	341	341					
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	316	316	402	402					
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	330	330	383	383					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
Sylhet Zone Total						2422	2377	1573	1636	1844	1846	255	138	
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	260	255	250	280					
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	18	0	20			Line Overload		
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload		
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	210	229	225	225					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	97	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105					
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			Line Overload		
**	Bheramara (HVDC) India			1000	1000	715	700	727	727					
Khulna Zone Total						2133	2129	1294	1404	1457	1597	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload		
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	33	33	33					
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	88	87	87	87		107	Arrival of GT2 HGPI experts delayed due to covid 19		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	42	22	30	30					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	330	520	622	622		724	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	150	150					
114	Bhola 220MW CCPP (Nutan Bidyut BCL)	Gas/HSD (IPP)	2x75+1x70	220	220	221	219	220	220					
Barishal Zone Total						2046	2046	698	916	1252	1252	0	831	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	184	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	30	30	30					
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	18	27	27	27					
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	85	92					
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35					
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	43	43					
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	0	25					
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	181	148	160	180	72		Gas Shortage		
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	197	190	200	200					
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	411	414	400	410					
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	17	17	17					
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	0	11	11					
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	43	43	43					
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113					
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113					
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0					
Rajshahi Zone Total						2179	2179	1108	1524	1498	1589	453	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	76	77	77	77	8		Coal Shortage		
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	107	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
Rangpur Zone Total						685	605	188	190	198	210	8	359	
Sub-total: Plants in operation						21435	21021	11105.0	12951	13540	14230	2622	2529	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10540	12292	12851	13506					
(B) Plants under long term maintenance/ contract expired														
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0					
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired						596	159	0	0	0	0			
Gross Total						22031	21180	11105	12951	13540	14230	2622	2529	
(C) Actual data of 13.09.21 (Yesterday) Monday :														
01.	Max. Demand at eve. peak (Generation end)	:	12951.00	MW,	at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12292.00	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12951.00	MW,	at =	21:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	10028.00	MW,	at =	8:00 hrs	Dhaka	4359	4359	0	Mymensingh	993	993	0
05.	Day-peak Generation (Generation end)	:	11105.00	MW,	at =	12:00 hrs	Chattogram	1229	1229	0	Sylhet	569	569	0
06.	Evening-peak Generation (Generation end)	:	12951.00	MW,	at =	21:00 hrs	Khulna	1498	1498	0	Barisal	372	372	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Rajshahi	1330	1330	0	Rangpur	734	734	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9433.00	MW,	at =	5:00 hrs	Cumilla	1208	1208	0				
09.	Generation shortfall at evening peak due to :	:									Total	12292	12292	0
a)	Gas limitation	:	2614	MW			13.	Fuel cost :	(a) Gas = 137099621 Taka	(c) Coal = 62277479 Taka				
d)	Coal supply Limitation	:	8	MW				(b) Oil = 882111460 Taka	Total = 1081488560 Taka					
b)	Low water level in Kapitai lake	:	0	MW										
c)	Plants under shut down/ maintenance	:	2529	MW			14.	Maximum Temperature in Dhaka was :	33.5° C					
10.	Total Energy (Generation + India Import)	:	281.15	MKWh			15.	Export through East-West interconnections :						
	By Gas = 136.641 MKWh							At evening peak-hour	: -114 MW,	at	21:00 hrs			
	By Coal = 13.508 MKWh							Maximum	: -206 MW,	at	1:00 hrs			
	By Solar= 0.653 MKWh							Energy	: 2.236 MKWh					
11.	Total Gas Supplied	:	1087.05	MMCFD										
(D) Forecast of 14.09.21 (Today) Tuesday :														
01.	Maximum Demand	:	13500	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14230	MW	(Generation end)		05.	Total Generation	:	293.07	MKWh			
03.	Maximum Shortage	:	-730	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.2° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation