

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2021				Day : Saturday		Date : 18.09.21						
Probable Maximum Demand : 12800 MW				Probable Maximum Generation : 14577 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 105.56 ft		Today = 105.71 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.09.21 (Yesterday)		18.09.21 (Today)		17.09.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	18.09.21 (Today) Gen. shortfall for : Gas/water/Coal limitation MW	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	310	310	126	Gas shortage	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	252	320	300	280	40	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	116	116	116	116	296	GBC problem	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	37	92	100	100	118	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	250	331	335	335			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	260	325	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	21	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	70	70			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	16	100	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	21	22	22			
18	Sumnit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	41	55	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	33	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	25	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	72	52	100			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	32	149	149			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	35	35			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	34	195	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	91	115	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300			
28	Bramhangsan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	70	90	95	95			
33	Meghnaghat 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	27	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	18	0	30	0			
Dhaka Zone Total				5717	5560	1985	2818	3491	3767	626	1082	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	166	169	168	168	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	115	115	65	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25			
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	19	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	50	50			
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	88	105	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	246	300	300			
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	10	100	100			
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	100	100	100			
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	71	0	85			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	0	20	21			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			27	42	10	30			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	50			
51	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	54	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	107	110	110	110			
53	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	100	100	100			
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	94	114	116	116			
Chattogram Zone Total				2442	2382	673	1236	1398	1529	245	415	
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	23	13	23			
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	212	189	200	200			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	270	275	320	310			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	275	340	330			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	56	55	55			
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	26	8	8	169	Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	78	127	138	140			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	141	140	140			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	192	200	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	5	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	25	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	18	21	21			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.015+1x1.086	200	200	0	0	150	200			
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	114	114	114			
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	99	105	98	98			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Impoport (Tripura)	India		160	160	98	116	138	164			
Cumilla Zone Total				3094	3034	1647	1826	2113	2231	567	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	131	145	150	150	57	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	0	8	8		Dependable cap. : 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	55	115	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	35	198	175	200			
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
82	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	18	0	50	0			
83	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	0	22	22	22			
Mymensingh Zone Total				717	709	260	499	544	517	57	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.09.21 (Yesterday)		18.09.21 (Today)		17.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT1 Load gear problem		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	Under maint.		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	53	51	51					
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage		
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	158	162	161	162	168		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	78	78	78					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	156	220	225	225					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	23	23	24	24					
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	310	341	341					
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	316	317	316	316					
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work		
Sylhet Zone Total						2422	2377	1456	1687	1720	1721	254	130	
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCPP	Gas (NWPGLCL)	1 x 278+1 x 132	410	410	270	405	400	400					
102	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	27			Line Overload		
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload		
104	Khulna 225 MW CCPP	HSD (NWPGLCL)	1 x 150+1x75	230	230	227	180	225	225					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	100	20	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	101	102	105	105					
107	Madhumati 100 MW PP	HFO (NWPGLCL)	6x18.415	105	105	0	0	100	100			Line Overload		
**	Bheramara (HVDC)	India		1000	1000	714	714	727	727					
Khulna Zone Total						2133	2129	1412	1421	1607	1724	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload		
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	18	30	33	33					
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	40	65	65		154	Arrival of GT2 HGPI experts delayed due to covid 19		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	66	21	22	22					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	500	622	622		744	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150					
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	200	224	220	220					
Barishali Zone Total						2046	2046	584	815	1222	1222	0	898	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	31					
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	27	27					
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	94	90	94					
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40					
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	43					
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	0	25					
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGLCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGLCL)	1x150 + 1x75	220	220	206	193	206	206	27		Gas Shortage		
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGLCL)	1x141+1x79	220	220	176	200	200	220					
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	309	418	400	400					
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22					
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
131	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	8	52	52	52					
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113					
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	113	113	113					
134	Sirajgonj 6.55 MW Solar	Solar (NWPGLCL)	1x6	6	6	2	0	6	0					
Rajshahi Zone Total						2179	2179	800	1241	1520	1647	408	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	79	80	80	6		Coal Shortage		
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	16					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	37	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
Rangpur Zone Total						685	605	124	192	201	219	6	359	
Sub-total: Plants in operation						21435	21021	8941.0	11735	13816	14577	2163	2884	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						8562	11238	13230	13960					
(B) Plants under long term maintenance/ contract expired														
142	Kaipoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0					
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired						596	159	0	0	0	0			
Gross Total						22031	21180	8941	11735	13816	14577	2163	2884	
(C) Actual data of 17.09.21 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)	:	11735.00	MW,	at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11238.00	MW,	at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12082.00	MW,	at =	1:00 hrs	Dhaka	3777	3777	0	Mymensingh	1026	1026	0
04.	Minimum Generation (Generation end)	:	8941.00	MW,	at =	9:00 hrs	Chattogram	1086	1086	0	Sylhet	503	503	0
05.	Day-peak Generation (Generation end)	:	8941.00	MW,	at =	12:00 hrs	Khulna	1444	1444	0	Barisal	336	336	0
06.	Evening-peak Generation (Generation end)	:	11735.00	MW,	at =	21:00 hrs	Rajshahi	1202	1202	0	Rangpur	730	730	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Cumilla	1134	1134	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8939.00	MW,	at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:												
	a) Gas limitation	:	2157	MW			13.	Fuel cost :	(a) Gas = 146507016 Taka	(c) Coal = 58559959 Taka				
	d) Coal supply Limitation	:	6	MW				(b) Oil = 487501627 Taka	Total = 692568602 Taka					
	b) Low water level in Kapta lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	2884	MW			14.	Maximum Temperature in Dhaka was :	32.5° C					
10.	Total Energy (Generation + India Import)	:	247.93	MKWh			15.	Export through East-West interconnections :						
	By Gas =	144.132	MKWh	By Oil =	67.110	MKWh		At evening peak-hour	:	-230	MW,	at	21:00 hrs	
	By Coal =	12.631	MKWh	By Hydro =	3.988	MKWh		Maximum	:	-382	MW,	at	18:30 hrs	
	By Solar=	0.471	MKWh					Energy	:	0.597	MKWh			
11.	Total Gas Supplied	:	1127.91	MMCFD										
(D) Forecast of 18.09.21 (Today) Saturday :														
01.	Maximum Demand	:	12800	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14577	MW	(Generation end)		05.	Total Generation	:	262.66	MKWh			
03.	Maximum Shortage	:	-1777	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.1° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation