

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

| Date : 19-Sep-21      |                                  |                | Page -2             |          |            |                  |                     |
|-----------------------|----------------------------------|----------------|---------------------|----------|------------|------------------|---------------------|
| No.                   | Name of the Power Stations       | Producer       | Installed Capacity  | Capacity | Peak Hour  | Energy Generated | Remarks             |
|                       |                                  |                | Unit No. X Capacity | MW       | Generation | KWH              |                     |
| 1                     | Ghorasal Repowered CCPP-Unit-    | PDB            | 1*260               | 260      | 0          | 0                | Under maint.        |
| 2                     | Ghorasal Repowered CCPP Unit-    | PDB            | 1*210               | 180      | 0          | 0                | Under maint.        |
|                       | Ghorasal TPP Unit-5              | PDB            | 1*210               | 190      | 0          | 0                | Gas shortage        |
| 3                     | Ghorasal 365 MW CCPP Unit-7      | PDB            | 1*243+1*122         | 365      | 310        | 7364336          | Machine problem     |
|                       | Ghorasal 78.5 MW PP(MAX)         | ORPP           | 2*40                | 0        | 0          | 0                | Contract Expired    |
| 4                     | Ghorasal 108MW PP (Regent)       | IPP            | 34*3.35             | 108      | 0          | 0                | Gas shortage        |
| 5                     | Haripur GTTP                     | SBU, PDB       | 2*32                | 20       | 0          | 0                | Under maint.        |
| 6                     | Haripur 412 MW CCPP              | EGCB           | 1*273+1*139         | 412      | 392        | 8738820          | Machine problem     |
| 7                     | Haripur 360MW CCPP(HPL)          | IPP            | 1*235+1*125         | 360      | 213        | 6268800          | Gas shortage        |
| 8                     | Meghnaghat 450 MW CCPP(MPL)      | IPP            | 2*150+1*150         | 450      | 280        | 6940000          | Dirty Gas           |
| 9                     | Meghnaghat 100 MW(IEL)           | ORPP           | 12*8.9              | 0        | 0          | 0                | Contract Expired    |
| 10                    | Meghnaghat CCPP(Summit)          | IPP            | 2*110+1*110         | 305      | 310        | 6656116          | FGMO                |
| 11                    | Madanganj 102 PP(Summit)         | ORPP           | 6*17                | 0        | 0          | 0                | Contract Expired    |
| 12                    | Madanganj-55 MW PP(Summit)       | (IPP)          | 3*17.08+1*11.3      | 55       | 55         | 1267755          |                     |
| 13                    | Keraniganj 100 MW PP (Powerpac)  | ORPP           | 8*13.45             | 100      | 0          | 0                | 161423              |
| 14                    | Narsinghdi 22 MW PP (Doreen)     | SIPP, REB      | 8*2.90              | 22       | 13         | 413784           |                     |
| 15                    | 210 MW Siddhirgonj TPP           | PDB            | 1*210               | 115      | 0          | 0                | Under maint.        |
| 16                    | Siddhirgonj 2120 MW GTTP         | EGCB           | 2*105               | 210      | 0          | 0                | Gas shortage        |
| 17                    | Siddhirgonj 102 PP(Summit)       | ORPP           | 12*8.9              | 0        | 0          | 0                | Contract Expired    |
| 18                    | Siddhirgonj 335 MW CCPP          | EGCB           | 1*217+1*118         | 335      | 251        | 6098348          | Gas shortage        |
| 19                    | Gaaganar 102 MW PP (Digital Po   | IPP            | 12*8.924            | 102      | 64         | 921600           | Low demand          |
| 20                    | Katpali 52 MW PP (Sinha)         | IPP            | 7*7.9               | 51       | 0          | 0                | Fuel shortage       |
| 21                    | Kamalaghat 54 MW PP(Banco En     | IPP            | 3*18                | 54       | 35         | 513000           | Engine problem      |
| 22                    | Kodda 150MW PP                   | BPDB-RPCL      | 9*17.06             | 149      | 64         | 678720           | Low demand          |
| 23                    | Manikganj 55 MW PP (Northern)    | IPP            | 3*19.3              | 55       | 55         | 830564           |                     |
| 24                    | Nababganj 55 MW PP (Southern)    | IPP            | 3*19.3              | 55       | 55         | 764450           |                     |
| 25                    | Bosila 108MW PP(RCL)             | IPP            | 12*8.775+1*3.5      | 108      | 0          | 0                | Fuel shortage       |
| 26                    | Summit Power (Madhabadi-Ashuli   | SIPP, REB      | 3*3.67+4*8.73       | 80       | 54         | 1246560          | Engine problem      |
| 27                    | Maona 33 MW PP(Summit)           | SIPP,REB       | 4*8.73              | 33       | 33         | 822800           |                     |
| 28                    | Rupganj 33 MW PP(Summit)         | SIPP,REB       | 4*8.73              | 33       | 33         | 815700           |                     |
| 29                    | Gazipur 52 MW PP                 | IPP            | 6*8.9               | 52       | 51         | 525120           |                     |
| 30                    | Tongi 80 MW GTTP                 | PDB            | 1*105               | 105      | 0          | 0                | Under maint.        |
| 31                    | Kodda 300 MW PP Unit-2 (Summ     | IPP            | 18*17.076           | 300      | 277        | 5504943          |                     |
| 32                    | Keraniganj 300 MW PP (APR)       | IPP            | 25*11.4             | 300      | 0          | 0                | Reserve.            |
| 33                    | Bramhangon 100 MW PP (Aggr       | IPP            | 100                 | 100      | 0          | 0                | Reserve.            |
| 34                    | Aurahati 100MW PP (Aggreko)      | IPP            | 0.85*23+0.95*91     | 100      | 0          | 0                | Reserve.            |
| 35                    | Kodda 149 MW PP Unit-1 (Summ     | IPP            | 149                 | 149      | 149        | 3161952          |                     |
| 36                    | Gazipur 100 MW PP                | RPCL           | 100 MW              | 105      | 105        | 1224000          |                     |
| 37                    | Meghnaghat 104 MW PP (OPCL)      | IPP            | 18.5*6              | 104      | 94         | 1756800          | Engine problem      |
| 38                    | Manikgonj 162MW PP(MPGL)         | IPP            | 9*18                | 162      | 162        | 3100320          |                     |
| 39                    | Spectra Solar Plant Ltd.         | IPP            | 35                  | 35       | 0          | 100032           |                     |
| Dhaka area Total      |                                  |                |                     | 5719     | 3055       | 65775143         |                     |
| 40                    | Chattogram TPP-1                 | PDB            | 1*210               | 180      | 120        | 2800000          | Gas shortage        |
|                       | Chattogram TPP-2                 | PDB            | 1*210               | 180      | 0          | 0                | Gas shortage        |
| 41                    | Razzan 25 MW PP                  | IPP            | 3*8.9               | 25       | 25         | 96458            |                     |
| 42                    | Teknaf 20MW PP (SolarTech/Teknaf | Solaretech     | 20                  | 20       | 0          | 21060            |                     |
| 43                    | Patenga 50MW PP (Baraka)         | IPP            | 8*6.98              | 50       | 50         | 286560           |                     |
| 44                    | Kaptai Hydro: Unit-1,2,3,4, 5    | PDB            | 2*40+3*50           | 230      | 166        | 3950560          | Low water level     |
| 45                    | Sikalbaha 225MW                  | PDB            | 1*150+1*175         | 225      | 0          | 0                | Under maint.        |
| 46                    | Sikalbaha Peaking GT             | PDB            | 1*150               | 150      | 0          | 0                | Under maint.        |
| 47                    | Sikalbaha 105 MW PP (Baraka St   | IPP            | 105 MW              | 105      | 105        | 2380290          | Engine problem      |
| 48                    | Hathazari 100 MW peaking PP      | IPP            | 11*8.9              | 98       | 0          | 0                | Under S/D           |
| 49                    | Dohazari-Kalash 100 MW Peakr     | PDB            | 6*17                | 102      | 85         | 399964           | Engine problem      |
| 50                    | Juidah 100 MW Unit-1 (Acom)      | ORPP           | 8*13.45             | 100      | 20         | 294240           |                     |
| 51                    | Juidah 100 MW PP Unit-3 (Acom)   | IPP            | 0                   | 100      | 90         | 1768320          |                     |
| 52                    | Barabkunda 22 MW PP (Regent)     | SIPP, PDB      | 8*2.90              | 22       | 21         | 493104           |                     |
|                       | * Malancha, Cig, EP2 (United)    |                | 5*8.73+3*9.34       | 0        | 17         | 453120           |                     |
| 53                    | Chattogram 108 MW PP (ECPV)      | IPP            | 16*7                | 108      | 88         | 2117760          | Engine problem      |
| 54                    | Kaptai 7 MW Solar PP             | PDB            | 7.4 MW              | 7        | 0          | 7439             |                     |
| 55                    | Anwara 300 MW PP (United)        | IPP            | 300 MW              | 300      | 304        | 4968000          |                     |
| 56                    | Jodiac Power                     | IPP            | 3*18.55+1*3.6       | 54       | 54         | 638192           |                     |
| 57                    | Karnaphuli Power Ltd.            | IPP            | 110                 | 110      | 110        | 2613625          |                     |
| 58                    | Juidah unit-2 (Acom)             | IPP            | 8*13.6              | 100      | 100        | 1886400          |                     |
| 59                    | Anilma Energy Ltd.               | IPP            | 6*21.2              | 116      | 114        | 2382382          |                     |
| Chattogram area Total |                                  |                |                     | 2382     | 1469       | 27557474         |                     |
| 60                    | Ashuganj TPP Unit-3              | APSCL          | 1*150               | 135      | 0          | 0                | Gas shortage        |
|                       | Ashuganj TPP Unit-4              | APSCL          | 1*150               | 129      | 0          | 0                | Gas shortage        |
|                       | Ashuganj TPP Unit-5              | APSCL          | 1*150               | 134      | 0          | 0                | Gas shortage        |
| 61                    | Ashuganj 225 MW CCPP             | APSCL          | 1*142+1*75          | 221      | 213        | 4669000          | FGMO                |
| 62                    | Ashuganj 450 MW CCPP(North)      | APSCL          | 1*360               | 360      | 265        | 7122300          | FGMO                |
| 63                    | Ashuganj 450 MW CCPP(South)      | APSCL          | 1*360               | 360      | 270        | 7236000          | FGMO                |
| 64                    | Ashuganj 50 MW PP                | RPP            | 14*3.968            | 45       | 23         | 511272           | Engine problem      |
| 65                    | Ashuganj 55 MW PP (Precision)    | RPP            | 15*4                | 55       | 56         | 1344000          |                     |
| 66                    | Ashuganj 195MW PP (APSCL-UN      | IPP            | 20*9.73+1*16        | 195      | 36         | 669090           | Gas shortage        |
| 67                    | Ashuganj 51 MW PP (Midland)      | IPP            | 6*9.34              | 51       | 43         | 1011510          | Engine problem      |
| 68                    | Ashuganj 150MW PP (Midland)      | IPP            | 23*7.015            | 150      | 144        | 3129672          |                     |
| 69                    | Titas 50 MW Peaking PP           | PDB            | 6*8.92              | 52       | 0          | 88656            | Reserve.            |
| 70                    | Chandpur 150 MW CCPP             | PDB            | 1*106+1*57          | 163      | 140        | 3358030          | Machine problem     |
| 71                    | Chandpur 200MW (Desh energy)     | IPP            | 0                   | 200      | 200        | 3566880          |                     |
| 72                    | Feni 22MW PP (Doreen)            | SIPP, PDB      | 8*2.90              | 22       | 22         | 512496           |                     |
| 73                    | Feni 11 MW PP (Doreen)           | SIPP, REB      | 4*2.90              | 11       | 11         | 242280           |                     |
| **                    | Impoport (Tripura)               | Imported power | 0                   | 160      | 130        | 2646720          |                     |
| 74                    | Jangalia 33MW PP (Summit)        | SIPP, PDB      | 4*8.73              | 33       | 29         | 641000           |                     |
| 75                    | Jangalia 52 MW PP (Lakdanavi)    | IPP            | 6*8.92              | 52       | 52         | 417595           |                     |
| 76                    | Comilla 25 MW PP (Summit)        | SIPP, PDB      | 3*3.67+2*6.97       | 25       | 21         | 451650           | Engine problem      |
| 77                    | Daudkandi 200 MW PP (B.Trac)     | IPP            | 154*1.4             | 200      | 0          | 0                | Reserve.            |
| 78                    | Feni Lanka Power                 | IPP            | 7*18.415+1*9.78     | 114      | 98         | 1543560          |                     |
| 79                    | Chowmuhani 113 MW                | IPP            | 12*9.78+2*3.1       | 113      | 97         | 2157120          | Engine problem      |
| 80                    | Bhairab 54.5 MW                  | IPP            | 3*18.2              | 54       | 17         | 444600           | 33 KV feeder fault. |
| Cumilla Area Total    |                                  |                |                     | 3034     | 1867       | 41763431         |                     |
| 81                    | RPCL 210MW CCPP                  | IPP            | 4*35+1*70           | 202      | 147        | 3050560          | Gas shortage        |
| 82                    | Tangail 22 MW PP (Doreen)        | SIPP, PDB      | 8*2.90              | 22       | 19         | 425220           |                     |
| 83                    | Jamalpur 95 MW PP(Powerpac)      | IPP            | 12*8.924            | 95       | 0          | 42240            | Engine problem      |
| 84                    | Sarishabari 3 MW Solar Plant     | IPP            | 1*3                 | 3        | 0          | 9950             |                     |
| 85                    | Mymensingh 200 MW PP (United     | IPP            | 200                 | 200      | 200        | 2712000          |                     |
| 86                    | Jamalpur 115 MW PP (United)      | IPP            | 115 MW              | 115      | 115        | 2534400          |                     |
| 87                    | Sultakhal 50 MW Solar PP         | IPP            | 50                  | 50       | 0          | 289540           |                     |
| 88                    | Tangail Pali Power Gen 22 MW     | IPP            | 4*6.7               | 22       | 22         | 392400           |                     |
| Mymensingh Area Total |                                  |                |                     | 709      | 503        | 9266610          |                     |
| 89                    | Fenchugonj CCPP Phase-1          | PDB            | 2*32+1*33           | 70       | 30         | 647000           | Machine problem     |
| 90                    | Fenchugonj CCPP Phase-2          | PDB            | 2*35+1*35           | 90       | 0          | 0                | Under maint.        |
| 91                    | Kushara 163 MW CCPP (KP)         | IPP            | 1*109+1*54          | 163      | 163        | 3276245          |                     |
| 92                    | Shahjibazar 330 MW CCPP          | PDB            | 3*110               | 330      | 160        | 3731000          | GT-2 under maint.   |
| 93                    | Fenchugonj 51 MW PP (Barakati    | RPP            | 18*2.90             | 51       | 50         | 1136200          |                     |
| 94                    | Fenchugonj 44MW PP (Energyprima  | RPP            | 12*2.3+3*5*2        | 0        | 0          | 0                | Contract Expired    |
| 94                    | Hobiganj 11MW PP Confidence-E    | SIPP, REB      | 4*2.90              | 11       | 8          | 153696           |                     |
| 95                    | Shahjibazar GTTP Unit- 8 & 9     | PDB            | 2*35                | 66       | 0          | 0                | Gas shortage        |
| 96                    | Shahjibazar 86MW PP (Shahjibaz   | RPP            | 32*2.90             | 86       | 78         | 1881600          |                     |
| 97                    | Shahjibazar 100 MW GTTP          | PDB            | 1*100               | 100      | 0          | 0                | Under Shut down     |
| 98                    | Sylhet 225 MW CCPP               | PDB            | 1*142+1*89          | 231      | 145        | 4113110          |                     |
| 99                    | Sylhet 20 MW GTTP                | PDB            | 1*20                | 20       | 0          | 0                | Gas shortage        |
|                       | Sylhet 50MW PP (EPL)             | RPP            | 27*2                | 0        | 0          | 0                | Contract Expired    |
| 100                   | Shahjahanulla 25 MW PP           | SIPP, REB      | 3*9.34              | 25       | 24         | 578760           |                     |
| 101                   | Bibiana-II 341 MW CCPP (Summ     | IPP            | 1*222+1*119         | 341      | 300        | 7177040          | FGMO                |
| 102                   | Bibiyana-III 400 MW CCPP         | PDB            | 400 MW              | 400      | 316        | 7611000          | Gas shortage        |
| 103                   | Sylhet 10MW PP (Desh)            | RPP            | 6*1.95              | 10       | 0          | 0                | Gas shortage        |
| 104                   | Bibiyana South 400 MW            | PDB            | 400 MW              | 383      | 320        | 7652100          | Gas shortage        |
| Sylhet Area Total     |                                  |                |                     | 2377     | 1594       | 37869751         |                     |
| 105                   | Bheramara GTTP Unit-3            | PDB            | 1*20                | 16       | 0          | 0                | Reserve.            |
| **                    | Bheramara (HVDC )                | Imported power | 2*500               | 1000     | 715        | 17294545         |                     |
| 106                   | Khulna 115 PP MW (KPCL-2)        | ORPP           | 7*17                | 0        | 0          | 0                | Contract Expired    |
| 107                   | Faridpur 50 MW Peaking PP        | PDB            | 8*6.89              | 54       | 33         | 74400            | Engine problem      |
| 108                   | Khulna 225 MW CCPP               | NWPGCL         | 1*150+1*75          | 230      | 230        | 3515520          |                     |
| 109                   | Copalganj 100 MW Peaking PP      | IPP            | 16*8.98             | 109      | 0          | 0                | Line O/L            |
| 110                   | Bheramara 410 MW CCPP            | NWPGCL         | 1*278+1*132         | 410      | 405        | 9199872          |                     |
|                       | Noapara 40 MW PP (Khanjahan A    | ORPP           | 5*8.5               | 0        | 0          | 0                | Contract Expired    |
| 111                   | Noapara 100 MW PP (Bangla Tre    | IPP            | 70*1.4              | 100      | 20         | 81600            | Low demand          |
| 112                   | Rupsha 105 MW PP (Orion rupsh    | IPP            | 6*18.445            | 105      | 105        | 1230720          |                     |
| 113                   | Madhumati 100 MW PP              | NWPGCL         | 100 MW              | 105      | 0          | 0                | Line O/L            |
| Khulna Area Total     |                                  |                |                     | 2129     | 1508       | 31398657         |                     |
| 114                   | Barisal 110 MW PP (Summit )      | IPP            | 7*17.076            | 110      | 0          | 0                | Line O/L            |
| 115                   | Bhola 33 MW PP (Venture)         | RPP            | 1*34.50             | 33       | 27         | 506902           |                     |
| 116                   | Bhola 225 MW CCPP                | PDB            | 2*63+1*68           | 194      | 67         | 1584000          |                     |
| 117                   | Bhola 95 MW PP (Aggreko)         | ORPP           | 96*1.10             | 95       | 22         | 400492           | Gas shortage        |
| 118                   | Payra 1320 MW                    | BCPCL          | 2*622               | 1244     | 480        | 10385600         | Line O/L            |
| 119                   | Bhola Nutan Biddut BD LTD        | IPP            | 220                 | 220      | 225        | 4508836          |                     |
| 120                   | United Payra Power Ltd.          | IPP            | 8*18.5+1*9.5        | 150      | 0          | 108000           | Reserve.            |
| Barisal Area Total    |                                  |                |                     | 2046     | 821        | 17483330         |                     |
| 121                   | Baghabari 71 MW GTTP             | PDB            | 1*71                | 71       | 0          | 0                | Gas shortage        |
|                       | Baghabari 100 MW GTTP            | PDB            | 1*100               | 100      | 0          | 0                | Gas shortage        |
| 122                   | Baghabari 50 MW Peaking PP       | PDB            | 6*8.9               | 52       | 50         | 107456           |                     |
| 123                   | Bera 70 MW Peaking PP            | PDB            | 9*8.29              | 71       | 10         | 14151            | Low demand          |
| 124                   | Ammura 50 MW PP(Sinha)           | ORPP           | 7*7.79              | 50       | 27         | 152110           | Engine problem      |
| 125                   | Katakhal 50 MW PP (Northern)     | ORPP           | 6*8.9               | 50       | 43         | 127318           | Engine problem      |
| 126                   | Katakhal 50 MW Peaking PP        | PDB            | 6*8.7               | 50       | 38         | 69999            | Engine problem      |
| 127                   | Sirajgonj Unit-1 225MW           | NWPGCL         | 1*150+1*75          | 210      | 0          | 0                | Gas shortage        |