

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2021				Day : Thursday				Date : 23.09.21						
Probable Maximum Demand : 12700 MW				Probable Maximum Generation : 14886 MW				Rule Curve = 104.08 ft.						
Water Level of Kaptai Lake at 06:00 AM				Today = 106.68 ft.										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.09.21 (Yesterday)		23.09.21 (Today)		22.09.21 (Yesterday)		23.09.21 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening	Day	Evening	Day	Evening	Description/ Remarks	Probable start-up date
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190		Gas shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	310	310		126			
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0		108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		CB Problem	
6	Hariapur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20		Gas Shortage	
7	Hariapur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	168	173	271	300		187		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280		170		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Hariapur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	398	395	412	412		17			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	325	335	334	335					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	280	280	305	305					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55					
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	2	40	60	60					
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	102	100	102					
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	21	22	22					
18	Summit Power (Madhabadi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	53	45	55	55					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	43	51	51					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	54	105	52	100					
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	150	149	149					
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	35	35					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	275	293	280	280					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149					
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300					
28	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100					
29	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	101	50	100					
30	Nababganj 55 MW PP (Southern pow)	HFO (IPP)	3x19.3	55	55	20	35	55	55					
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55					
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	94	94	94	94					
33	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	126	144	162	162					
34	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	23	0	30	0					
Dhaka Zone Total					5717	5560	2848	3288	3632	3932	885	803		
35	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	166	166	168	168		40		Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120		60		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Gas Shortage	
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
38	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	25	25	25					
39	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	19	0	20	0					
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	11	50	50	50					
41	Sikalbaha 105 MW PP (Baraka Sikalbi)	HFO (IPP)	6x18.415	105	105	89	89	105	105					
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225		HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	252	305	300	300					
45	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	50	100	100					
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	75	78	100	100					
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	0	102					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				Environment Issue	
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	20	21					
*	Malancha, Ctg. EPZ (United)	Gas	5x8.73+3x9.34			2	5	13	20					
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	79	86	88	88					
51	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	31	54	54					
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110					
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100					
54	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	108	108	116	116					
Chattogram Zone Total					2442	2382	1171	1443	1494	1579	240	415		
55	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	0	0	0	0		135		Gas Shortage	
	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0		129		Gas Shortage	
	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0		134		Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	20	23	23	23					
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	188	180	210	210					
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	310	305	310	320					
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	330	320	330					
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	56	55	55					
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	55	55		187		Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43					
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	133	129	135	145					
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50					
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	140	138	140	140					
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	175	200	200					
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
68	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	2	11	11	11					
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	34	52	52					
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	21	21					
72	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	89x1.4+8x1.515+15x1.059	200	200	0	25	150	200					
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	84	114	114	114					
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	52	96	95	96					
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
**	Imphort (Tripura)	India		160	160	112	138	138	164					
Cumilla Zone Total					3094	3034	1724	1948	2144	2301	585	0		
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	103	140	120	140		62		Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22					
78	Jamalur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	0	8	8				Dependable cap. : 8MW	
79	Jamalur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	107	115	115	115					
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	161	175	175	200					
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
82	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0					
83	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	19	24	22	22					
Mumensingh Zone Total					717	709	457	473	514	507	62	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.09.21 (Yesterday)		23.09.21 (Today)		22.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT1 Load gear problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	31	51	51				
87	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
89	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	155	162	160	160	168		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	80	81	81				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	206	220	220	220				
93	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	285	341	341				
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	241	316	316	316				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	385	320	320	320				
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
Sylhet Zone Total				2422	2377	1611	1655	1730	1730	254	117		
100	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	260	265	400	400				
102	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	26	0	27			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	220	225	225				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	70	50	100				
106	Rupsha 105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	70	56	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			Line Overload	
**	Bheramara (HVDC)	India	1x100	1000	1000	719	719	729	729				
Khulna Zone Total				2133	2129	1169	1356	1609	1726	0	0		
108	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	28	33	33				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	87	87	87	87		107	Arrival of GT2 HGPI experts delayed due to covid 19	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1x1x96	95	95	12	12	22	22				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	430	622	622		814	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
114	Bhola 220MW CCPP (Nutan Bidyt BI)	Gas/HSD (IPP)	2x75+1x70	220	220	225	219	220	220				
Barishal Zone Total				2046	2046	661	776	1244	1244	0	921		
115	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	34	30	30				
119	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	27	27				
120	Chapainawabganj 100 MW Peaking P	HFO (PDB)	12x8.924	104	104	0	94	90	94				
121	Katakhati 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	30				
122	Katakhati 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0	43				
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	33				
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	183	176	200	220	44		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	189	179	200	220				
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	385	400	400				
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22				
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	43	43				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	113	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	101	113	113				
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
Rajshahi Zone Total				2179	2179	1077	1359	1505	1649	425	0		
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	80	5		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0	274		Under maint.	
136	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	15				
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	67	113	113	113				
138	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Majpara, Tatalia 8 MW Solar PP (Sympa Pow)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total				685	605	152	193	201	218	5	359		
Sub-total: Plants in operation				21435	21021	10870.0	12491	14073	14886	2456	2615		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10404	11955	13469	14247				
(B) Plants under long term maintenance/ contract expired													
140	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogura 20 MW PP (Energyprime)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired				596	159	0	0	0	0				
Gross Total				22031	21180	10870	12491	14073	14886	2456	2615		
(C) Actual data of 22.09.21 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)		12491.00	MW,	at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)		11955.00	MW,	at = 19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)		12491.00	MW,	at = 19:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)		9183.00	MW,	at = 7:00 hrs	Dhaka	4486	4486	0	Mymensingh	957	957	0
05.	Day-peak Generation (Generation end)		10870.00	MW,	at = 12:00 hrs	Chattogram	1287	1287	0	Sylhet	509	509	0
06.	Evening-peak Generation (Generation end)		12491.00	MW,	at = 19:00 hrs	Khulna	1351	1351	0	Barishal	322	322	0
07.	Evening Peak Load-shed (Sub-station end)		0.00	MW,	at = 19:00 hrs	Rajshahi	1188	1188	0	Rangpur	786	786	0
08.	Minimum Generation Forecast up to 8:00 hrs.		9408.00	MW,	at = 5:00 hrs	Cumilla	1069	1069	0				
09.	Generation shortfall at evening peak due to :									Total	11955	11955	0
	a) Gas limitation		2451	MW		13.	Fuel cost :	(a) Gas = 147680744	Taka	(c) Coal = 56672324	Taka		
	d) Coal supply Limitation		5	MW			(b) Oil = 588287747	Taka	Total = 792640815	Taka			
	b) Low water level in Kaptai lake		0	MW									
	c) Plants under shut down/ maintenance		2615	MW		14.	Maximum Temperature in Dhaka was :	33.6° C					
10.	Total Energy (Generation + India Import)		263.68	MKWh		15.	Export through East-West interconnections :						
	By Gas = 146.796	MKWh	By Oil = 79.949	MKWh			At evening peak-hour		-78	MW,	at 19:00 hrs		
	By Coal = 12.205	MKWh	By Hydro = 3.864	MKWh			Maximum		-102	MW,	at 21:00 hrs		
	By Solar= 0.730	MKWh					Energy		0.3175	MKWh			
11.	Total Gas Supplied		1130.87	MMCFD									
(D) Forecast of 23.09.21 (Today) Thursday :													
01.	Maximum Demand		12700	MW	(Generation end)	04.	Maximum Load-shed		0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation		14886	MW	(Generation end)	05.	Total Generation		268.09	MKWh			
03.	Maximum Shortage		-2186	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :		34.2° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation