

Date : 8-Oct-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CAPP-Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP-Unit-4	PDB	1'210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1'210	190	0	0	Gas shortage
3	Ghorasal 385 MW CAPP Unit-7	PDB	1'243+1'122	365	290	7182155	Machine problem
3	Ghorasal 78.5 MW PP(MAX)	ORPP	2'40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	0	0	Gas shortage
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	333	8125840	Gas shortage
7	Haripur 360MW CAPP(HPL)	IPP	1'235+1'125	360	327	6466000	Gas shortage
8	Meghnaghat 450 MW CAPP(WPL)	IPP	2'150+1'150	450	250	6300000	Gas shortage
9	Meghnaghat 100 MW(EL)	ORPP	1'27.9	0	0	0	Contract Expired
10	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	305	285	6607942	FGMO
11	Madanganj 102 PP(Summit)	ORPP	6'17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	45	1042719	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	ORPP	6'13.45	100	37	529783	Engine problem
14	Narshingaj 22 MW F-1 (Doreen)	SIPP, REB	8'2.90	22	18	364660	
15	210 MW Siddhirganj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirganj 2'120 MW GTPP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla)	ORPP	12'8.9	0	0	0	Contract Expired
18	Siddhirganj 335 MW CAPP	EGCB	1'217+1'118	335	333	8016967	
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	102	1652976	
20	Kalpoti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	1302840	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	115	877920	High Voltage.
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	1329528	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	17	1026228	load incrising time.
25	Bosila 108MW PP(CLO)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabad+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	55	1152240	Engine problem
27	Maana 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	815300	
28	Rugganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	792000	
29	Gazipur 52 MW PP	IPP	6'8.9	52	51	393120	
30	Tongi 80 MW GTPP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	300	5251525	
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	85394	Reserve.
33	Bramhanganj 100 MW PP (Aggreko)	IPP	0	100	0	0	Reserve.
34	Aurahat 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	94482	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	147	2826580	High Voltage.
36	Gazipur 100 MW PP	RPCL	100 MW	105	90	1563600	Engine problem
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	104	2255040	
38	Manikganj 162MW PP(MPGL)	IPP	9'18	162	162	3777120	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	1624	
Dhaka area Total				5560	3238	70744589	
40	Chattogram TPP-1	PDB	1'210	180	120	2810000	Gas shortage
41	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
42	Raozan 25 MW PP	IPP	3'8.9	25	25	220334	
42	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	96525	
43	Palenga 50MW PP (Baraka)	IPP	8'8.98	50	46	720000	
44	Kapla Hydro 100 MW PP (2,3,4, 5)	PDB	2'140+3'350	230	160	3791564	Low water level
45	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	105	2299153	
48	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	0	Under SID
49	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	102	817490	
50	Judah 100 MW Unit-1 (Acom)	ORPP	8'13.45	100	62	1149120	Low demand
51	Judah 100 MW Unit-3 (Acom)	IPP	0	100	100	2199360	
52	Baratkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	16	410832	Engine problem
53	Malancha, Ctg. EPZ (United)	IPP	5'8.73+3'9.34	0	42	626400	
53	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	48	612480	Engine problem
54	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	25441	
55	Anwara 300 MW PP (United)	IPP	300 MW	300	305	3886581	High Voltage.
56	Jodlac Power	IPP	3'18.55+1'3.6	54	54	1289581	
57	Karnahat Power Ltd.	IPP	110	110	68	1951882	Low demand
58	Judah unit-2 (Acom)	IPP	8'13.6	100	100	2376000	
59	Anilma Energy Ltd.	IPP	6'21.2	116	116	2578091	
Chattogram area Total				2382	1489	27800834	
60	Ashuganj TPP Unit-3	APSCCL	1'150	135	70	1720164	Gas shortage
61	Ashuganj TPP Unit-4	APSCCL	1'150	129	0	0	Gas shortage
62	Ashuganj TPP Unit-5	APSCCL	1'150	134	0	0	Gas shortage
61	Ashuganj 225 MW CAPP	APSCCL	1'142+1'175	221	137	3336000	ST under maint
62	Ashuganj 450 MW CAPP(North)	APSCCL	1'360	360	270	6947800	FGMO
63	Ashuganj 450 MW CAPP(South)	APSCCL	1'360	360	280	6948000	FGMO
64	Ashuganj 50 MW PP	APSCCL	14'3.968	45	23	400032	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	47	1021920	
66	Ashuganj 195MW PP (APSCCL-United)	IPP	20'9.73+1'16	195	16	301090	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6'8.34	51	51	1245640	
68	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	137	2888787	Engine problem
69	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	91032	Reserve.
70	Chandpur 150 MW CAPP	PDB	1'106+1'57	163	85	1742300	Machine problem
71	Chandpur 200MW (Desh energy)	IPP	0	200	200	3593280	
72	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	19	451980	
73	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	8	223380	
**	Import (Tripura)	Imported power	0	160	118	2345280	
74	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	776100	
75	Jangalia 52 MW PP (Lakdanav)	IPP	6'8.92	52	52	829310	
76	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	21	502430	
77	Dauidkand 200 MW PP (B. Trac)	IPP	154'1.4	200	0	107520	Reserve.
78	Feni Lanka Power Station-2	IPP	7'18.445+1'9.78	114	98	1222080	Engine problem
79	Chowmahani 113 MW	IPP	12'9.78+2'3.1	113	96	1440800	Engine problem
80	Bhairab 54.5 MW	IPP	3'18.2	54	17	438840	33 kv feeder fault.
Cumilla Area Total				3034	1778	38573565	
81	RPCL 210MW CAPP	IPP	4'35+1'70	202	153	3289600	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	481104	
83	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	8	0	0	Under maint.
84	Saristabar 3 MW Solar Plant	IPP	1'3	3	0	10800	
85	Mymensingh 200 MW PP (United)	IPP	200	200	180	3117600	
86	Jamalpur 115 MW PP (United)	IPP	115 MW	115	106	2367600	
87	Sutiakhali 50 MW Solar PP	IPP	50	50	0	279100	
88	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	22	253200	
Mymensingh Area Total				622	483	9799004	
89	Fenchuganj CAPP Phase-1	PDB	2'32+1'33	70	43	1029500	Machine problem
90	Fenchuganj CAPP Phase-2	PDB	2'35+1'35	90	42	817929	Machine problem
91	Kushihara 163 MW CAPP (KP)	IPP	1'109+1'154	163	163	3517118	
92	Shajibazar 330 MW CAPP	PDB	3'110	330	160	3725000	GT-2 under maint
93	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	50	1099800	
94	Fenchuganj 44MW (Energyprima)	RPP	12'3.3+5'2	0	0	0	Contract Expired
94	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	248976	
95	Shajibazar GT Unit- 8 & 9	PDB	2'16	206	66	1386144	
96	Shajibazar 88MW PP (Shajibazar)	RPP	32'2.90	86	81	1897920	
97	Shajibazar 100 MW GTPP	PDB	1'100	100	0	0	Under Shut down
98	Sylhet 225 MW CAPP	PDB	1'142+1'89	231	0	0	
99	Sylhet 20 MW GTPP	RPP	1'20	20	18	389000	
100	Sylhet 50MW PP (EPL)	IPP	27'2	0	0	0	Contract Expired
100	Shajibahannu 25 MW PP	SIPP, REB	3'9.34	25	24	57844	
101	Bibiana-II 341 MW CAPP (Summit)	IPP	1'222+1'119	341	300	7237000	FGMO
102	Bibiana-III 400 MW CAPP	PDB	400 MW	400	322	7813000	Gas shortage
103	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	218700	
104	Bibiana South 400 MW	PDB	400 MW	383	320	7678000	Gas shortage
Sylhet Area Total				2377	1600	37635531	
105	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Reserve.
**	Bheramara 1MW CAPP	Imported power	2'500	1000	708	17091454	
106	Khuilna 115 MW PP (KPCL-2)	ORPP	7'17	0	0	0	Contract Expired
107	Faridpur 50 MW Peaking PP	PDB	8'8.9	54	0	39650	Engine problem
108	Khuilna 225 MW CAPP	NWPGCL	1'150+1'175	230	120	2328000	Low demand
109	Gopalganj 100 MW Peaking PP	PDB	16'8.98	109	0	0	Reserve.
110	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	345	6345792	Gas shortage
111	Noapara 40 MW PP (Kharajahan Ali)	ORPP	5'8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	30720	Reserve.
112	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	105	1548960	
113	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
Khuilna Area Total				2129	1278	27380576	
114	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	0	0	Line O/L
115	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	34	649883	
116	Bhola 225 MW CAPP	PDB	2'83+1'88	194	50	1172332	Machine problem
117	Bhola 95 MW PP (Aggreko)	ORPP	96'1.10	95	53	685235	Gas shortage
118	Payra 1320 MW	BCPCL	2'622	1244	570	13009400	
119	Bhola Nutan Bidut BD LTD	IPP	2'20	220	223	518504	
120	United Payra Power Ltd.	IPP	8'18.5+1'9.5	150	54	439200	Line O/L
Barisal Area Total				2048	984	16484654	
121	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
122	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage
122	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	50	403040	
123	Bera 70 MW Peaking PP	PDB	9'8.29	71	0	29593	Reserve.
124	Amnura 50 MW PP(Sinha)	ORPP	7'7.79	50	0	0	Reserve.
125	Katakhal 50 MW PP (Northern)	ORPP	6'8.9	50	0	57014	Reserve.
126	Katakhal 50 MW Peaking PP	PDB	6'8.7	50	30	172818	Engine problem
127	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'175	210	0	0	Gas shortage
128	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'175	220	181	3723100	Gas shortage
129	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	205	4246073	Gas shortage
130	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1'282+1'132	414	415	9235127	FGMO
131	Santahar 50 MW Peaking PP	PDB	6'8.7	50	34	218520	Engine problem
132	Bogra 22 MW PP (GBB)	RPP	6'4	22	22	483120	
133	Bogra 20 MW PP (Energyprima)	RPP	5'3.3+5'2	0	0	0	Contract Expired
134	Ullapara 11 MW PP (Summit)	SIPP, REB	4'2.90	11	11	251838	
135	Natore 52 MW PP (Rajlanka)	IPP	6'8.92	52	52	512640	
136	Chapanawabganj 100 MW Peaking PP	PDB	12'8.924	104	94	742888	Engine problem
137	Baghabari 200 MW PP (Paramount)	IPP	200 MW	200	0	0	Reserve.
138	Bagura 113 MW PP (Confidence)-2	IPP	113 MW	113	113	2096928	Engine problem
139	Confidence Power Bogura Unit-1 113 MW	IPP	6'18.55	113	113	2154720	
140	Sirajgonj 6.5 MW Solar	NWPGCL	1'6	6	0	14839	
Rajshahi Area Total				2179	1320	2434	