

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2021				Day : Thursday				Date : 30.09.21			
Probable Maximum Demand : 13000 MW				Probable Maximum Generation : 15149 MW				Rule Curve = 106.56 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 106.50 ft.				Today = 106.56 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.09.21 (Yesterday)		30.09.21 (Today)		29.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	310	310	126	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	331	321	340	340	39	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	320	340	340	340	110	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	341	412	412	71	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	255	254	240	240		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	290	275	305	305		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	55	50	55	55		
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	48	68	68		
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	102	102	102		
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	19	22	22		
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	52	51	55	55		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33		
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	51	51	51		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	100	105		
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	150	149	149		
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	275	280	250	300		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	130	149	149	149		
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300		
28	Bramhangsan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
29	Auralahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	55	55		
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	84	94	94	94		
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	24	0	30	0		
Dhaka Zone Total				5717	5560	2970	3332	3714	3989	677	857
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	116	159	157	157	40	Unit 2 under overhauling
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25		
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	0	0	20	0		
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	18	50	50	50		
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	51	105	105	105		
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	305	305	300	300		
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	40	100	100		
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	34	102		
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	18	21	21		
50	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	5	5	15		
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	58	90	90		
52	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
53	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	110	110	110		
54	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
55	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	53	116	116	116		
Chattogram Zone Total				2442	2382	1005	1450	1512	1565	240	415
56	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	80	135	55		Gas Shortage
57	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
58	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	20	23	23	23		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	207	214	210	210		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	285	270	310	340		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	280	310	330		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	55	55	55		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	43	43	43		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	20	130	135	137		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	140	141	140	140		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	36	52	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	19	20	21		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.015+1x1.086	200	200	0	0	150	200		
76	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	50	100	100	100		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	50	96	90	98		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
79	Impoport (Tripura)	India		160	160	90	136	138	164		
Cumilla Zone Total				3094	3034	1543	1927	2147	2389	505	0
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	164	155	150	155	47	Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	22	22		
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	0	0	0		Dependable cap. : 8MW
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	35	165	170	200		
85	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
86	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	34	0	50	0		
87	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	0	23	22	22		
Mymensingh Zone Total				717	709	368	479	531	514	47	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.09.21 (Yesterday)		30.09.21 (Today)		29.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	43	43	43	43		27	GT1 Load gear problem		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35-1x35	104	90	0	0	0	0		90	Under maint.		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50					
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	130	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	63	60	60	3		Gas Shortage		
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	160	161	160	160	169		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	80	81	81					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	193	220	220					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24					
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	270	341	341					
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	303	316	316	316					
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	321	320	320	320					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
Sylhet Zone Total						2422	2377	1561	1686	1817	1817	174	117	
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCPP	Gas (NWPGLCL)	1 x 278+1 x 132	410	410	350	320	400	410					
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	7	0	25			Line Overload		
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload		
104	Khulna 225 MW CCPP	HSD (NWPGLCL)	1 x 150+1x75	230	230	120	170	225	225					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	45	103	70	105					
107	Madhumati 100 MW PP	HFO (NWPGLCL)	6x18.415	105	105	0	0	100	100			Line Overload		
**	Bheramara (HVDC)	India		1000	1000	719	717	734	734					
Khulna Zone Total						2133	2129	1238	1317	1579	1739	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload		
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	18	30	30	30					
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	87	87	88	88		107	Arrival of GT2 HGPI experts delayed due to covid 19		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	22	22	22	22					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	480	622	622		764	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	150					
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	224	228	220	220					
Barishal Zone Total						2046	2046	651	864	1092	1242	0	871	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	36	34	35					
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	28	28					
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	94	90	94					
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	0	40					
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	24	0	50					
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	0	30					
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGLCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGLCL)	1x150 + 1x75	220	220	174	166	200	220	54		Gas Shortage		
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGLCL)	1x141+1x79	220	220	172	167	200	220					
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	336	330	400	400					
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22					
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	52	52					
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113					
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	95	113	113					
134	Sirajgonj 6.55 MW Solar	Solar (NWPGLCL)	1x6	6	6	2	0	6	0					
Rajshahi Zone Total						2179	2179	783	1255	1519	1678	435	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	78	78	5		Coal Shortage		
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0					
Rangpur Zone Total						685	605	117	193	199	216	5	359	
Sub-total: Plants in operation						21435	21021	10236.0	12503	14110	15149	2083	2619	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								9742	11899	13428	14417			
(B) Plants under long term maintenance/ contract expired														
140	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0					
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
145	Meghnaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
146	Khulna 115 MW PP (KPCCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired						596	159	0	0	0	0			
Gross Total						22031	21180	10236	12503	14110	15149	2083	2619	
(C) Actual data of 29.09.21 (Yesterday) Wednesday :														
01.	Max. Demand at eve. peak (Generation end)	:	12503.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11899.00	MW,	at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12503.00	MW,	at =	19:00 hrs	Dhaka	4425	4425	0	Myrnsingh	1021	1021	0
04.	Minimum Generation (Generation end)	:	9031.00	MW,	at =	7:00 hrs	Chattogram	1242	1242	0	Sylhet	543	543	0
05.	Day-peak Generation (Generation end)	:	10236.00	MW,	at =	12:00 hrs	Khulna	1301	1301	0	Barishal	311	311	0
06.	Evening-peak Generation (Generation end)	:	12503.00	MW,	at =	19:00 hrs	Rajshahi	1228	1228	0	Rangpur	725	725	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Cumilla	1103	1103	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9254.00	MW,	at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:												
a)	Gas limitation	:	2078	MW			13.	Fuel cost :	(a) Gas = 166024258	Taka	(c) Coal = 54504168	Taka		
b)	Coal supply Limitation	:	5	MW				(b) Oil = 505877411	Taka	Total = 726405836	Taka			
c)	Low water level in Kapta lake	:	0	MW										
d)	Plants under shut down/ maintenance	:	2619	MW			14.	Maximum Temperature in Dhaka was :	31.2° C					
e)	Total Energy (Generation + India Import)	:	261.45	MKWh			15.	Export through East-West interconnections :						
	By Gas =	161.733	MKWh					At evening peak-hour	:	-126	MW,	at	19:00 hrs	
	By Coal =	11.714	MKWh					Maximum	:	-176	MW,	at	18:30 hrs	
	By Solar=	0.544	MKWh					Energy	:	0.976	MKWh			
11.	Total Gas Supplied	:	1186.20	MMCFD										
(D) Forecast of 30.09.21 (Today) Thursday :														
01.	Maximum Demand	:	13000	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15149	MW	(Generation end)		05.	Total Generation	:	271.84	MKWh			
03.	Maximum Shortage	:	-2149	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.6° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation